IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL 2R G2 22 MD HO UV FA 930.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
[TEST] LLIA001588-035A (s)
[TESTLAB] LightLab International Allentown, LLC
[ISSUEDATE] 3/4/2022
[MANUFAC] Lumen Focus, LLC
[LUMCAT] FFL 2R G2 22 MD HO UV FA 930
[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflectors,
[MORE] two optical compartments each with one frosted linear ribbed plastic enclosure.
[LAMP] 128 white LEDs, two LS3872A8_3000_90R 3000K LED boards
[BALLAST] One ULT D15CC55UNVPW-C LED driver programmed at 1140mA
[OTHER] 120.0Vac, 60.01Hz
[OTHER] This test was performed using the absolute method of photometry.
[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	7749
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	132
Total Luminaire Watts	58.5
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	1.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	7385	7917	8445
55	6807	7564	8336
65	6124	7126	8113
75	5109	6327	7254
85	3223	3396	3049

Photometric Toolbox® Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL 2R G2 22 MD HO UV FA 930.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	1024.68	N.A.	13.20
0-30	2160.08	N.A.	27.90
0-40	3508.43	N.A.	45.30
0-60	6128.37	N.A.	79.10
0-80	7627.34	N.A.	98.40
0-90	7749.15	N.A.	100.00
10-90	7482.73	N.A.	96.60
20-40	2483.76	N.A.	32.10
20-50	3863.8	N.A.	49.90
40-70	3571.16	N.A.	46.10
60-80	1498.97	N.A.	19.30
70-80	547.75	N.A.	7.10
80-90	121.81	N.A.	1.60
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	7749.15	N.A.	100.00

Total Luminaire Efficiency = N.A.%

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	266.43
10-20	758.25
20-30	1135.4
30-40	1348.36
40-50	1380.04
50-60	1239.89
60-70	951.23
70-80	547.75
80-90	121.81
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

Photometric Toolbox® Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL 2R G2 22 MD HO UV FA 930.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	98	94	91	94	91	89	90	88	86	84
2	99	91	84	78	96	89	83	77	85	80	75	82	78	74	79	75	72	70
3	90	80	71	65	88	78	70	64	75	69	63	72	67	62	70	65	61	59
4	83	71	62	55	80	69	61	55	67	60	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	53	47	60	52	47	58	51	46	56	50	46	43
6	70	57	48	41	68	56	47	41	54	46	41	52	46	40	51	45	40	38
7	65	51	43	37	63	51	42	36	49	42	36	48	41	36	46	40	36	34
8	61	47	38	33	59	46	38	33	45	38	32	44	37	32	43	36	32	30
9	57	43	35	29	55	43	35	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	27	52	39	32	27	38	31	26	37	31	26	36	31	26	24

Photometric Toolbox® Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL 2R G2 22 MD HO UV FA 930.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	18.5	20.2	18.9	20.5	20.8	19.7	21.3	20.1	21.6	22.0
	3H	20.3	21.7	20.6	22.1	22.4	21.7	23.2	22.1	23.5	23.8
	4H	20.9	22.3	21.3	22.6	23.0	22.4	23.8	22.8	24.2	24.5
	6H	21.3	22.6	21.7	22.9	23.3	22.9	24.2	23.3	24.6	25.0
	8H	21.4	22.6	21.8	23.0	23.4	23.0	24.3	23.5	24.7	25.1
	12H	21.4	22.6	21.9	23.0	23.4	23.1	24.2	23.5	24.6	25.1
4H	2H	19.3	20.7	19.7	21.1	21.5	20.2	21.6	20.6	22.0	22.4
	3H	21.3	22.4	21.7	22.8	23.2	22.5	23.6	22.9	24.0	24.4
	4H	22.0	23.0	22.4	23.5	23.9	23.3	24.4	23.8	24.8	25.2
	6H	22.5	23.4	23.0	23.9	24.3	24.0	24.9	24.4	25.3	25.8
	8H	22.7	23.5	23.1	24.0	24.4	24.1	25.0	24.6	25.4	25.9
	12H	22.8	23.5	23.3	24.0	24.5	24.2	24.9	24.7	25.4	25.9
8H	4H	22.4	23.3	22.9	23.7	24.2	23.6	24.4	24.0	24.9	25.3
	6H	23.0	23.8	23.5	24.3	24.7	24.3	25.0	24.8	25.5	26.0
	8H	23.3	23.9	23.8	24.4	24.9	24.5	25.2	25.0	25.7	26.2
	12H	23.4	24.0	23.9	24.5	25.0	24.6	25.2	25.1	25.7	26.2
12H	4H	22.5	23.2	22.9	23.7	24.2	23.6	24.4	24.1	24.8	25.3
	6H	23.1	23.8	23.7	24.2	24.8	24.4	25.0	24.9	25.5	26.0
	8H	23.4	24.0	23.9	24.4	25.0	24.6	25.2	25.1	25.7	26.2

Maximum UGR = 26.2

Photometric Toolbox® Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL 2R G2 22 MD HO UV FA 930.IES

POLAR GRAPH



Maximum Candela = 2820.334 Located At Horizontal Angle = 0, Vertical Angle = 0
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (0) (Through Max. Cd.)

Photometric Toolbox® Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.