



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 14 HI UV FA 935.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-027 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 2/28/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFL G2 14 HI UV FA 935

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflector,
[MORE] frosted linear ribbed plastic enclosure.

[LAMP] 96 white LEDs, two LS3873A7_3500_90R 3500K LED boards

[BALLAST] One ULT D15CC55UNVPW-C LED driver programmed at 820mA

[OTHER] 120.0Vac, 60.00Hz, 0.3600A, 42.56W, 0.985PF, 7.7%THD(i)

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	5886
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	138
Total Luminaire Watts	42.558
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.85 ft
Luminous Width (90-270)	0.85 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	5944	6314	6648
55	5525	6065	6532
65	5007	5732	6253
75	4205	5043	5364
85	2673	2453	1099

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 14 HI UV FA 935.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	773.77	N.A.	13.10
0-30	1634.15	N.A.	27.80
0-40	2659.77	N.A.	45.20
0-60	4662.05	N.A.	79.20
0-80	5801.32	N.A.	98.60
0-90	5885.83	N.A.	100.00
10-90	5684.88	N.A.	96.60
20-40	1886.00	N.A.	32.00
20-50	2939.35	N.A.	49.90
40-70	2729.11	N.A.	46.40
60-80	1139.27	N.A.	19.40
70-80	412.44	N.A.	7.00
80-90	84.51	N.A.	1.40
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	5885.83	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	200.95
10-20	572.82
20-30	860.38
30-40	1025.62
40-50	1053.35
50-60	948.93
60-70	726.83
70-80	412.44
80-90	84.51
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 14 HI UV FA 935.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	95	98	94	92	94	91	89	90	88	86	84
2	99	91	84	78	96	89	83	77	85	80	75	82	78	74	79	75	72	70
3	90	80	71	65	88	78	71	64	75	69	63	72	67	62	70	65	61	59
4	83	71	62	55	80	69	61	55	67	60	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	53	47	60	52	47	58	51	46	56	50	46	43
6	70	57	48	41	68	56	47	41	54	46	41	52	46	40	51	45	40	38
7	65	51	43	37	63	51	42	36	49	42	36	48	41	36	46	40	36	34
8	61	47	38	33	59	46	38	32	45	38	32	44	37	32	43	36	32	30
9	57	43	35	29	55	43	35	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	27	52	39	32	27	38	31	26	37	31	26	36	30	26	24


IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 14 HI UV FA 935.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	18.0	19.6	18.3	19.9	20.2	18.9	20.6	19.3	20.9	21.2
	3H	19.7	21.2	20.1	21.5	21.9	20.8	22.3	21.2	22.6	23.0
	4H	20.3	21.7	20.7	22.0	22.4	21.5	22.9	21.9	23.2	23.6
	6H	20.7	22.0	21.1	22.4	22.8	21.9	23.2	22.3	23.6	24.0
	8H	20.9	22.1	21.3	22.5	22.9	22.0	23.3	22.5	23.6	24.0
	12H	20.9	22.1	21.3	22.5	22.9	22.0	23.2	22.4	23.6	24.0
4H	2H	18.7	20.1	19.1	20.5	20.8	19.5	20.9	19.9	21.2	21.6
	3H	20.7	21.8	21.1	22.2	22.6	21.6	22.8	22.0	23.2	23.6
	4H	21.4	22.5	21.9	22.9	23.3	22.4	23.5	22.9	23.9	24.3
	6H	22.0	22.9	22.4	23.3	23.8	23.0	23.9	23.4	24.3	24.8
	8H	22.1	23.0	22.6	23.4	23.9	23.1	24.0	23.6	24.4	24.9
	12H	22.2	23.0	22.7	23.5	23.9	23.1	23.9	23.6	24.4	24.8
8H	4H	21.8	22.7	22.3	23.1	23.6	22.7	23.6	23.1	24.0	24.5
	6H	22.5	23.2	23.0	23.7	24.2	23.3	24.1	23.8	24.6	25.0
	8H	22.7	23.3	23.2	23.8	24.3	23.5	24.2	24.0	24.7	25.2
	12H	22.9	23.4	23.4	23.9	24.5	23.6	24.1	24.1	24.6	25.2
12H	4H	21.9	22.6	22.3	23.1	23.6	22.7	23.5	23.2	24.0	24.4
	6H	22.6	23.2	23.1	23.7	24.2	23.4	24.0	23.9	24.5	25.0
	8H	22.8	23.4	23.3	23.9	24.4	23.6	24.2	24.1	24.7	25.2

Maximum UGR = 25.2

POLAR GRAPH



Maximum Candela = 2130.401 Located At Horizontal Angle = 90, Vertical Angle = 2
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (2) (Through Max. Cd.)