



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 14 LW UV FA 930.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-027 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 2/28/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFL G2 14 LW UV FA 930

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflector,

[MORE] frosted linear ribbed plastic enclosure.

[LAMP] 96 white LEDs, two LS3873A7_3000_90R 3000K LED boards

[BALLAST] One ULT D10CC30UNVPW-C LED driver programmed at 540mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	3922
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	141
Total Luminaire Watts	27.9
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.85 ft
Luminous Width (90-270)	0.85 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	3961	4208	4431
55	3682	4042	4353
65	3337	3820	4167
75	2802	3361	3575
85	1781	1635	732

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 14 LW UV FA 930.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	515.65	N.A.	13.10
0-30	1089.01	N.A.	27.80
0-40	1772.49	N.A.	45.20
0-60	3106.82	N.A.	79.20
0-80	3866.04	N.A.	98.60
0-90	3922.36	N.A.	100.00
10-90	3788.45	N.A.	96.60
20-40	1256.84	N.A.	32.00
20-50	1958.8	N.A.	49.90
40-70	1818.7	N.A.	46.40
60-80	759.22	N.A.	19.40
70-80	274.86	N.A.	7.00
80-90	56.32	N.A.	1.40
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	3922.36	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	133.92
10-20	381.73
20-30	573.36
30-40	683.48
40-50	701.96
50-60	632.38
60-70	484.36
70-80	274.86
80-90	56.32
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 14 LW UV FA 930.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	95	98	94	92	94	91	89	90	88	86	84
2	99	91	84	78	96	89	83	77	85	80	75	82	78	74	79	75	72	70
3	90	80	72	65	88	78	71	64	75	69	63	72	67	62	70	65	61	59
4	83	71	62	55	80	69	61	55	67	60	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	53	47	60	52	47	58	51	46	56	50	46	43
6	70	57	48	41	68	56	47	41	54	46	41	52	46	40	51	45	40	38
7	65	51	43	37	63	51	42	36	49	42	36	48	41	36	46	40	36	34
8	61	47	38	33	59	46	38	32	45	38	32	44	37	32	43	36	32	30
9	57	43	35	29	55	43	35	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	27	52	39	32	27	38	31	26	37	31	26	36	30	26	24

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 14 LW UV FA 930.IES

UGR TABLE - CORRECTED


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	16.6	18.2	16.9	18.5	18.8	17.5	19.2	17.9	19.5	19.8
	3H	18.3	19.8	18.7	20.1	20.5	19.4	20.9	19.8	21.2	21.6
	4H	18.9	20.3	19.3	20.6	21.0	20.1	21.5	20.5	21.8	22.2
	6H	19.3	20.6	19.7	21.0	21.4	20.5	21.8	20.9	22.2	22.6
	8H	19.5	20.7	19.9	21.1	21.5	20.6	21.9	21.1	22.2	22.6
	12H	19.5	20.7	19.9	21.1	21.5	20.6	21.8	21.0	22.2	22.6
4H	2H	17.3	18.7	17.7	19.1	19.4	18.1	19.5	18.5	19.8	20.2
	3H	19.3	20.4	19.7	20.8	21.2	20.2	21.4	20.6	21.8	22.2
	4H	20.0	21.1	20.5	21.5	21.9	21.0	22.1	21.5	22.5	22.9
	6H	20.6	21.5	21.0	21.9	22.4	21.6	22.5	22.0	22.9	23.4
	8H	20.7	21.6	21.2	22.0	22.5	21.7	22.6	22.2	23.0	23.5
	12H	20.8	21.6	21.3	22.1	22.5	21.7	22.5	22.2	23.0	23.4
8H	4H	20.4	21.3	20.9	21.7	22.2	21.3	22.2	21.7	22.6	23.1
	6H	21.1	21.8	21.6	22.3	22.8	21.9	22.7	22.4	23.2	23.6
	8H	21.3	21.9	21.8	22.4	22.9	22.1	22.8	22.6	23.3	23.8
	12H	21.4	22.0	22.0	22.5	23.1	22.2	22.7	22.7	23.2	23.8
12H	4H	20.5	21.2	20.9	21.7	22.2	21.3	22.1	21.8	22.6	23.0
	6H	21.1	21.8	21.7	22.3	22.8	22.0	22.6	22.5	23.1	23.6
	8H	21.4	22.0	21.9	22.5	23.0	22.2	22.8	22.7	23.3	23.8

Maximum UGR = 23.8

POLAR GRAPH



Maximum Candela = 1419.716 Located At Horizontal Angle = 90, Vertical Angle = 2
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (2) (Through Max. Cd.)