



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 14 MD UV FA 950.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-027 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 2/28/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFL G2 14 MD UV FA 950

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflector,

[MORE] frosted linear ribbed plastic enclosure.

[LAMP] 96 white LEDs, two LS3873A7_5000_90R 5000K LED boards

[BALLAST] One ULT D10CC30UNVPW-C LED driver programmed at 660mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4907
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	146
Total Luminaire Watts	33.7
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.85 ft
Luminous Width (90-270)	0.85 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	4956	5264	5543
55	4606	5056	5446
65	4174	4778	5213
75	3505	4205	4472
85	2229	2045	916

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 14 MD UV FA 950.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	645.06	N.A.	13.10
0-30	1362.33	N.A.	27.80
0-40	2217.35	N.A.	45.20
0-60	3886.57	N.A.	79.20
0-80	4836.34	N.A.	98.60
0-90	4906.79	N.A.	100.00
10-90	4739.27	N.A.	96.60
20-40	1572.29	N.A.	32.00
20-50	2450.42	N.A.	49.90
40-70	2275.15	N.A.	46.40
60-80	949.77	N.A.	19.40
70-80	343.84	N.A.	7.00
80-90	70.45	N.A.	1.40
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	4906.79	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	167.53
10-20	477.54
20-30	717.27
30-40	855.02
40-50	878.14
50-60	791.09
60-70	605.93
70-80	343.84
80-90	70.45
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 14 MD UV FA 950.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	95	98	94	92	94	91	89	90	88	86	84
2	99	91	84	78	96	89	83	77	85	80	75	82	78	74	79	75	72	70
3	90	80	71	65	88	78	71	64	75	69	63	72	67	62	70	65	61	59
4	83	71	62	55	80	69	61	55	67	60	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	53	47	60	52	47	58	51	46	56	50	46	43
6	70	57	48	41	68	56	47	41	54	46	41	52	46	40	51	45	40	38
7	65	51	43	37	63	51	42	36	49	42	36	48	41	36	46	40	36	34
8	61	47	38	33	59	46	38	32	45	38	32	44	37	32	43	36	32	30
9	57	43	35	29	55	43	35	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	27	52	39	32	27	38	31	26	37	31	26	36	30	26	24

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 14 MD UV FA 950.IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20


Room Size UGR Viewed Crosswise

UGR Viewed Endwise

X=2H	Y=2H	17.3	18.9	17.6	19.2	19.5	18.2	19.9	18.6	20.2	20.5
	3H	19.0	20.5	19.4	20.8	21.2	20.1	21.6	20.5	21.9	22.3
	4H	19.6	21.0	20.0	21.3	21.7	20.8	22.2	21.2	22.5	22.9
	6H	20.0	21.3	20.4	21.7	22.1	21.2	22.5	21.6	22.9	23.3
	8H	20.2	21.4	20.6	21.8	22.2	21.3	22.6	21.8	22.9	23.3
	12H	20.2	21.4	20.6	21.8	22.2	21.3	22.5	21.7	22.9	23.3
4H	2H	18.0	19.4	18.4	19.8	20.1	18.8	20.2	19.2	20.5	20.9
	3H	20.0	21.1	20.4	21.5	21.9	20.9	22.1	21.3	22.5	22.9
	4H	20.7	21.8	21.2	22.2	22.6	21.7	22.8	22.2	23.2	23.6
	6H	21.3	22.2	21.7	22.6	23.1	22.3	23.2	22.7	23.6	24.1
	8H	21.4	22.3	21.9	22.7	23.2	22.4	23.3	22.9	23.7	24.2
	12H	21.5	22.3	22.0	22.8	23.2	22.4	23.2	22.9	23.7	24.1
8H	4H	21.1	22.0	21.6	22.4	22.9	22.0	22.9	22.4	23.3	23.8
	6H	21.8	22.5	22.3	23.0	23.5	22.6	23.4	23.1	23.9	24.3
	8H	22.0	22.6	22.5	23.1	23.6	22.8	23.5	23.3	24.0	24.5
	12H	22.2	22.7	22.7	23.2	23.8	22.9	23.4	23.4	23.9	24.5
12H	4H	21.2	21.9	21.6	22.4	22.9	22.0	22.8	22.5	23.3	23.7
	6H	21.9	22.5	22.4	23.0	23.5	22.7	23.3	23.2	23.8	24.3
	8H	22.1	22.7	22.6	23.2	23.7	22.9	23.5	23.4	24.0	24.5

Maximum UGR = 24.5

POLAR GRAPH



Maximum Candela = 1776.035 Located At Horizontal Angle = 90, Vertical Angle = 2
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (2) (Through Max. Cd.)