



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 14 SL UV FA 935.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-027 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 2/28/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFL G2 14 SL UV FA 935

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflector,

[MORE] frosted linear ribbed plastic enclosure.

[LAMP] 96 white LEDs, two LS3873A7_3500_90R 3500K LED boards

[BALLAST] One ULT D700C20UNVPW-C LED driver programmed at 260mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1889
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	134
Total Luminaire Watts	14.1
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.85 ft
Luminous Width (90-270)	0.85 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1908	2027	2134
55	1773	1947	2097
65	1607	1840	2007
75	1350	1619	1722
85	858	787	353

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 14 SL UV FA 935.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	248.35	N.A.	13.10
0-30	524.50	N.A.	27.80
0-40	853.68	N.A.	45.20
0-60	1496.33	N.A.	79.20
0-80	1861.99	N.A.	98.60
0-90	1889.11	N.A.	100.00
10-90	1824.62	N.A.	96.60
20-40	605.33	N.A.	32.00
20-50	943.41	N.A.	49.90
40-70	875.93	N.A.	46.40
60-80	365.66	N.A.	19.40
70-80	132.38	N.A.	7.00
80-90	27.12	N.A.	1.40
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	1889.11	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	64.50
10-20	183.85
20-30	276.15
30-40	329.18
40-50	338.08
50-60	304.57
60-70	233.28
70-80	132.38
80-90	27.12
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 14 SL UV FA 935.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	95	98	94	92	94	91	89	90	88	86	84
2	99	91	84	78	96	89	83	77	85	80	75	82	78	74	79	75	72	70
3	90	80	72	65	88	78	71	64	75	69	63	72	67	62	70	65	61	59
4	83	71	62	55	80	69	61	55	67	60	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	53	47	60	52	47	58	51	46	56	50	46	43
6	70	57	48	41	68	56	47	41	54	46	41	52	46	40	51	45	40	38
7	65	51	43	37	63	51	42	36	49	42	36	48	41	36	46	40	36	34
8	61	47	38	33	59	46	38	32	45	38	32	44	37	32	43	36	32	30
9	57	43	35	29	55	43	35	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	27	52	39	32	27	38	31	26	37	31	26	36	30	26	24


IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 14 SL UV FA 935.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	14.0	15.6	14.3	15.9	16.2	14.9	16.6	15.3	16.9	17.2
	3H	15.7	17.2	16.1	17.5	17.9	16.8	18.3	17.2	18.6	19.0
	4H	16.3	17.7	16.7	18.0	18.4	17.5	18.9	17.9	19.2	19.6
	6H	16.7	18.0	17.1	18.4	18.8	17.9	19.2	18.3	19.6	20.0
	8H	16.9	18.1	17.3	18.5	18.9	18.0	19.3	18.5	19.6	20.0
	12H	16.9	18.1	17.3	18.5	18.9	18.0	19.2	18.4	19.6	20.0
4H	2H	14.7	16.1	15.1	16.5	16.8	15.5	16.9	15.9	17.2	17.6
	3H	16.7	17.8	17.1	18.2	18.6	17.6	18.8	18.0	19.2	19.6
	4H	17.4	18.5	17.9	18.9	19.3	18.4	19.5	18.9	19.9	20.3
	6H	18.0	18.9	18.4	19.3	19.8	19.0	19.9	19.4	20.3	20.8
	8H	18.1	19.0	18.6	19.4	19.9	19.1	20.0	19.6	20.4	20.9
	12H	18.2	19.0	18.7	19.5	19.9	19.1	19.9	19.6	20.4	20.8
8H	4H	17.8	18.7	18.3	19.1	19.6	18.7	19.6	19.1	20.0	20.5
	6H	18.5	19.2	19.0	19.7	20.1	19.3	20.1	19.8	20.6	21.0
	8H	18.7	19.3	19.2	19.8	20.3	19.5	20.2	20.0	20.7	21.1
	12H	18.8	19.4	19.4	19.9	20.5	19.6	20.1	20.1	20.6	21.2
12H	4H	17.9	18.6	18.3	19.1	19.6	18.7	19.5	19.2	20.0	20.4
	6H	18.5	19.2	19.1	19.7	20.2	19.4	20.0	19.9	20.5	21.0
	8H	18.8	19.4	19.3	19.9	20.4	19.6	20.2	20.1	20.7	21.2

Maximum UGR = 21.2

POLAR GRAPH



Maximum Candela = 683.772 Located At Horizontal Angle = 90, Vertical Angle = 2
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (2) (Through Max. Cd.)