



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 22 SL UV FA 950.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-024 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 2/25/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFL G2 22 SL UV FA 950

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflector,  
[MORE] frosted linear ribbed plastic enclosure.

[LAMP] 48 white LEDs, one LS3872A7\_5000\_90R 5000K LED board

[BALLAST] One ULT D700C20UNVPW-C LED driver programmed at 260mA

[OTHER] 120.0Vac, 60.01Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1869
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	130
Total Luminaire Watts	14.4
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	1.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1712	1847	1983
55	1576	1787	2011
65	1418	1758	2131
75	1193	1772	2335
85	795	1508	2081

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 22 SL UV FA 950.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	238.78	N.A.	12.80
0-30	503.15	N.A.	26.90
0-40	817.11	N.A.	43.70
0-60	1433.16	N.A.	76.70
0-80	1823.2	N.A.	97.60
0-90	1868.84	N.A.	100.00
10-90	1806.74	N.A.	96.70
20-40	578.33	N.A.	30.90
20-50	900.65	N.A.	48.20
40-70	852.12	N.A.	45.60
60-80	390.04	N.A.	20.90
70-80	153.96	N.A.	8.20
80-90	45.65	N.A.	2.40
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	1868.84	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	62.11
10-20	176.67
20-30	264.36
30-40	313.97
40-50	322.32
50-60	293.73
60-70	236.08
70-80	153.96
80-90	45.65
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 22 SL UV FA 950.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	90	83	77	95	88	81	76	84	79	74	81	76	72	78	74	71	68
3	89	78	70	63	87	77	69	63	74	67	62	71	65	61	69	64	60	57
4	82	69	60	54	79	68	60	53	66	58	52	63	57	52	61	56	51	49
5	75	62	53	46	73	61	52	46	59	51	45	57	50	45	55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	40	51	44	39	50	44	39	37
7	64	51	42	35	63	50	41	35	48	41	35	47	40	35	45	39	35	33
8	60	46	38	32	58	45	37	32	44	37	31	43	36	31	42	36	31	29
9	56	42	34	29	55	42	34	28	41	33	28	40	33	28	39	32	28	26
10	52	39	31	26	51	39	31	26	38	31	26	37	30	26	36	30	25	24

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 22 SL UV FA 950.IES**

**UGR TABLE - CORRECTED**


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	13.4	15.0	13.7	15.3	15.7	14.8	16.5	15.2	16.8	17.1
	3H	15.1	16.6	15.5	16.9	17.3	17.2	18.7	17.6	19.0	19.4
	4H	15.7	17.2	16.1	17.5	17.9	18.2	19.7	18.6	20.0	20.4
	6H	16.2	17.5	16.6	17.9	18.2	19.1	20.5	19.6	20.8	21.2
	8H	16.3	17.6	16.7	18.0	18.3	19.5	20.8	19.9	21.2	21.6
	12H	16.4	17.6	16.8	18.0	18.4	19.7	20.9	20.2	21.3	21.7
4H	2H	14.3	15.7	14.7	16.0	16.4	15.4	16.8	15.8	17.2	17.5
	3H	16.2	17.4	16.6	17.8	18.2	18.0	19.2	18.4	19.6	20.0
	4H	17.0	18.1	17.4	18.5	18.9	19.2	20.3	19.6	20.7	21.2
	6H	17.6	18.5	18.0	18.9	19.4	20.3	21.3	20.8	21.7	22.2
	8H	17.7	18.6	18.2	19.1	19.5	20.7	21.6	21.2	22.1	22.5
	12H	17.8	18.6	18.3	19.1	19.6	21.0	21.8	21.5	22.3	22.8
8H	4H	17.6	18.5	18.0	18.9	19.4	19.5	20.4	20.0	20.8	21.3
	6H	18.3	19.1	18.8	19.5	20.0	20.8	21.5	21.3	22.0	22.5
	8H	18.5	19.2	19.0	19.7	20.2	21.3	22.0	21.8	22.5	23.0
	12H	18.7	19.3	19.2	19.8	20.4	21.7	22.3	22.2	22.8	23.3
12H	4H	17.7	18.5	18.2	19.0	19.5	19.5	20.3	20.0	20.8	21.3
	6H	18.5	19.2	19.0	19.6	20.2	20.8	21.5	21.3	22.0	22.5
	8H	18.8	19.4	19.3	19.9	20.5	21.4	22.0	21.9	22.5	23.0

Maximum UGR = 23.3

POLAR GRAPH



Maximum Candela = 657.6 Located At Horizontal Angle = 90, Vertical Angle = .5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)