



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 22 HI UV FA 930.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-024 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 2/25/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFL G2 22 HI UV FA 930

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflector,  
[MORE] frosted linear ribbed plastic enclosure.

[LAMP] 84 white LEDs, one LS3872A10\_3000\_90R 3000K LED board

[BALLAST] One ULT D15CC55UNVPW-C LED driver programmed at 940mA

[OTHER] 120.0Vac, 60.01Hz, 0.3616A, 42.80W, 0.986PF, 7.7%THD(i)

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	5581
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	130
Total Luminaire Watts	42.796
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	1.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	5113	5517	5922
55	4706	5337	6006
65	4234	5249	6365
75	3563	5291	6972
85	2374	4504	6215

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 22 HI UV FA 930.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	713.10	N.A.	12.80
0-30	1502.61	N.A.	26.90
0-40	2440.26	N.A.	43.70
0-60	4280.03	N.A.	76.70
0-80	5444.86	N.A.	97.60
0-90	5581.18	N.A.	100.00
10-90	5395.7	N.A.	96.70
20-40	1727.16	N.A.	30.90
20-50	2689.73	N.A.	48.20
40-70	2544.81	N.A.	45.60
60-80	1164.83	N.A.	20.90
70-80	459.80	N.A.	8.20
80-90	136.32	N.A.	2.40
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	5581.18	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	185.48
10-20	527.63
20-30	789.51
30-40	937.65
40-50	962.58
50-60	877.19
60-70	705.04
70-80	459.80
80-90	136.32
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 22 HI UV FA 930.IES

## COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	90	83	77	95	88	81	76	84	79	74	81	76	72	78	74	71	68
3	89	79	70	63	87	77	69	63	74	67	62	71	65	61	69	64	60	57
4	82	69	60	54	79	68	60	53	66	58	52	63	57	52	61	56	51	49
5	75	62	53	46	73	61	52	46	59	51	45	57	50	45	55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	40	51	44	39	50	44	39	37
7	64	51	42	36	63	50	41	35	48	41	35	47	40	35	45	39	35	33
8	60	46	38	32	58	45	37	32	44	37	31	43	36	31	42	36	31	29
9	56	42	34	29	55	42	34	28	41	33	28	40	33	28	39	32	28	26
10	52	39	31	26	51	39	31	26	38	31	26	37	30	26	36	30	25	24


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 22 HI UV FA 930.IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	17.2	18.8	17.5	19.1	19.5	18.6	20.3	19.0	20.6	20.9
	3H	18.9	20.4	19.3	20.7	21.1	21.0	22.5	21.4	22.8	23.2
	4H	19.5	21.0	19.9	21.3	21.7	22.0	23.5	22.4	23.8	24.2
	6H	20.0	21.3	20.4	21.7	22.0	22.9	24.3	23.4	24.6	25.0
	8H	20.1	21.4	20.5	21.7	22.1	23.3	24.6	23.7	25.0	25.3
	12H	20.2	21.4	20.6	21.8	22.2	23.5	24.7	24.0	25.1	25.5
4H	2H	18.1	19.5	18.4	19.8	20.2	19.2	20.6	19.6	21.0	21.3
	3H	20.0	21.2	20.4	21.6	22.0	21.8	23.0	22.2	23.4	23.8
	4H	20.8	21.9	21.2	22.3	22.7	23.0	24.1	23.4	24.5	24.9
	6H	21.4	22.3	21.8	22.7	23.2	24.1	25.1	24.6	25.5	26.0
	8H	21.5	22.4	22.0	22.9	23.3	24.5	25.4	25.0	25.9	26.3
	12H	21.6	22.4	22.1	22.9	23.4	24.8	25.6	25.3	26.1	26.6
8H	4H	21.4	22.3	21.8	22.7	23.2	23.3	24.2	23.8	24.6	25.1
	6H	22.1	22.9	22.6	23.3	23.8	24.6	25.3	25.1	25.8	26.3
	8H	22.3	23.0	22.8	23.5	24.0	25.1	25.8	25.6	26.3	26.8
	12H	22.5	23.1	23.0	23.6	24.2	25.5	26.1	26.0	26.6	27.1
12H	4H	21.5	22.3	22.0	22.8	23.3	23.3	24.1	23.8	24.6	25.1
	6H	22.3	23.0	22.8	23.4	24.0	24.6	25.3	25.1	25.8	26.3
	8H	22.6	23.2	23.1	23.7	24.2	25.2	25.8	25.7	26.3	26.8

Maximum UGR = 27.1

POLAR GRAPH



Maximum Candela = 1963.881 Located At Horizontal Angle = 90, Vertical Angle = .5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)