



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 22 SL UV FA 935.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-024 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 2/25/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFL G2 22 SL UV FA 935

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflector,
[MORE] frosted linear ribbed plastic enclosure.

[LAMP] 48 white LEDs, one LS3872A7_3500_90R 3500K LED board

[BALLAST] One ULT D700C20UNVPW-C LED driver programmed at 260mA

[OTHER] 120.0Vac, 60.01Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1825
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	127
Total Luminaire Watts	14.4
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	1.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1672	1805	1937
55	1539	1746	1964
65	1385	1717	2082
75	1165	1731	2281
85	777	1473	2033

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 22 SL UV FA 935.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	233.24	N.A.	12.80
0-30	491.47	N.A.	26.90
0-40	798.16	N.A.	43.70
0-60	1399.91	N.A.	76.70
0-80	1780.9	N.A.	97.60
0-90	1825.48	N.A.	100.00
10-90	1764.82	N.A.	96.70
20-40	564.92	N.A.	30.90
20-50	879.75	N.A.	48.20
40-70	832.35	N.A.	45.60
60-80	380.99	N.A.	20.90
70-80	150.39	N.A.	8.20
80-90	44.59	N.A.	2.40
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	1825.48	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	60.67
10-20	172.58
20-30	258.23
30-40	306.68
40-50	314.84
50-60	286.91
60-70	230.60
70-80	150.39
80-90	44.59
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 22 SL UV FA 935.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	106	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	90	83	77	96	88	81	76	84	79	74	81	76	72	78	74	71	68
3	89	79	70	63	87	77	69	63	74	67	62	71	65	61	69	64	60	57
4	82	69	60	54	79	68	60	53	66	58	52	63	57	52	61	56	51	49
5	75	62	53	46	73	61	52	46	59	51	45	57	50	45	55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	40	51	45	39	50	44	39	37
7	64	51	42	36	63	50	41	35	48	41	35	47	40	35	45	39	35	33
8	60	46	38	32	58	46	37	32	44	37	31	43	36	31	42	36	31	29
9	56	42	34	29	55	42	34	28	41	33	28	40	33	28	39	32	28	26
10	52	39	31	26	51	39	31	26	38	31	26	37	30	26	36	30	25	24


IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 22 SL UV FA 935.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	13.3	14.9	13.6	15.2	15.6	14.7	16.4	15.1	16.7	17.0
	3H	15.0	16.5	15.4	16.8	17.2	17.1	18.6	17.5	18.9	19.3
	4H	15.6	17.1	16.0	17.4	17.8	18.1	19.6	18.5	19.9	20.3
	6H	16.1	17.4	16.5	17.8	18.1	19.0	20.4	19.5	20.7	21.1
	8H	16.2	17.5	16.6	17.8	18.2	19.4	20.7	19.8	21.1	21.4
	12H	16.3	17.5	16.7	17.9	18.3	19.6	20.8	20.1	21.2	21.6
4H	2H	14.2	15.6	14.5	15.9	16.3	15.3	16.7	15.7	17.1	17.4
	3H	16.1	17.3	16.5	17.7	18.1	17.9	19.1	18.3	19.5	19.9
	4H	16.9	18.0	17.3	18.4	18.8	19.1	20.2	19.5	20.6	21.1
	6H	17.5	18.4	17.9	18.8	19.3	20.2	21.2	20.7	21.6	22.1
	8H	17.6	18.5	18.1	19.0	19.4	20.6	21.5	21.1	22.0	22.4
	12H	17.7	18.5	18.2	19.0	19.5	20.9	21.7	21.4	22.2	22.7
8H	4H	17.5	18.4	17.9	18.8	19.3	19.4	20.3	19.9	20.7	21.2
	6H	18.2	19.0	18.7	19.4	19.9	20.7	21.4	21.2	21.9	22.4
	8H	18.4	19.1	18.9	19.6	20.1	21.2	21.9	21.7	22.4	22.9
	12H	18.6	19.2	19.1	19.7	20.3	21.6	22.2	22.1	22.7	23.2
12H	4H	17.6	18.4	18.1	18.9	19.4	19.4	20.2	19.9	20.7	21.2
	6H	18.4	19.1	18.9	19.5	20.1	20.7	21.4	21.2	21.9	22.4
	8H	18.7	19.3	19.2	19.8	20.3	21.3	21.9	21.8	22.4	22.9

Maximum UGR = 23.2

POLAR GRAPH



Maximum Candela = 642.344 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)