



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 24 LW UV FA 950.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-020A (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 2/25/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFL G2 24 LW UV FA 950

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflector,

[MORE] frosted linear ribbed plastic enclosure.

[LAMP] 96 white LEDs, two LS3873A7_5000_90R 5000K LED boards

[BALLAST] One ULT D10CC30UNVPW-C LED driver programmed at 570mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4275
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	145
Total Luminaire Watts	29.4
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1906	2037	2161
55	1761	1978	2181
65	1586	1949	2282
75	1329	1973	2497
85	844	1821	2243

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 24 LW UV FA 950.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	541.95	N.A.	12.70
0-30	1143.96	N.A.	26.80
0-40	1861.17	N.A.	43.50
0-60	3272.99	N.A.	76.60
0-80	4166.32	N.A.	97.50
0-90	4274.93	N.A.	100.00
10-90	4134.13	N.A.	96.70
20-40	1319.22	N.A.	30.90
20-50	2057.48	N.A.	48.10
40-70	1951.94	N.A.	45.70
60-80	893.33	N.A.	20.90
70-80	353.22	N.A.	8.30
80-90	108.60	N.A.	2.50
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	4274.93	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	140.80
10-20	401.15
20-30	602.01
30-40	717.21
40-50	738.27
50-60	673.56
60-70	540.11
70-80	353.22
80-90	108.60
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 24 LW UV FA 950.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	90	82	76	95	88	81	76	84	79	74	81	76	72	78	74	70	68
3	89	78	70	63	87	77	69	63	74	67	62	71	65	60	68	64	59	57
4	82	69	60	53	79	68	60	53	65	58	52	63	57	52	61	55	51	49
5	75	62	53	46	73	61	52	46	59	51	45	57	50	45	55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	40	51	44	39	50	44	39	37
7	64	51	42	35	62	50	41	35	48	41	35	47	40	35	45	39	34	32
8	60	46	37	32	58	45	37	31	44	37	31	43	36	31	42	35	31	29
9	56	42	34	28	54	42	34	28	41	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	39	31	26	38	30	26	37	30	25	36	30	25	24

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 24 LW UV FA 950.IES

UGR TABLE - CORRECTED


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	13.8	15.5	14.2	15.8	16.1	15.1	16.8	15.5	17.1	17.4
	3H	15.6	17.1	15.9	17.4	17.8	17.5	19.0	17.8	19.3	19.6
	4H	16.2	17.6	16.6	18.0	18.3	18.5	19.9	18.9	20.2	20.6
	6H	16.6	18.0	17.0	18.3	18.7	19.4	20.7	19.8	21.1	21.5
	8H	16.8	18.0	17.2	18.4	18.8	19.7	21.0	20.2	21.4	21.8
	12H	16.8	18.0	17.3	18.4	18.9	20.0	21.2	20.4	21.6	22.0
4H	2H	14.7	16.1	15.1	16.5	16.8	15.7	17.1	16.1	17.5	17.8
	3H	16.7	17.9	17.1	18.3	18.7	18.3	19.5	18.7	19.9	20.3
	4H	17.4	18.5	17.9	18.9	19.4	19.5	20.6	19.9	21.0	21.4
	6H	18.0	19.0	18.4	19.4	19.9	20.6	21.5	21.0	22.0	22.4
	8H	18.2	19.1	18.6	19.5	20.0	21.0	21.9	21.5	22.3	22.8
	12H	18.3	19.1	18.8	19.6	20.0	21.3	22.1	21.8	22.6	23.0
8H	4H	18.0	18.9	18.5	19.4	19.8	19.8	20.7	20.2	21.1	21.6
	6H	18.8	19.5	19.3	20.0	20.5	21.1	21.8	21.6	22.3	22.8
	8H	19.0	19.7	19.5	20.2	20.7	21.6	22.3	22.1	22.8	23.3
	12H	19.2	19.8	19.7	20.3	20.9	22.0	22.6	22.5	23.1	23.6
12H	4H	18.2	19.0	18.6	19.5	19.9	19.8	20.6	20.3	21.1	21.6
	6H	19.0	19.7	19.5	20.1	20.7	21.1	21.8	21.6	22.3	22.8
	8H	19.3	19.9	19.8	20.4	21.0	21.7	22.3	22.2	22.8	23.4

Maximum UGR = 23.6

POLAR GRAPH



Maximum Candela = 1492.104 Located At Horizontal Angle = 90, Vertical Angle = 2
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (2) (Through Max. Cd.)