



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 24 SL UV FA 930.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-020A (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 2/25/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFL G2 24 SL UV FA 930

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflector,
[MORE] frosted linear ribbed plastic enclosure.

[LAMP] 96 white LEDs, two LS3873A7_3000_90R 3000K LED boards

[BALLAST] One ULT D700C20UNVPW-C LED driver programmed at 390mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	2848
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	139
Total Luminaire Watts	20.5
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1270	1357	1440
55	1173	1318	1453
65	1057	1299	1521
75	886	1315	1664
85	563	1213	1494

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 24 SL UV FA 930.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	361.09	N.A.	12.70
0-30	762.20	N.A.	26.80
0-40	1240.06	N.A.	43.50
0-60	2180.74	N.A.	76.60
0-80	2775.95	N.A.	97.50
0-90	2848.31	N.A.	100.00
10-90	2754.5	N.A.	96.70
20-40	878.97	N.A.	30.90
20-50	1370.87	N.A.	48.10
40-70	1300.54	N.A.	45.70
60-80	595.21	N.A.	20.90
70-80	235.34	N.A.	8.30
80-90	72.36	N.A.	2.50
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	2848.31	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	93.81
10-20	267.28
20-30	401.11
30-40	477.86
40-50	491.89
50-60	448.78
60-70	359.87
70-80	235.34
80-90	72.36
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 24 SL UV FA 930.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	90	82	77	95	88	81	76	84	79	74	81	76	72	78	74	70	68
3	89	78	70	63	87	77	69	63	74	67	62	71	65	60	68	64	59	57
4	82	69	60	53	79	68	60	53	65	58	52	63	57	52	61	55	51	49
5	75	62	53	46	73	61	52	46	59	51	45	57	50	45	55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	40	51	44	39	50	44	39	37
7	64	51	42	35	62	50	41	35	48	41	35	47	40	35	45	39	34	32
8	60	46	37	32	58	45	37	31	44	37	31	43	36	31	42	35	31	29
9	56	42	34	28	54	42	34	28	41	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	39	31	26	38	30	26	37	30	25	36	30	25	24

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 24 SL UV FA 930.IES

UGR TABLE - CORRECTED


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	12.3	14.0	12.7	14.3	14.6	13.6	15.3	14.0	15.6	15.9
	3H	14.1	15.6	14.4	15.9	16.3	16.0	17.5	16.3	17.8	18.1
	4H	14.7	16.1	15.1	16.5	16.8	17.0	18.4	17.4	18.7	19.1
	6H	15.1	16.5	15.5	16.8	17.2	17.9	19.2	18.3	19.6	20.0
	8H	15.3	16.5	15.7	16.9	17.3	18.2	19.5	18.7	19.9	20.3
	12H	15.3	16.5	15.8	16.9	17.4	18.5	19.7	18.9	20.1	20.5
4H	2H	13.2	14.6	13.6	15.0	15.3	14.2	15.6	14.6	16.0	16.3
	3H	15.2	16.4	15.6	16.8	17.2	16.8	18.0	17.2	18.4	18.8
	4H	15.9	17.0	16.4	17.4	17.9	18.0	19.1	18.4	19.5	19.9
	6H	16.5	17.5	16.9	17.9	18.4	19.1	20.0	19.5	20.5	20.9
	8H	16.7	17.6	17.1	18.0	18.5	19.5	20.4	20.0	20.8	21.3
	12H	16.8	17.6	17.3	18.1	18.5	19.8	20.6	20.3	21.1	21.5
8H	4H	16.5	17.4	17.0	17.9	18.3	18.3	19.2	18.7	19.6	20.1
	6H	17.3	18.0	17.8	18.5	19.0	19.6	20.3	20.1	20.8	21.3
	8H	17.5	18.2	18.0	18.7	19.2	20.1	20.8	20.6	21.3	21.8
	12H	17.7	18.3	18.2	18.8	19.4	20.5	21.1	21.0	21.6	22.1
12H	4H	16.7	17.5	17.1	18.0	18.4	18.3	19.1	18.8	19.6	20.1
	6H	17.5	18.2	18.0	18.6	19.2	19.6	20.3	20.1	20.8	21.3
	8H	17.8	18.4	18.3	18.9	19.5	20.2	20.8	20.7	21.3	21.9

Maximum UGR = 22.1

POLAR GRAPH



Maximum Candela = 994.163 Located At Horizontal Angle = 90, Vertical Angle = 2
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (2) (Through Max. Cd.)