



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 24 VL UV FA 930.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-020A (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 2/25/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFL G2 24 VL UV FA 930

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflector,  
[MORE] frosted linear ribbed plastic enclosure.

[LAMP] 96 white LEDs, two LS3873A7\_3000\_90R 3000K LED boards

[BALLAST] One ULT D10CC30UNVPW-C LED driver programmed at 500mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	3653
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	142
Total Luminaire Watts	25.8
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1628	1741	1846
55	1505	1690	1863
65	1355	1666	1950
75	1136	1686	2134
85	721	1556	1917

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 24 VL UV FA 930.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	463.08	N.A.	12.70
0-30	977.49	N.A.	26.80
0-40	1590.32	N.A.	43.50
0-60	2796.69	N.A.	76.60
0-80	3560.02	N.A.	97.50
0-90	3652.82	N.A.	100.00
10-90	3532.51	N.A.	96.70
20-40	1127.24	N.A.	30.90
20-50	1758.07	N.A.	48.10
40-70	1667.88	N.A.	45.70
60-80	763.33	N.A.	20.90
70-80	301.82	N.A.	8.30
80-90	92.80	N.A.	2.50
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	3652.82	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	120.31
10-20	342.77
20-30	514.40
30-40	612.83
40-50	630.83
50-60	575.54
60-70	461.51
70-80	301.82
80-90	92.80
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 24 VL UV FA 930.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	90	82	76	95	88	81	76	84	79	74	81	76	72	78	74	70	68
3	89	78	70	63	87	77	69	63	74	67	62	71	65	60	68	64	59	57
4	82	69	60	53	79	68	60	53	65	58	52	63	57	52	61	55	51	49
5	75	62	53	46	73	61	52	46	59	51	45	57	50	45	55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	40	51	44	39	50	44	39	37
7	64	51	42	35	62	50	41	35	48	41	35	47	40	35	45	39	34	32
8	60	46	37	32	58	45	37	31	44	37	31	43	36	31	42	35	31	29
9	56	42	34	28	54	42	34	28	41	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	39	31	26	38	30	26	37	30	25	36	30	25	24

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 24 VL UV FA 930.IES**

**UGR TABLE - CORRECTED**


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	13.2	14.9	13.6	15.2	15.5	14.5	16.2	14.9	16.5	16.8
	3H	15.0	16.5	15.3	16.8	17.2	16.9	18.4	17.2	18.7	19.0
	4H	15.6	17.0	16.0	17.4	17.7	17.9	19.3	18.3	19.6	20.0
	6H	16.0	17.4	16.4	17.7	18.1	18.8	20.1	19.2	20.5	20.9
	8H	16.2	17.4	16.6	17.8	18.2	19.1	20.4	19.6	20.8	21.2
	12H	16.2	17.4	16.7	17.8	18.3	19.4	20.6	19.8	21.0	21.4
4H	2H	14.1	15.5	14.5	15.9	16.2	15.1	16.5	15.5	16.9	17.2
	3H	16.1	17.3	16.5	17.7	18.1	17.7	18.9	18.1	19.3	19.7
	4H	16.8	17.9	17.3	18.3	18.8	18.9	20.0	19.3	20.4	20.8
	6H	17.4	18.4	17.8	18.8	19.3	20.0	20.9	20.4	21.4	21.8
	8H	17.6	18.5	18.0	18.9	19.4	20.4	21.3	20.9	21.7	22.2
	12H	17.7	18.5	18.2	19.0	19.4	20.7	21.5	21.2	22.0	22.4
8H	4H	17.4	18.3	17.9	18.8	19.2	19.2	20.1	19.6	20.5	21.0
	6H	18.2	18.9	18.7	19.4	19.9	20.5	21.2	21.0	21.7	22.2
	8H	18.4	19.1	18.9	19.6	20.1	21.0	21.7	21.5	22.2	22.7
	12H	18.6	19.2	19.1	19.7	20.3	21.4	22.0	21.9	22.5	23.0
12H	4H	17.6	18.4	18.0	18.9	19.3	19.2	20.0	19.7	20.5	21.0
	6H	18.4	19.1	18.9	19.5	20.1	20.5	21.2	21.0	21.7	22.2
	8H	18.7	19.3	19.2	19.8	20.4	21.1	21.7	21.6	22.2	22.8

Maximum UGR = 23.0

POLAR GRAPH



Maximum Candela = 1274.965 Located At Horizontal Angle = 90, Vertical Angle = 2  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (2) (Through Max. Cd.)