



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 2R 24 HI UV FA 950.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-030 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 2/28/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFL G2 2R 24 HI UV FA 950

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflectors,

[MORE] two frosted linear ribbed plastic enclosures.

[LAMP] 192 white LEDs, four LS3873A7_5000_90R 5000K LED boards

[BALLAST] One ULT D15CC55UNVPW-C LED driver programmed at 920mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	6974
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	152
Total Luminaire Watts	46
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	3228	3433	3614
55	2989	3294	3559
65	2702	3124	3461
75	2267	2808	3101
85	1432	1579	1178

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 2R 24 HI UV FA 950.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	914.55	N.A.	13.10
0-30	1930.84	N.A.	27.70
0-40	3140.91	N.A.	45.00
0-60	5501.02	N.A.	78.90
0-80	6862.73	N.A.	98.40
0-90	6974.43	N.A.	100.00
10-90	6736.87	N.A.	96.60
20-40	2226.36	N.A.	31.90
20-50	3467.93	N.A.	49.70
40-70	3221.69	N.A.	46.20
60-80	1361.71	N.A.	19.50
70-80	500.13	N.A.	7.20
80-90	111.70	N.A.	1.60
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	6974.43	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	237.56
10-20	677.00
20-30	1016.28
30-40	1210.08
40-50	1241.57
50-60	1118.53
60-70	861.58
70-80	500.13
80-90	111.70
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 2R 24 HI UV FA 950.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	94	91	89	90	88	86	84
2	99	91	84	78	96	89	82	77	85	80	75	82	77	74	79	75	72	70
3	90	80	71	65	88	78	70	64	75	68	63	72	67	62	70	65	61	59
4	82	70	62	55	80	69	61	54	67	59	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	53	47	60	52	46	58	51	46	56	50	45	43
6	70	57	48	41	68	56	47	41	54	46	41	52	45	40	51	45	40	38
7	65	51	43	36	63	51	42	36	49	41	36	48	41	36	46	40	35	33
8	60	47	38	32	59	46	38	32	45	37	32	44	37	32	42	36	32	30
9	56	43	35	29	55	42	35	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	27	52	39	32	26	38	31	26	37	31	26	36	30	26	24


IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 2R 24 HI UV FA 950.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	15.8	17.4	16.2	17.8	18.1	16.8	18.4	17.2	18.7	19.1
	3H	17.5	19.0	17.9	19.3	19.7	18.8	20.3	19.1	20.6	20.9
	4H	18.2	19.5	18.6	19.9	20.3	19.5	20.9	19.9	21.3	21.6
	6H	18.6	19.9	19.0	20.2	20.6	20.0	21.3	20.4	21.7	22.1
	8H	18.7	19.9	19.1	20.3	20.7	20.1	21.4	20.5	21.8	22.2
	12H	18.7	19.9	19.2	20.3	20.7	20.2	21.3	20.6	21.7	22.2
4H	2H	16.6	18.0	17.0	18.3	18.7	17.4	18.8	17.8	19.1	19.5
	3H	18.5	19.7	19.0	20.1	20.5	19.6	20.7	20.0	21.1	21.5
	4H	19.3	20.3	19.7	20.8	21.2	20.5	21.5	20.9	21.9	22.4
	6H	19.8	20.8	20.3	21.2	21.7	21.1	22.0	21.5	22.5	22.9
	8H	20.0	20.9	20.4	21.3	21.8	21.2	22.1	21.7	22.6	23.0
	12H	20.1	20.9	20.5	21.3	21.8	21.3	22.1	21.8	22.6	23.0
8H	4H	19.7	20.6	20.1	21.0	21.5	20.7	21.6	21.2	22.0	22.5
	6H	20.4	21.1	20.9	21.6	22.0	21.5	22.2	22.0	22.7	23.2
	8H	20.6	21.2	21.1	21.7	22.2	21.7	22.3	22.2	22.8	23.3
	12H	20.7	21.3	21.2	21.8	22.4	21.8	22.3	22.3	22.8	23.4
12H	4H	19.7	20.5	20.2	21.0	21.5	20.7	21.5	21.2	22.0	22.5
	6H	20.5	21.1	21.0	21.6	22.1	21.5	22.2	22.0	22.6	23.2
	8H	20.7	21.3	21.2	21.8	22.3	21.8	22.3	22.3	22.8	23.4

Maximum UGR = 23.4

POLAR GRAPH



Maximum Candela = 2514.938 Located At Horizontal Angle = 67.5, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (67.5 - 247.5) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)