



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 2R 24 LW UV FA 940.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-030 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 2/28/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFL G2 2R 24 LW UV FA 940

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflectors,

[MORE] two frosted linear ribbed plastic enclosures.

[LAMP] 192 white LEDs, four LS3873A7_4000_90R 4000K LED boards

[BALLAST] One ULT D10CC30UNVPW-C LED driver programmed at 560mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4229
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	150
Total Luminaire Watts	28.2
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1957	2081	2191
55	1813	1998	2158
65	1638	1894	2099
75	1374	1702	1880
85	868	958	714

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 2R 24 LW UV FA 940.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	554.52	N.A.	13.10
0-30	1170.73	N.A.	27.70
0-40	1904.43	N.A.	45.00
0-60	3335.44	N.A.	78.90
0-80	4161.09	N.A.	98.40
0-90	4228.82	N.A.	100.00
10-90	4084.78	N.A.	96.60
20-40	1349.91	N.A.	31.90
20-50	2102.72	N.A.	49.70
40-70	1953.41	N.A.	46.20
60-80	825.65	N.A.	19.50
70-80	303.24	N.A.	7.20
80-90	67.73	N.A.	1.60
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	4228.82	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	144.04
10-20	410.48
20-30	616.20
30-40	733.71
40-50	752.81
50-60	678.20
60-70	522.40
70-80	303.24
80-90	67.73
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 2R 24 LW UV FA 940.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	94	91	89	90	88	86	84
2	99	91	84	78	96	89	82	77	85	80	75	82	77	74	79	75	72	70
3	90	80	71	65	88	78	70	64	75	68	63	72	67	62	70	65	61	59
4	82	70	62	55	80	69	61	54	67	59	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	53	47	60	52	46	58	51	46	56	50	45	43
6	70	57	48	41	68	56	47	41	54	46	41	52	45	40	51	45	40	38
7	65	51	43	36	63	51	42	36	49	41	36	48	41	36	46	40	35	33
8	60	47	38	32	59	46	38	32	45	37	32	44	37	32	42	36	32	30
9	56	43	35	29	55	42	35	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	27	52	39	32	26	38	31	26	37	31	26	36	30	26	24

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 2R 24 LW UV FA 940.IES

UGR TABLE - CORRECTED


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	14.0	15.6	14.4	16.0	16.3	15.0	16.6	15.4	16.9	17.3
	3H	15.7	17.2	16.1	17.5	17.9	17.0	18.5	17.3	18.8	19.1
	4H	16.4	17.7	16.8	18.1	18.5	17.7	19.1	18.1	19.5	19.8
	6H	16.8	18.1	17.2	18.4	18.8	18.2	19.5	18.6	19.9	20.3
	8H	16.9	18.1	17.3	18.5	18.9	18.3	19.6	18.7	20.0	20.4
	12H	17.0	18.1	17.4	18.5	18.9	18.4	19.5	18.8	19.9	20.4
4H	2H	14.8	16.2	15.2	16.5	16.9	15.6	17.0	16.0	17.3	17.7
	3H	16.7	17.9	17.2	18.3	18.7	17.8	18.9	18.2	19.3	19.7
	4H	17.5	18.5	17.9	19.0	19.4	18.7	19.7	19.1	20.1	20.6
	6H	18.0	19.0	18.5	19.4	19.9	19.3	20.2	19.7	20.7	21.1
	8H	18.2	19.1	18.6	19.5	20.0	19.4	20.3	19.9	20.8	21.2
	12H	18.3	19.1	18.7	19.5	20.0	19.5	20.3	20.0	20.8	21.2
8H	4H	17.9	18.8	18.3	19.2	19.7	18.9	19.8	19.4	20.2	20.7
	6H	18.6	19.3	19.1	19.8	20.2	19.7	20.4	20.2	20.9	21.4
	8H	18.8	19.4	19.3	19.9	20.4	19.9	20.5	20.4	21.0	21.5
	12H	18.9	19.5	19.4	20.0	20.6	20.0	20.5	20.5	21.0	21.6
12H	4H	17.9	18.7	18.4	19.2	19.7	18.9	19.7	19.4	20.2	20.7
	6H	18.7	19.3	19.2	19.8	20.3	19.7	20.4	20.2	20.8	21.4
	8H	18.9	19.5	19.4	20.0	20.5	20.0	20.5	20.5	21.0	21.6

Maximum UGR = 21.6

POLAR GRAPH



Maximum Candela = 1524.886 Located At Horizontal Angle = 67.5, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (67.5 - 247.5) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)