



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 2R 24 HI UV FA 935.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-030 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 2/28/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFL G2 2R 24 HI UV FA 935

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflectors,

[MORE] two frosted linear ribbed plastic enclosures.

[LAMP] 192 white LEDs, four LS3873A7_3500_90R 3500K LED boards

[BALLAST] One ULT D15CC55UNVPW-C LED driver programmed at 920mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	6813
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	148
Total Luminaire Watts	46
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	3153	3353	3530
55	2920	3218	3476
65	2639	3052	3381
75	2214	2743	3029
85	1399	1543	1150

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 2R 24 HI UV FA 935.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	893.34	N.A.	13.10
0-30	1886.04	N.A.	27.70
0-40	3068.04	N.A.	45.00
0-60	5373.39	N.A.	78.90
0-80	6703.51	N.A.	98.40
0-90	6812.62	N.A.	100.00
10-90	6580.58	N.A.	96.60
20-40	2174.71	N.A.	31.90
20-50	3387.48	N.A.	49.70
40-70	3146.95	N.A.	46.20
60-80	1330.12	N.A.	19.50
70-80	488.52	N.A.	7.20
80-90	109.11	N.A.	1.60
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	6812.62	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	232.04
10-20	661.29
20-30	992.70
30-40	1182.00
40-50	1212.77
50-60	1092.58
60-70	841.59
70-80	488.52
80-90	109.11
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 2R 24 HI UV FA 935.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	94	91	89	90	88	86	84
2	99	91	84	78	96	89	82	77	85	80	75	82	77	74	79	75	72	70
3	90	80	71	65	88	78	70	64	75	68	63	72	67	62	70	65	61	59
4	82	70	62	55	80	69	61	54	67	59	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	53	47	60	52	46	58	51	46	56	50	45	43
6	70	57	48	41	68	56	47	41	54	46	41	52	45	40	51	45	40	38
7	65	51	43	36	63	51	42	36	49	41	36	48	41	36	46	40	35	33
8	60	47	38	32	59	46	38	32	45	37	32	44	37	32	42	36	32	30
9	56	43	35	29	55	42	35	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	27	52	39	32	26	38	31	26	37	31	26	36	30	26	24

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 2R 24 HI UV FA 935.IES

UGR TABLE - CORRECTED


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	15.7	17.3	16.1	17.7	18.0	16.7	18.3	17.1	18.6	19.0
	3H	17.4	18.9	17.8	19.2	19.6	18.7	20.2	19.0	20.5	20.8
	4H	18.1	19.4	18.5	19.8	20.2	19.4	20.8	19.8	21.2	21.5
	6H	18.5	19.8	18.9	20.1	20.5	19.9	21.2	20.3	21.6	22.0
	8H	18.6	19.8	19.0	20.2	20.6	20.0	21.3	20.4	21.7	22.1
	12H	18.6	19.8	19.1	20.2	20.6	20.1	21.2	20.5	21.6	22.1
4H	2H	16.5	17.9	16.9	18.2	18.6	17.3	18.7	17.7	19.0	19.4
	3H	18.4	19.6	18.9	20.0	20.4	19.5	20.6	19.9	21.0	21.4
	4H	19.2	20.2	19.6	20.7	21.1	20.4	21.4	20.8	21.8	22.3
	6H	19.7	20.7	20.2	21.1	21.6	21.0	21.9	21.4	22.4	22.8
	8H	19.9	20.8	20.3	21.2	21.7	21.1	22.0	21.6	22.5	22.9
	12H	20.0	20.8	20.4	21.2	21.7	21.2	22.0	21.7	22.5	22.9
8H	4H	19.6	20.5	20.0	20.9	21.4	20.6	21.5	21.1	21.9	22.4
	6H	20.3	21.0	20.8	21.5	21.9	21.4	22.1	21.9	22.6	23.1
	8H	20.5	21.1	21.0	21.6	22.1	21.6	22.2	22.1	22.7	23.2
	12H	20.6	21.2	21.1	21.7	22.3	21.7	22.2	22.2	22.7	23.3
12H	4H	19.6	20.4	20.1	20.9	21.4	20.6	21.4	21.1	21.9	22.4
	6H	20.4	21.0	20.9	21.5	22.0	21.4	22.1	21.9	22.5	23.1
	8H	20.6	21.2	21.1	21.7	22.2	21.7	22.2	22.2	22.7	23.3

Maximum UGR = 23.3

POLAR GRAPH



Maximum Candela = 2456.592 Located At Horizontal Angle = 67.5, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (67.5 - 247.5) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)