



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 2R 24 VH UV FA 950.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-030 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 2/28/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFL G2 2R 24 VH UV FA 950

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflectors,

[MORE] two frosted linear ribbed plastic enclosures.

[LAMP] 192 white LEDs, four LS3873A7\_5000\_90R 5000K LED boards

[BALLAST] One ULT D15CC55UNVPW-C LED driver programmed at 1060mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	8030
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	152
Total Luminaire Watts	52.9
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	3717	3952	4161
55	3442	3793	4097
65	3111	3597	3985
75	2610	3233	3570
85	1649	1818	1356

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 2R 24 VH UV FA 950.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	1052.97	N.A.	13.10
0-30	2223.07	N.A.	27.70
0-40	3616.3	N.A.	45.00
0-60	6333.62	N.A.	78.90
0-80	7901.43	N.A.	98.40
0-90	8030.03	N.A.	100.00
10-90	7756.52	N.A.	96.60
20-40	2563.33	N.A.	31.90
20-50	3992.82	N.A.	49.70
40-70	3709.3	N.A.	46.20
60-80	1567.81	N.A.	19.50
70-80	575.82	N.A.	7.20
80-90	128.61	N.A.	1.60
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	8030.03	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	273.51
10-20	779.46
20-30	1170.1
30-40	1393.23
40-50	1429.49
50-60	1287.83
60-70	991.99
70-80	575.82
80-90	128.61
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 2R 24 VH UV FA 950.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	94	91	89	90	88	86	84
2	99	91	84	78	96	89	82	77	85	80	75	82	77	74	79	75	72	70
3	90	80	71	65	88	78	70	64	75	68	63	72	67	62	70	65	61	59
4	82	70	62	55	80	69	61	54	67	59	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	53	47	60	52	46	58	51	46	56	50	45	43
6	70	57	48	41	68	56	47	41	54	46	41	52	45	40	51	45	40	38
7	65	51	43	36	63	51	42	36	49	41	36	48	41	36	46	40	35	33
8	60	47	38	32	59	46	38	32	45	37	32	44	37	32	42	36	32	30
9	56	43	35	29	55	42	35	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	27	52	39	32	26	38	31	26	37	31	26	36	30	26	24

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 2R 24 VH UV FA 950.IES**

**UGR TABLE - CORRECTED**


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	16.2	17.8	16.6	18.2	18.5	17.2	18.8	17.6	19.1	19.5
	3H	17.9	19.4	18.3	19.7	20.1	19.2	20.7	19.5	21.0	21.3
	4H	18.6	19.9	19.0	20.3	20.7	19.9	21.3	20.3	21.7	22.0
	6H	19.0	20.3	19.4	20.6	21.0	20.4	21.7	20.8	22.1	22.5
	8H	19.1	20.3	19.5	20.7	21.1	20.5	21.8	20.9	22.2	22.6
	12H	19.1	20.3	19.6	20.7	21.1	20.6	21.7	21.0	22.1	22.6
4H	2H	17.0	18.4	17.4	18.7	19.1	17.8	19.2	18.2	19.5	19.9
	3H	18.9	20.1	19.4	20.5	20.9	20.0	21.1	20.4	21.5	21.9
	4H	19.7	20.7	20.1	21.2	21.6	20.8	21.9	21.3	22.3	22.8
	6H	20.2	21.2	20.7	21.6	22.0	21.5	22.4	21.9	22.9	23.3
	8H	20.4	21.2	20.8	21.7	22.2	21.6	22.5	22.1	23.0	23.4
	12H	20.5	21.3	20.9	21.7	22.2	21.7	22.5	22.2	23.0	23.4
8H	4H	20.1	21.0	20.5	21.4	21.9	21.1	22.0	21.6	22.4	22.9
	6H	20.8	21.5	21.3	22.0	22.4	21.9	22.6	22.4	23.1	23.6
	8H	21.0	21.6	21.5	22.1	22.6	22.1	22.7	22.6	23.2	23.7
	12H	21.1	21.7	21.6	22.2	22.8	22.2	22.7	22.7	23.2	23.8
12H	4H	20.1	20.9	20.6	21.4	21.9	21.1	21.9	21.6	22.4	22.9
	6H	20.9	21.5	21.4	22.0	22.5	21.9	22.6	22.4	23.0	23.6
	8H	21.1	21.7	21.6	22.2	22.7	22.2	22.7	22.7	23.2	23.8

Maximum UGR = 23.8

POLAR GRAPH



Maximum Candela = 2895.583 Located At Horizontal Angle = 67.5, Vertical Angle = .5  
# 1 - Vertical Plane Through Horizontal Angles (67.5 - 247.5) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)