



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 2R 24 SH UV FA 950.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-030

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 2/28/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFL G2 2R 24 SH UV FA 950

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflectors,  
[MORE] two frosted linear ribbed plastic enclosures.

[LAMP] 192 white LEDs, four LS3873A7\_5000\_90R 5000K LED boards

[BALLAST] One ULT D15CC55UNVPW-C LED driver programmed at 1190mA

[OTHER] 120.0Vac, 60.00Hz, 0.5026A, 59.80W, 0.991PF, 6.0%THD(i)

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	8999
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	150
Total Luminaire Watts	59.804
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	4165	4429	4663
55	3857	4251	4592
65	3486	4031	4466
75	2925	3623	4001
85	1848	2038	1520

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 2R 24 SH UV FA 950.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	1180.04	N.A.	13.10
0-30	2491.34	N.A.	27.70
0-40	4052.69	N.A.	45.00
0-60	7097.91	N.A.	78.90
0-80	8854.91	N.A.	98.40
0-90	8999.04	N.A.	100.00
10-90	8692.52	N.A.	96.60
20-40	2872.65	N.A.	31.90
20-50	4474.64	N.A.	49.70
40-70	4156.91	N.A.	46.20
60-80	1757.00	N.A.	19.50
70-80	645.31	N.A.	7.20
80-90	144.12	N.A.	1.60
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	8999.04	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	306.52
10-20	873.52
20-30	1311.3
30-40	1561.35
40-50	1601.99
50-60	1443.23
60-70	1111.69
70-80	645.31
80-90	144.12
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 2R 24 SH UV FA 950.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	94	91	89	90	88	86	84
2	99	91	84	78	96	89	82	77	85	80	75	82	77	74	79	75	72	70
3	90	80	71	65	88	78	70	64	75	68	63	72	67	62	70	65	61	59
4	82	70	62	55	80	69	61	54	67	59	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	53	47	60	52	46	58	51	46	56	50	45	43
6	70	57	48	41	68	56	47	41	54	46	41	52	45	40	51	45	40	38
7	65	51	43	36	63	51	42	36	49	41	36	48	41	36	46	40	35	33
8	60	47	38	32	59	46	38	32	45	37	32	44	37	32	42	36	32	30
9	56	43	35	29	55	42	35	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	27	52	39	32	26	38	31	26	37	31	26	36	30	26	24

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 2R 24 SH UV FA 950.IES**

**UGR TABLE - CORRECTED**


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	16.6	18.2	17.0	18.6	18.9	17.6	19.2	18.0	19.5	19.9
	3H	18.3	19.8	18.7	20.1	20.5	19.6	21.1	19.9	21.4	21.7
	4H	19.0	20.3	19.4	20.7	21.1	20.3	21.7	20.7	22.1	22.4
	6H	19.4	20.7	19.8	21.0	21.4	20.8	22.1	21.2	22.5	22.9
	8H	19.5	20.7	19.9	21.1	21.5	20.9	22.2	21.3	22.6	23.0
	12H	19.5	20.7	20.0	21.1	21.5	21.0	22.1	21.4	22.5	23.0
4H	2H	17.4	18.8	17.8	19.1	19.5	18.2	19.6	18.6	19.9	20.3
	3H	19.3	20.5	19.8	20.9	21.3	20.4	21.5	20.8	21.9	22.3
	4H	20.1	21.1	20.5	21.6	22.0	21.2	22.3	21.7	22.7	23.2
	6H	20.6	21.6	21.1	22.0	22.5	21.9	22.8	22.3	23.3	23.7
	8H	20.8	21.7	21.2	22.1	22.6	22.0	22.9	22.5	23.4	23.8
	12H	20.9	21.7	21.3	22.1	22.6	22.1	22.9	22.6	23.4	23.8
8H	4H	20.5	21.4	20.9	21.8	22.3	21.5	22.4	22.0	22.8	23.3
	6H	21.2	21.9	21.7	22.4	22.8	22.3	23.0	22.8	23.5	24.0
	8H	21.4	22.0	21.9	22.5	23.0	22.5	23.1	23.0	23.6	24.1
	12H	21.5	22.1	22.0	22.6	23.2	22.6	23.1	23.1	23.6	24.2
12H	4H	20.5	21.3	21.0	21.8	22.3	21.5	22.3	22.0	22.8	23.3
	6H	21.3	21.9	21.8	22.4	22.9	22.3	23.0	22.8	23.4	24.0
	8H	21.5	22.1	22.0	22.6	23.1	22.6	23.1	23.1	23.6	24.2

Maximum UGR = 24.2

POLAR GRAPH



Maximum Candela = 3245 Located At Horizontal Angle = 67.5, Vertical Angle = .5  
# 1 - Vertical Plane Through Horizontal Angles (67.5 - 247.5) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)