



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFR G2 14 HI UV FA 940.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-017 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 2/17/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFR G2 14 HI UV FA 940

[LUMINAIRE] Retrofit kit installed in an A.L.P. EF-1x4-2L-23GA 1x4 housing,

[MORE] formed white painted steel reflectors, frosted linear ribbed plastic enclosure.

[LAMP] 96 white LEDs, two LS3873A7_4000_90R 4000K LED boards

[BALLAST] One ULT D15CC55UNVPW-C LED driver programmed at 820mA

[OTHER] 120.0Vac, 60.00Hz, 0.3593A, 42.64W, 0.989PF, 7.9%THD(i)

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	5989
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	140
Total Luminaire Watts	42.637
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.75 ft
Luminous Width (90-270)	0.75 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	7132	7657	8138
55	6593	7313	7726
65	5944	6641	6840
75	4993	5422	5141
85	3290	1974	1009

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 14 HI UV FA 940.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	805.95	N.A.	13.50
0-30	1701.05	N.A.	28.40
0-40	2766.35	N.A.	46.20
0-60	4826.21	N.A.	80.60
0-80	5917.96	N.A.	98.80
0-90	5989.26	N.A.	100.00
10-90	5779.87	N.A.	96.50
20-40	1960.4	N.A.	32.70
20-50	3051.43	N.A.	50.90
40-70	2773.25	N.A.	46.30
60-80	1091.75	N.A.	18.20
70-80	378.35	N.A.	6.30
80-90	71.30	N.A.	1.20
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	5989.26	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	209.39
10-20	596.56
20-30	895.10
30-40	1065.31
40-50	1091.03
50-60	968.83
60-70	713.40
70-80	378.35
80-90	71.30
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 14 HI UV FA 940.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	105	100	97	106	102	98	95	98	95	92	94	92	89	91	88	87	85
2	99	91	85	79	97	89	83	78	86	81	76	83	78	75	80	76	73	71
3	91	80	72	66	88	79	71	65	76	69	64	73	68	63	70	66	62	60
4	83	71	63	56	81	70	62	55	67	60	55	65	59	54	63	58	53	51
5	76	64	55	48	74	63	54	48	60	53	47	58	52	47	57	51	46	44
6	71	57	48	42	69	56	48	42	55	47	42	53	46	41	51	45	41	39
7	65	52	43	37	64	51	43	37	50	42	37	48	42	37	47	41	36	34
8	61	47	39	33	59	47	39	33	45	38	33	44	38	33	43	37	32	31
9	57	44	35	30	56	43	35	30	42	35	30	41	34	30	40	34	29	28
10	53	40	32	27	52	40	32	27	39	32	27	38	31	27	37	31	27	25


IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 14 HI UV FA 940.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	18.5	20.2	18.9	20.5	20.8	19.4	21.0	19.7	21.3	21.6
	3H	20.2	21.7	20.6	22.0	22.4	21.0	22.5	21.4	22.8	23.2
	4H	20.9	22.2	21.3	22.6	23.0	21.5	22.9	21.9	23.2	23.6
	6H	21.3	22.6	21.7	22.9	23.3	21.8	23.1	22.2	23.4	23.8
	8H	21.4	22.6	21.8	23.0	23.4	21.8	23.0	22.3	23.4	23.8
	12H	21.5	22.6	21.9	23.0	23.4	21.8	23.0	22.2	23.4	23.8
4H	2H	19.3	20.6	19.7	21.0	21.4	19.9	21.3	20.3	21.6	22.0
	3H	21.2	22.3	21.6	22.7	23.1	21.8	22.9	22.2	23.3	23.7
	4H	21.9	23.0	22.4	23.4	23.8	22.4	23.4	22.8	23.9	24.3
	6H	22.5	23.4	22.9	23.8	24.3	22.8	23.7	23.2	24.1	24.6
	8H	22.6	23.5	23.1	23.9	24.4	22.8	23.7	23.3	24.1	24.6
	12H	22.7	23.5	23.2	23.9	24.4	22.8	23.6	23.3	24.1	24.5
8H	4H	22.2	23.1	22.7	23.5	24.0	22.6	23.5	23.1	23.9	24.4
	6H	22.9	23.6	23.4	24.1	24.5	23.1	23.8	23.6	24.3	24.8
	8H	23.1	23.7	23.6	24.2	24.7	23.2	23.8	23.7	24.3	24.8
	12H	23.2	23.8	23.7	24.3	24.8	23.2	23.7	23.7	24.2	24.8
12H	4H	22.2	23.0	22.7	23.5	23.9	22.7	23.4	23.1	23.9	24.4
	6H	22.9	23.5	23.4	24.0	24.5	23.1	23.8	23.6	24.2	24.8
	8H	23.1	23.7	23.6	24.2	24.7	23.2	23.8	23.7	24.3	24.8

Maximum UGR = 24.8

POLAR GRAPH



Maximum Candela = 2220 Located At Horizontal Angle = 90, Vertical Angle = 2
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (2) (Through Max. Cd.)