



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFR G2 14 SL UV FA 950.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-017 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 2/17/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFR G2 14 SL UV FA 950

[LUMINAIRE] Retrofit kit installed in an A.L.P. EF-1x4-2L-23GA 1x4 housing,

[MORE] formed white painted steel reflectors, frosted linear ribbed plastic enclosure.

[LAMP] 96 white LEDs, two LS3873A7_5000_90R 5000K LED boards

[BALLAST] One ULT D700C20UNVPW-C LED driver programmed at 260mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

| | |
|---------------------------------|-----------------|
| Lumens Per Lamp | N.A. (absolute) |
| Total Lamp Lumens | N.A. (absolute) |
| Luminaire Lumens | 1923 |
| Total Luminaire Efficiency | N.A. |
| Luminaire Efficacy Rating (LER) | 136 |
| Total Luminaire Watts | 14.1 |
| Ballast Factor | 1.00 |
| CIE Type | Direct |
| Spacing Criterion (0-180) | 1.20 |
| Spacing Criterion (90-270) | 1.28 |
| Spacing Criterion (Diagonal) | 1.36 |
| Basic Luminous Shape | Rectangular |
| Luminous Length (0-180) | 3.75 ft |
| Luminous Width (90-270) | 0.75 ft |
| Luminous Height | 0.00 ft |

LUMINANCE DATA (cd/sq.m)

| Angle In Degrees | Average 0-Deg | Average 45-Deg | Average 90-Deg |
|---------------------|------------------|-------------------|-------------------|
| 45 | 2290 | 2458 | 2612 |
| 55 | 2116 | 2347 | 2480 |
| 65 | 1908 | 2132 | 2196 |
| 75 | 1603 | 1740 | 1650 |
| 85 | 1056 | 634 | 324 |

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 14 SL UV FA 950.IES

ZONAL LUMEN SUMMARY

| Zone | Lumens | %Lamp | %Fixt |
|---------|---------|-------|--------|
| 0-20 | 258.71 | N.A. | 13.50 |
| 0-30 | 546.05 | N.A. | 28.40 |
| 0-40 | 888.01 | N.A. | 46.20 |
| 0-60 | 1549.24 | N.A. | 80.60 |
| 0-80 | 1899.69 | N.A. | 98.80 |
| 0-90 | 1922.58 | N.A. | 100.00 |
| 10-90 | 1855.37 | N.A. | 96.50 |
| 20-40 | 629.30 | N.A. | 32.70 |
| 20-50 | 979.52 | N.A. | 50.90 |
| 40-70 | 890.23 | N.A. | 46.30 |
| 60-80 | 350.46 | N.A. | 18.20 |
| 70-80 | 121.45 | N.A. | 6.30 |
| 80-90 | 22.89 | N.A. | 1.20 |
| 90-110 | 0.00 | N.A. | 0.00 |
| 90-120 | 0.00 | N.A. | 0.00 |
| 90-130 | 0.00 | N.A. | 0.00 |
| 90-150 | 0.00 | N.A. | 0.00 |
| 90-180 | 0.00 | N.A. | 0.00 |
| 110-180 | 0.00 | N.A. | 0.00 |
| 0-180 | 1922.58 | N.A. | 100.00 |

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

| Zone | Lumens |
|---------|--------|
| 0-10 | 67.22 |
| 10-20 | 191.50 |
| 20-30 | 287.33 |
| 30-40 | 341.97 |
| 40-50 | 350.23 |
| 50-60 | 311.00 |
| 60-70 | 229.00 |
| 70-80 | 121.45 |
| 80-90 | 22.89 |
| 90-100 | 0.00 |
| 100-110 | 0.00 |
| 110-120 | 0.00 |
| 120-130 | 0.00 |
| 130-140 | 0.00 |
| 140-150 | 0.00 |
| 150-160 | 0.00 |
| 160-170 | 0.00 |
| 170-180 | 0.00 |

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 14 SL UV FA 950.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

| RC | 80 | | | | 70 | | | | 50 | | | 30 | | | 10 | | | 0 |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| RW | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 0 |
| 0 | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | 106 | 106 | 106 | 102 | 102 | 102 | 100 |
| 1 | 109 | 104 | 100 | 97 | 106 | 102 | 98 | 95 | 98 | 95 | 92 | 94 | 92 | 89 | 91 | 88 | 87 | 85 |
| 2 | 99 | 91 | 85 | 79 | 97 | 89 | 83 | 78 | 86 | 81 | 76 | 83 | 78 | 74 | 80 | 76 | 73 | 71 |
| 3 | 91 | 80 | 72 | 66 | 88 | 79 | 71 | 65 | 76 | 69 | 64 | 73 | 68 | 63 | 70 | 66 | 62 | 60 |
| 4 | 83 | 71 | 63 | 56 | 81 | 70 | 62 | 55 | 67 | 60 | 55 | 65 | 59 | 54 | 63 | 58 | 53 | 51 |
| 5 | 76 | 64 | 55 | 48 | 74 | 63 | 54 | 48 | 60 | 53 | 47 | 58 | 52 | 47 | 57 | 51 | 46 | 44 |
| 6 | 71 | 57 | 48 | 42 | 69 | 56 | 48 | 42 | 55 | 47 | 42 | 53 | 46 | 41 | 51 | 45 | 41 | 39 |
| 7 | 65 | 52 | 43 | 37 | 64 | 51 | 43 | 37 | 50 | 42 | 37 | 48 | 42 | 37 | 47 | 41 | 36 | 34 |
| 8 | 61 | 47 | 39 | 33 | 59 | 47 | 39 | 33 | 45 | 38 | 33 | 44 | 38 | 33 | 43 | 37 | 32 | 31 |
| 9 | 57 | 44 | 35 | 30 | 56 | 43 | 35 | 30 | 42 | 35 | 30 | 41 | 34 | 29 | 40 | 34 | 29 | 28 |
| 10 | 53 | 40 | 32 | 27 | 52 | 40 | 32 | 27 | 39 | 32 | 27 | 38 | 31 | 27 | 37 | 31 | 27 | 25 |


IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 14 SL UV FA 950.IES

UGR TABLE - CORRECTED

| Reflectances | | | | | | | | | | | |
|----------------|------|----------------------|------|------|------|------|--------------------|------|------|------|------|
| Ceiling Cavity | 70 | 70 | 50 | 50 | 30 | 70 | 70 | 50 | 50 | 30 | |
| Walls | 50 | 30 | 50 | 30 | 30 | 50 | 30 | 50 | 30 | 30 | |
| Floor Cavity | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | |
| Room Size | | UGR Viewed Crosswise | | | | | UGR Viewed Endwise | | | | |
| X=2H | Y=2H | 14.6 | 16.3 | 15.0 | 16.6 | 16.9 | 15.5 | 17.1 | 15.8 | 17.4 | 17.7 |
| | 3H | 16.3 | 17.8 | 16.7 | 18.1 | 18.5 | 17.1 | 18.6 | 17.5 | 18.9 | 19.3 |
| | 4H | 17.0 | 18.3 | 17.4 | 18.7 | 19.1 | 17.6 | 19.0 | 18.0 | 19.3 | 19.7 |
| | 6H | 17.4 | 18.7 | 17.8 | 19.0 | 19.4 | 17.9 | 19.2 | 18.3 | 19.5 | 19.9 |
| | 8H | 17.5 | 18.7 | 17.9 | 19.1 | 19.5 | 17.9 | 19.1 | 18.4 | 19.5 | 19.9 |
| | 12H | 17.6 | 18.7 | 18.0 | 19.1 | 19.5 | 17.9 | 19.1 | 18.3 | 19.5 | 19.9 |
| 4H | 2H | 15.4 | 16.7 | 15.8 | 17.1 | 17.5 | 16.0 | 17.4 | 16.4 | 17.8 | 18.1 |
| | 3H | 17.3 | 18.4 | 17.7 | 18.8 | 19.2 | 17.9 | 19.0 | 18.3 | 19.4 | 19.8 |
| | 4H | 18.0 | 19.1 | 18.5 | 19.5 | 19.9 | 18.5 | 19.5 | 18.9 | 20.0 | 20.4 |
| | 6H | 18.6 | 19.5 | 19.0 | 19.9 | 20.4 | 18.9 | 19.8 | 19.3 | 20.2 | 20.7 |
| | 8H | 18.7 | 19.6 | 19.2 | 20.0 | 20.5 | 18.9 | 19.8 | 19.4 | 20.2 | 20.7 |
| | 12H | 18.8 | 19.6 | 19.3 | 20.0 | 20.5 | 18.9 | 19.7 | 19.4 | 20.2 | 20.6 |
| 8H | 4H | 18.3 | 19.2 | 18.8 | 19.6 | 20.1 | 18.7 | 19.6 | 19.2 | 20.0 | 20.5 |
| | 6H | 19.0 | 19.7 | 19.5 | 20.2 | 20.6 | 19.2 | 19.9 | 19.7 | 20.4 | 20.9 |
| | 8H | 19.2 | 19.8 | 19.7 | 20.3 | 20.8 | 19.3 | 19.9 | 19.8 | 20.4 | 20.9 |
| | 12H | 19.3 | 19.9 | 19.8 | 20.4 | 20.9 | 19.3 | 19.8 | 19.8 | 20.3 | 20.9 |
| 12H | 4H | 18.3 | 19.1 | 18.8 | 19.6 | 20.0 | 18.8 | 19.5 | 19.2 | 20.0 | 20.5 |
| | 6H | 19.0 | 19.6 | 19.5 | 20.1 | 20.6 | 19.2 | 19.9 | 19.7 | 20.3 | 20.9 |
| | 8H | 19.2 | 19.8 | 19.7 | 20.3 | 20.8 | 19.3 | 19.9 | 19.8 | 20.4 | 20.9 |

Maximum UGR = 20.9

POLAR GRAPH



Maximum Candela = 712.632 Located At Horizontal Angle = 90, Vertical Angle = 2
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (2) (Through Max. Cd.)