



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFR G2 22 VL UV FA 930.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-014 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 2/17/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFR G2 22 VL UV FA 930

[LUMINAIRE] Retrofit kit installed in an A.L.P. EL-2x2-20-2 2x2 housing,

[MORE] formed white painted steel reflectors, frosted linear ribbed plastic enclosure.

[LAMP] 48 white LEDs, one LS3872A7\_3000\_90R 3000K LED board

[BALLAST] One ULT D700C20UNVPW-C LED driver programmed at 400mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	2835
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	131
Total Luminaire Watts	21.6
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	1.84 ft
Luminous Width (90-270)	1.84 ft
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	2578	2825	3078
55	2365	2746	3160
65	2117	2714	3368
75	1790	2747	3797
85	1290	2318	2597

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFR G2 22 VL UV FA 930.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	359.79	N.A.	12.70
0-30	758.14	N.A.	26.70
0-40	1231.78	N.A.	43.50
0-60	2166.68	N.A.	76.40
0-80	2766.31	N.A.	97.60
0-90	2834.9	N.A.	100.00
10-90	2741.31	N.A.	96.70
20-40	871.99	N.A.	30.80
20-50	1359.88	N.A.	48.00
40-70	1295.74	N.A.	45.70
60-80	599.63	N.A.	21.20
70-80	238.79	N.A.	8.40
80-90	68.59	N.A.	2.40
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	2834.9	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	93.59
10-20	266.20
20-30	398.35
30-40	473.64
40-50	487.89
50-60	447.01
60-70	360.84
70-80	238.79
80-90	68.59
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFR G2 22 VL UV FA 930.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	90	82	76	95	88	81	76	84	79	74	81	76	72	78	74	70	68
3	89	78	70	63	87	77	69	63	74	67	62	71	65	60	68	64	59	57
4	82	69	60	53	79	68	60	53	65	58	52	63	57	52	61	55	51	49
5	75	62	53	46	73	61	52	46	59	51	45	57	50	45	55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	50	44	39	37
7	64	50	42	35	62	50	41	35	48	40	35	47	40	35	45	39	34	32
8	60	46	37	32	58	45	37	31	44	37	31	43	36	31	42	35	31	29
9	56	42	34	28	54	42	34	28	41	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	39	31	26	37	30	26	37	30	25	36	30	25	24

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFR G2 22 VL UV FA 930.IES**

**UGR TABLE - CORRECTED**


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	14.7	16.4	15.1	16.7	17.0	16.4	18.1	16.8	18.4	18.7
	3H	16.4	17.9	16.8	18.3	18.6	18.8	20.3	19.2	20.7	21.0
	4H	17.0	18.5	17.4	18.8	19.2	19.9	21.3	20.3	21.7	22.0
	6H	17.5	18.8	17.9	19.2	19.6	20.8	22.2	21.3	22.5	22.9
	8H	17.6	18.9	18.1	19.3	19.7	21.2	22.4	21.6	22.8	23.2
	12H	17.7	18.9	18.1	19.3	19.7	21.3	22.5	21.7	22.9	23.3
4H	2H	15.6	17.0	16.0	17.4	17.8	16.9	18.4	17.3	18.7	19.1
	3H	17.6	18.8	18.0	19.2	19.6	19.6	20.8	20.0	21.2	21.6
	4H	18.3	19.4	18.8	19.8	20.3	20.9	22.0	21.3	22.4	22.8
	6H	18.9	19.9	19.3	20.3	20.8	22.0	23.0	22.4	23.4	23.9
	8H	19.1	20.0	19.6	20.4	20.9	22.4	23.3	22.8	23.7	24.2
	12H	19.2	20.0	19.7	20.5	21.0	22.6	23.4	23.1	23.9	24.3
8H	4H	19.0	19.9	19.4	20.3	20.8	21.1	22.0	21.6	22.5	22.9
	6H	19.7	20.5	20.2	21.0	21.4	22.5	23.2	22.9	23.7	24.2
	8H	20.0	20.7	20.5	21.2	21.6	22.9	23.6	23.4	24.1	24.6
	12H	20.2	20.8	20.7	21.3	21.8	23.2	23.8	23.7	24.3	24.9
12H	4H	19.1	19.9	19.6	20.4	20.9	21.2	22.0	21.6	22.5	22.9
	6H	19.9	20.6	20.5	21.1	21.6	22.5	23.2	23.0	23.6	24.2
	8H	20.3	20.9	20.8	21.4	21.9	23.0	23.6	23.5	24.1	24.7

Maximum UGR = 24.9

POLAR GRAPH



Maximum Candela = 992.337 Located At Horizontal Angle = 90, Vertical Angle = .5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)