



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFR G2 24 HI UV FA 940.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-007A (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 2/17/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFR G2 24 HI UV FA 940

[LUMINAIRE] Retrofit kit installed in an A.L.P. EL-2x4-23-2 2x4 housing,

[MORE] formed white painted steel reflectors, frosted linear ribbed plastic enclosure.

[LAMP] 96 white LEDs, two LS3873A7\_4000\_90R 4000K 48 LED boards

[BALLAST] One ULT D15CC55UNVPW-C LED driver programmed at 950mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	6917
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	140
Total Luminaire Watts	49.3
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.75 ft
Luminous Width (90-270)	1.75 ft
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	3284	3575	3859
55	3017	3488	3956
65	2702	3463	4196
75	2268	3554	4692
85	1530	3119	3236

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFR G2 24 HI UV FA 940.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	871.70	N.A.	12.60
0-30	1839.79	N.A.	26.60
0-40	2993.65	N.A.	43.30
0-60	5277.23	N.A.	76.30
0-80	6746.37	N.A.	97.50
0-90	6917.46	N.A.	100.00
10-90	6690.98	N.A.	96.70
20-40	2121.95	N.A.	30.70
20-50	3312.82	N.A.	47.90
40-70	3166.95	N.A.	45.80
60-80	1469.14	N.A.	21.20
70-80	585.77	N.A.	8.50
80-90	171.09	N.A.	2.50
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	6917.46	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	226.48
10-20	645.22
20-30	968.09
30-40	1153.86
40-50	1190.86
50-60	1092.71
60-70	883.37
70-80	585.77
80-90	171.09
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFR G2 24 HI UV FA 940.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	89	82	76	95	88	81	75	84	78	74	81	76	72	78	74	70	68
3	89	78	70	63	87	77	69	63	74	67	61	71	65	60	68	63	59	57
4	82	69	60	53	79	68	59	53	65	58	52	63	57	51	61	55	51	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	45	55	49	44	42
6	69	56	46	40	67	55	46	40	53	45	39	51	44	39	49	43	39	37
7	64	50	41	35	62	50	41	35	48	40	35	47	40	35	45	39	34	32
8	60	46	37	31	58	45	37	31	44	36	31	43	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	36	30	25	23


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFR G2 24 HI UV FA 940.IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	15.6	17.2	15.9	17.6	17.9	17.2	18.9	17.6	19.2	19.5
	3H	17.3	18.8	17.7	19.1	19.5	19.6	21.1	20.0	21.4	21.8
	4H	17.9	19.4	18.3	19.7	20.1	20.6	22.1	21.0	22.4	22.8
	6H	18.4	19.7	18.8	20.1	20.5	21.6	22.9	22.0	23.3	23.6
	8H	18.5	19.8	18.9	20.2	20.6	21.9	23.1	22.3	23.5	23.9
	12H	18.6	19.8	19.0	20.2	20.6	22.0	23.2	22.4	23.6	24.0
4H	2H	16.5	17.9	16.9	18.3	18.6	17.8	19.2	18.2	19.5	19.9
	3H	18.5	19.7	18.9	20.1	20.5	20.4	21.6	20.8	22.0	22.4
	4H	19.2	20.3	19.7	20.7	21.2	21.6	22.7	22.1	23.1	23.6
	6H	19.8	20.8	20.3	21.2	21.7	22.7	23.7	23.2	24.1	24.6
	8H	20.0	20.9	20.5	21.3	21.8	23.1	24.0	23.6	24.4	24.9
	12H	20.1	20.9	20.6	21.4	21.9	23.3	24.1	23.8	24.6	25.1
8H	4H	19.9	20.8	20.4	21.2	21.7	21.9	22.8	22.4	23.3	23.7
	6H	20.7	21.4	21.1	21.9	22.4	23.2	24.0	23.7	24.5	24.9
	8H	20.9	21.6	21.4	22.1	22.6	23.7	24.3	24.2	24.9	25.3
	12H	21.1	21.7	21.6	22.2	22.8	24.0	24.6	24.5	25.1	25.6
12H	4H	20.0	20.8	20.5	21.3	21.8	22.0	22.8	22.4	23.3	23.7
	6H	20.9	21.6	21.4	22.0	22.5	23.3	24.0	23.8	24.4	25.0
	8H	21.2	21.8	21.7	22.3	22.9	23.8	24.4	24.3	24.9	25.4

Maximum UGR = 25.6

POLAR GRAPH



Maximum Candela = 2399.38 Located At Horizontal Angle = 90, Vertical Angle = 1.5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (1.5) (Through Max. Cd.)