



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 2 LW UV 950.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-011A(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/2/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] ECL G2 2 LW UV 950

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] no enclosure.

[LAMP] 28 white LEDs on one LS3872A LED board

[BALLAST] One ULT D700C20UNVPW-C LED driver labeled as 160mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1142
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	134
Total Luminaire Watts	8.5
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.30
Spacing Criterion (90-270)	1.32
Spacing Criterion (Diagonal)	1.42
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	1.99 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.02 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	5423	5250	5234
55	5313	5078	4975
65	4991	4610	4487
75	4214	3608	3527
85	2321	1602	1503

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 2 LW UV 950.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	139.72	N.A.	12.20
0-30	299.14	N.A.	26.20
0-40	495.14	N.A.	43.40
0-60	895.31	N.A.	78.40
0-80	1123.17	N.A.	98.40
0-90	1141.8	N.A.	100.00
10-90	1105.83	N.A.	96.80
20-40	355.43	N.A.	31.10
20-50	563.61	N.A.	49.40
40-70	547.05	N.A.	47.90
60-80	227.86	N.A.	20.00
70-80	80.97	N.A.	7.10
80-90	18.63	N.A.	1.60
90-110	0.11	N.A.	0.00
90-120	0.11	N.A.	0.00
90-130	0.11	N.A.	0.00
90-150	0.11	N.A.	0.00
90-180	0.11	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	1141.91	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	35.97
10-20	103.75
20-30	159.43
30-40	196.00
40-50	208.18
50-60	191.98
60-70	146.89
70-80	80.97
80-90	18.63
90-100	0.11
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 2 LW UV 950.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	93	91	88	90	88	86	84
2	99	90	83	78	96	88	82	77	85	79	75	81	77	73	78	75	71	69
3	90	79	71	64	87	77	70	64	74	68	62	72	66	61	69	64	60	58
4	82	70	61	54	80	68	60	54	66	59	53	64	57	52	61	56	51	49
5	75	62	53	46	73	61	53	46	59	51	46	57	50	45	55	49	45	42
6	69	56	47	40	67	55	46	40	53	45	40	51	45	39	50	44	39	37
7	64	51	42	35	63	50	41	35	48	41	35	47	40	35	45	39	35	33
8	60	46	37	32	58	45	37	31	44	37	31	43	36	31	42	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	36	30	25	23

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 2 LW UV 950.IES**

**UGR TABLE - CORRECTED**

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise


X=2H	Y=2H	17.9	19.6	18.3	19.9	20.2	18.0	19.7	18.4	20.0	20.3
	3H	19.7	21.2	20.1	21.5	21.9	19.8	21.3	20.2	21.6	22.0
	4H	20.3	21.7	20.7	22.1	22.4	20.4	21.9	20.8	22.2	22.6
	6H	20.7	22.0	21.1	22.4	22.8	20.8	22.1	21.2	22.5	22.9
	8H	20.8	22.0	21.2	22.4	22.8	20.9	22.2	21.4	22.6	23.0
	12H	20.8	22.0	21.2	22.4	22.8	21.0	22.2	21.4	22.6	23.0

UGR Viewed Endwise

4H	2H	18.6	20.0	19.0	20.3	20.7	18.7	20.1	19.1	20.4	20.8
	3H	20.5	21.7	20.9	22.1	22.5	20.6	21.8	21.0	22.2	22.6
	4H	21.3	22.3	21.7	22.7	23.2	21.3	22.4	21.8	22.8	23.3
	6H	21.8	22.7	22.2	23.1	23.6	21.9	22.8	22.3	23.2	23.7
	8H	21.9	22.7	22.3	23.2	23.7	22.0	22.9	22.4	23.3	23.8
	12H	21.9	22.7	22.4	23.2	23.7	22.1	22.8	22.5	23.3	23.8
8H	4H	21.5	22.4	22.0	22.8	23.3	21.6	22.5	22.1	22.9	23.4
	6H	22.1	22.8	22.6	23.3	23.8	22.2	22.9	22.7	23.4	23.9
	8H	22.2	22.9	22.8	23.4	23.9	22.4	23.0	22.9	23.5	24.0
	12H	22.4	22.9	22.9	23.4	24.0	22.5	23.1	23.0	23.6	24.1
12H	4H	21.5	22.3	22.0	22.8	23.3	21.6	22.4	22.1	22.9	23.3
	6H	22.1	22.8	22.6	23.2	23.8	22.2	22.9	22.7	23.3	23.9
	8H	22.3	22.9	22.8	23.4	23.9	22.4	23.0	22.9	23.5	24.1

Maximum UGR = 24.1

POLAR GRAPH



Maximum Candela = 380.081 Located At Horizontal Angle = 90, Vertical Angle = 2  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (2) (Through Max. Cd.)