



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 2 VH UV 950.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-011A(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/2/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] ECL G2 2 VH UV 950

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] no enclosure.

[LAMP] 64 white LEDs on one LS3872A LED board

[BALLAST] One ULT D10CC30UNVPW-C LED driver labeled as 550mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4408
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	151
Total Luminaire Watts	29.1
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.30
Spacing Criterion (90-270)	1.32
Spacing Criterion (Diagonal)	1.42
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	1.99 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.02 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	20933	20265	20202
55	20510	19602	19203
65	19264	17795	17320
75	16266	13927	13616
85	8960	6185	5800

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 2 VH UV 950.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	539.30	N.A.	12.20
0-30	1154.68	N.A.	26.20
0-40	1911.24	N.A.	43.40
0-60	3455.85	N.A.	78.40
0-80	4335.39	N.A.	98.40
0-90	4407.31	N.A.	100.00
10-90	4268.47	N.A.	96.80
20-40	1371.94	N.A.	31.10
20-50	2175.52	N.A.	49.40
40-70	2111.6	N.A.	47.90
60-80	879.54	N.A.	20.00
70-80	312.55	N.A.	7.10
80-90	71.92	N.A.	1.60
90-110	0.41	N.A.	0.00
90-120	0.41	N.A.	0.00
90-130	0.41	N.A.	0.00
90-150	0.41	N.A.	0.00
90-180	0.41	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	4407.72	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	138.84
10-20	400.45
20-30	615.38
30-40	756.56
40-50	803.57
50-60	741.04
60-70	566.99
70-80	312.55
80-90	71.92
90-100	0.41
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 2 VH UV 950.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	93	91	88	90	88	86	84
2	99	90	83	78	96	88	82	77	85	79	75	81	77	73	78	75	71	69
3	90	79	71	64	87	77	70	64	74	68	62	72	66	61	69	64	60	58
4	82	70	61	54	80	68	60	54	66	59	53	64	57	52	61	56	51	49
5	75	62	53	46	73	61	53	46	59	51	46	57	50	45	55	49	45	42
6	69	56	47	40	67	55	46	40	53	45	40	51	45	39	50	44	39	37
7	64	51	42	35	63	50	41	35	48	41	35	47	40	35	45	39	35	33
8	60	46	37	32	58	45	37	31	44	37	31	43	36	31	42	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	36	30	25	23


IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 2 VH UV 950.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	22.6	24.3	23.0	24.6	24.9	22.7	24.4	23.1	24.7	25.0
	3H	24.4	25.9	24.8	26.2	26.6	24.5	26.0	24.9	26.3	26.7
	4H	25.0	26.4	25.4	26.8	27.1	25.1	26.5	25.5	26.9	27.3
	6H	25.4	26.7	25.8	27.1	27.5	25.5	26.8	25.9	27.2	27.6
	8H	25.5	26.7	25.9	27.1	27.5	25.6	26.9	26.1	27.3	27.7
	12H	25.5	26.7	25.9	27.1	27.5	25.7	26.9	26.1	27.3	27.7
4H	2H	23.3	24.7	23.7	25.0	25.4	23.4	24.8	23.7	25.1	25.5
	3H	25.2	26.4	25.6	26.8	27.2	25.3	26.5	25.7	26.9	27.3
	4H	26.0	27.0	26.4	27.4	27.9	26.0	27.1	26.5	27.5	28.0
	6H	26.4	27.4	26.9	27.8	28.3	26.5	27.5	27.0	27.9	28.4
	8H	26.6	27.4	27.0	27.9	28.3	26.7	27.6	27.1	28.0	28.5
	12H	26.6	27.4	27.1	27.9	28.4	26.8	27.5	27.2	28.0	28.5
8H	4H	26.2	27.1	26.7	27.5	28.0	26.3	27.2	26.8	27.6	28.1
	6H	26.8	27.5	27.3	28.0	28.5	26.9	27.6	27.4	28.1	28.6
	8H	26.9	27.6	27.5	28.1	28.6	27.1	27.7	27.6	28.2	28.7
	12H	27.1	27.6	27.6	28.1	28.7	27.2	27.8	27.7	28.3	28.8
12H	4H	26.2	27.0	26.7	27.5	28.0	26.3	27.1	26.8	27.6	28.0
	6H	26.8	27.5	27.3	27.9	28.5	26.9	27.6	27.4	28.0	28.6
	8H	27.0	27.6	27.5	28.1	28.6	27.1	27.7	27.6	28.2	28.8

Maximum UGR = 28.8

POLAR GRAPH



Maximum Candela = 1467.102 Located At Horizontal Angle = 90, Vertical Angle = 2
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (2) (Through Max. Cd.)