



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 2 ML UV 950.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-011A(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/2/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] ECL G2 2 ML UV 950

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] no enclosure.

[LAMP] 28 white LEDs on one LS3872A LED board

[BALLAST] One ULT D700C20UNVPW-C LED driver labeled as 240mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1697
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	140
Total Luminaire Watts	12.1
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.30
Spacing Criterion (90-270)	1.32
Spacing Criterion (Diagonal)	1.42
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	1.99 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.02 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	8061	7804	7779
55	7898	7548	7394
65	7418	6852	6669
75	6264	5363	5243
85	3450	2382	2234

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 2 ML UV 950.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	207.67	N.A.	12.20
0-30	444.64	N.A.	26.20
0-40	735.97	N.A.	43.40
0-60	1330.77	N.A.	78.40
0-80	1669.46	N.A.	98.40
0-90	1697.15	N.A.	100.00
10-90	1643.69	N.A.	96.80
20-40	528.30	N.A.	31.10
20-50	837.74	N.A.	49.40
40-70	813.13	N.A.	47.90
60-80	338.69	N.A.	20.00
70-80	120.36	N.A.	7.10
80-90	27.69	N.A.	1.60
90-110	0.16	N.A.	0.00
90-120	0.16	N.A.	0.00
90-130	0.16	N.A.	0.00
90-150	0.16	N.A.	0.00
90-180	0.16	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	1697.31	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	53.46
10-20	154.21
20-30	236.97
30-40	291.33
40-50	309.44
50-60	285.36
60-70	218.33
70-80	120.36
80-90	27.69
90-100	0.16
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 2 ML UV 950.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	93	91	88	90	88	86	84
2	99	90	83	78	96	88	82	77	85	79	75	82	77	73	78	75	71	69
3	90	79	71	64	87	77	70	64	74	68	62	72	66	61	69	64	60	58
4	82	70	61	54	80	68	60	54	66	59	53	64	57	52	61	56	51	49
5	75	62	53	46	73	61	53	46	59	51	46	57	50	45	55	49	45	42
6	69	56	47	40	68	55	46	40	53	45	40	51	45	39	50	44	39	37
7	64	51	42	36	63	50	41	35	48	41	35	47	40	35	45	39	35	33
8	60	46	37	32	58	45	37	31	44	37	31	43	36	31	42	35	31	29
9	56	42	34	28	54	42	34	28	41	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	36	30	25	23


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 2 ML UV 950.IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	19.2	20.9	19.6	21.2	21.5	19.3	21.0	19.7	21.3	21.6
	3H	21.0	22.5	21.4	22.8	23.2	21.1	22.6	21.5	22.9	23.3
	4H	21.6	23.0	22.0	23.4	23.7	21.7	23.2	22.1	23.5	23.9
	6H	22.0	23.3	22.4	23.7	24.1	22.1	23.4	22.5	23.8	24.2
	8H	22.1	23.3	22.5	23.7	24.1	22.2	23.5	22.7	23.9	24.3
	12H	22.1	23.3	22.5	23.7	24.1	22.3	23.5	22.7	23.9	24.3
4H	2H	19.9	21.3	20.3	21.6	22.0	20.0	21.4	20.4	21.7	22.1
	3H	21.8	23.0	22.2	23.4	23.8	21.9	23.1	22.3	23.5	23.9
	4H	22.6	23.6	23.0	24.0	24.5	22.6	23.7	23.1	24.1	24.6
	6H	23.1	24.0	23.5	24.4	24.9	23.2	24.1	23.6	24.5	25.0
	8H	23.2	24.0	23.6	24.5	25.0	23.3	24.2	23.7	24.6	25.1
	12H	23.2	24.0	23.7	24.5	25.0	23.4	24.1	23.8	24.6	25.1
8H	4H	22.8	23.7	23.3	24.1	24.6	22.9	23.8	23.4	24.2	24.7
	6H	23.4	24.1	23.9	24.6	25.1	23.5	24.2	24.0	24.7	25.2
	8H	23.5	24.2	24.1	24.7	25.2	23.7	24.3	24.2	24.8	25.3
	12H	23.7	24.2	24.2	24.7	25.3	23.8	24.4	24.3	24.9	25.4
12H	4H	22.8	23.6	23.3	24.1	24.6	22.9	23.7	23.4	24.2	24.6
	6H	23.4	24.1	23.9	24.5	25.1	23.5	24.2	24.0	24.6	25.2
	8H	23.6	24.2	24.1	24.7	25.2	23.7	24.3	24.2	24.8	25.4

Maximum UGR = 25.4

POLAR GRAPH



Maximum Candela = 564.946 Located At Horizontal Angle = 90, Vertical Angle = 2  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (2) (Through Max. Cd.)