



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 4 LW UV FR 940.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-018(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/1/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] ECL G2 4 LW UV FR 940

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMP] 56 white LEDs on two LS3872A LED boards

[BALLAST] One ULT D700C20UNVPW-C LED driver labeled as 320mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	2185
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	142
Total Luminaire Watts	15.4
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	4.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.06 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	4602	4430	4426
55	4011	4020	4065
65	3224	3515	3588
75	2340	3004	3038
85	1342	2796	2665

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 4 LW UV FR 940.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	271.60	N.A.	12.40
0-30	577.58	N.A.	26.40
0-40	945.72	N.A.	43.30
0-60	1657.78	N.A.	75.90
0-80	2066.52	N.A.	94.60
0-90	2145.52	N.A.	98.20
10-90	2075.38	N.A.	95.00
20-40	674.12	N.A.	30.90
20-50	1051.87	N.A.	48.20
40-70	963.76	N.A.	44.10
60-80	408.74	N.A.	18.70
70-80	157.05	N.A.	7.20
80-90	78.99	N.A.	3.60
90-110	38.94	N.A.	1.80
90-120	39.02	N.A.	1.80
90-130	39.02	N.A.	1.80
90-150	39.02	N.A.	1.80
90-180	39.02	N.A.	1.80
110-180	0.08	N.A.	0.00
0-180	2184.53	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	70.13
10-20	201.46
20-30	305.98
30-40	368.14
40-50	377.74
50-60	334.32
60-70	251.69
70-80	157.05
80-90	78.99
90-100	31.66
100-110	7.27
110-120	0.08
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 4 LW UV FR 940.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	108	103	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83	81
2	98	89	82	76	95	87	81	75	83	78	73	80	75	71	76	73	69	67
3	89	78	70	63	86	77	69	63	73	67	61	70	65	60	67	63	59	56
4	82	69	60	54	79	68	60	53	65	58	52	63	56	51	60	55	50	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	44	54	48	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	49	43	38	36
7	64	51	42	36	62	50	41	35	48	40	35	46	40	35	45	39	34	32
8	60	46	38	32	58	45	37	31	44	36	31	42	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 4 LW UV FR 940.IES**

**UGR TABLE - CORRECTED**


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	15.7	17.3	16.1	17.7	18.0	17.4	19.0	17.8	19.3	19.7
	3H	17.0	18.5	17.4	18.8	19.2	19.4	20.8	19.8	21.2	21.6
	4H	17.4	18.8	17.8	19.2	19.6	20.2	21.6	20.6	22.0	22.4
	6H	17.6	18.9	18.1	19.3	19.7	21.0	22.3	21.4	22.7	23.1
	8H	17.7	18.9	18.1	19.3	19.8	21.4	22.6	21.8	23.0	23.5
	12H	17.7	18.9	18.2	19.3	19.8	21.8	22.9	22.2	23.3	23.8
4H	2H	16.5	17.9	17.0	18.3	18.7	17.8	19.2	18.3	19.6	20.0
	3H	18.1	19.2	18.5	19.7	20.1	20.1	21.2	20.5	21.7	22.1
	4H	18.6	19.7	19.1	20.1	20.6	21.1	22.1	21.5	22.6	23.1
	6H	18.9	19.9	19.4	20.4	20.9	22.0	23.0	22.5	23.4	23.9
	8H	19.0	19.9	19.5	20.4	20.9	22.5	23.4	23.0	23.8	24.3
	12H	19.1	19.9	19.6	20.4	20.9	23.0	23.8	23.5	24.3	24.8
8H	4H	19.2	20.0	19.6	20.5	21.0	21.3	22.2	21.8	22.6	23.2
	6H	19.7	20.4	20.2	20.9	21.5	22.4	23.2	22.9	23.7	24.2
	8H	19.9	20.5	20.4	21.0	21.6	23.0	23.7	23.6	24.2	24.7
	12H	20.0	20.5	20.5	21.1	21.7	23.6	24.2	24.2	24.8	25.4
12H	4H	19.3	20.1	19.8	20.6	21.1	21.3	22.1	21.8	22.6	23.1
	6H	19.9	20.6	20.5	21.1	21.6	22.5	23.1	23.0	23.6	24.2
	8H	20.1	20.7	20.7	21.3	21.9	23.1	23.7	23.6	24.2	24.8

Maximum UGR = 25.4

POLAR GRAPH



Maximum Candela = 742.346 Located At Horizontal Angle = 90, Vertical Angle = 3.5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (3.5) (Through Max. Cd.)