



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 6 MH UV 935.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-016(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/1/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] ECL G2 6 MH UV 935

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] no enclosure.

[LAMP] 144 white LEDs on three LS3872A LED boards

[BALLAST] One ULT D15CC55UNVPW-C LED driver labeled as 1020mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	8117
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	157
Total Luminaire Watts	51.6
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.30
Spacing Criterion (90-270)	1.32
Spacing Criterion (Diagonal)	1.42
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	6.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.02 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	12885	12446	12352
55	12675	12080	11727
65	11993	11000	10573
75	10245	8643	8059
85	5827	3902	3475

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 6 MH UV 935.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	992.71	N.A.	12.20
0-30	2125.9	N.A.	26.20
0-40	3519.66	N.A.	43.40
0-60	6368.03	N.A.	78.50
0-80	7985.81	N.A.	98.40
0-90	8116.22	N.A.	100.00
10-90	7860.66	N.A.	96.80
20-40	2526.95	N.A.	31.10
20-50	4008.33	N.A.	49.40
40-70	3894.31	N.A.	48.00
60-80	1617.78	N.A.	19.90
70-80	571.84	N.A.	7.00
80-90	130.41	N.A.	1.60
90-110	0.71	N.A.	0.00
90-120	0.71	N.A.	0.00
90-130	0.71	N.A.	0.00
90-150	0.71	N.A.	0.00
90-180	0.71	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	8116.93	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	255.56
10-20	737.15
20-30	1133.18
30-40	1393.76
40-50	1481.39
50-60	1366.99
60-70	1045.94
70-80	571.84
80-90	130.41
90-100	0.71
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 6 MH UV 935.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	93	91	88	90	88	86	84
2	99	90	83	78	96	88	82	77	85	79	75	82	77	73	78	75	71	69
3	90	79	71	64	87	77	70	64	74	68	62	72	66	61	69	64	60	58
4	82	70	61	54	80	68	60	54	66	59	53	64	57	52	61	56	52	49
5	75	62	53	46	73	61	53	46	59	51	46	57	50	45	55	49	45	42
6	69	56	47	40	68	55	46	40	53	45	40	51	45	39	50	44	39	37
7	64	51	42	36	63	50	41	35	48	41	35	47	40	35	45	39	35	33
8	60	46	37	32	58	45	37	31	44	37	31	43	36	31	42	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	36	30	25	23

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 6 MH UV 935.IES**

**UGR TABLE - CORRECTED**


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	20.9	22.6	21.3	22.9	23.2	21.0	22.7	21.4	23.0	23.3
	3H	22.7	24.2	23.1	24.5	24.9	22.8	24.3	23.2	24.7	25.0
	4H	23.3	24.7	23.7	25.1	25.4	23.4	24.8	23.8	25.2	25.6
	6H	23.7	25.0	24.1	25.4	25.8	23.8	25.1	24.2	25.5	25.9
	8H	23.8	25.0	24.2	25.4	25.8	23.9	25.2	24.3	25.6	26.0
	12H	23.8	25.0	24.2	25.4	25.8	24.0	25.2	24.4	25.5	26.0
4H	2H	21.6	23.0	22.0	23.3	23.7	21.7	23.1	22.1	23.4	23.8
	3H	23.5	24.7	23.9	25.1	25.5	23.6	24.8	24.0	25.2	25.6
	4H	24.3	25.3	24.7	25.7	26.2	24.3	25.4	24.7	25.8	26.2
	6H	24.8	25.7	25.2	26.1	26.6	24.8	25.8	25.3	26.2	26.6
	8H	24.9	25.7	25.3	26.2	26.7	25.0	25.8	25.4	26.3	26.7
	12H	24.9	25.7	25.4	26.2	26.7	25.0	25.8	25.5	26.3	26.8
8H	4H	24.5	25.4	25.0	25.8	26.3	24.6	25.5	25.0	25.9	26.4
	6H	25.1	25.8	25.6	26.3	26.8	25.2	25.9	25.6	26.4	26.8
	8H	25.2	25.9	25.8	26.4	26.9	25.3	26.0	25.8	26.5	27.0
	12H	25.3	25.9	25.9	26.4	27.0	25.4	26.0	26.0	26.5	27.1
12H	4H	24.5	25.3	25.0	25.8	26.3	24.6	25.4	25.1	25.9	26.3
	6H	25.1	25.8	25.6	26.2	26.8	25.2	25.8	25.7	26.3	26.8
	8H	25.3	25.9	25.8	26.4	26.9	25.4	26.0	25.9	26.5	27.0

Maximum UGR = 27.1

POLAR GRAPH



Maximum Candela = 2700.345 Located At Horizontal Angle = 90, Vertical Angle = 2.5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (2.5) (Through Max. Cd.)