



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 6 MD UV 950.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-016(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/1/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] ECL G2 6 MD UV 950

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] no enclosure.

[LAMP] 84 white LEDs on three LS3872A LED boards

[BALLAST] One ULT D15CC55UNVPW-C LED driver labeled as 960mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	6663
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	152
Total Luminaire Watts	43.9
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.30
Spacing Criterion (90-270)	1.32
Spacing Criterion (Diagonal)	1.42
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	6.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.02 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	10577	10217	10140
55	10405	9916	9627
65	9845	9030	8680
75	8410	7095	6616
85	4783	3203	2852

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 6 MD UV 950.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	814.92	N.A.	12.20
0-30	1745.15	N.A.	26.20
0-40	2889.3	N.A.	43.40
0-60	5227.53	N.A.	78.50
0-80	6555.58	N.A.	98.40
0-90	6662.63	N.A.	100.00
10-90	6452.84	N.A.	96.80
20-40	2074.38	N.A.	31.10
20-50	3290.45	N.A.	49.40
40-70	3196.85	N.A.	48.00
60-80	1328.04	N.A.	19.90
70-80	469.42	N.A.	7.00
80-90	107.06	N.A.	1.60
90-110	0.58	N.A.	0.00
90-120	0.58	N.A.	0.00
90-130	0.58	N.A.	0.00
90-150	0.58	N.A.	0.00
90-180	0.58	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	6663.21	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	209.79
10-20	605.13
20-30	930.23
30-40	1144.14
40-50	1216.07
50-60	1122.16
60-70	858.62
70-80	469.42
80-90	107.06
90-100	0.58
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 6 MD UV 950.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	93	91	88	90	88	86	84
2	99	90	83	78	96	88	82	77	85	79	75	82	77	73	78	75	71	69
3	90	79	71	64	87	77	70	64	74	68	62	72	66	61	69	64	60	58
4	82	70	61	54	80	68	60	54	66	59	53	64	57	52	61	56	52	49
5	75	62	53	46	73	61	53	46	59	51	46	57	50	45	55	49	45	42
6	69	56	47	40	68	55	46	40	53	45	40	51	45	39	50	44	39	37
7	64	51	42	36	63	50	41	35	48	41	35	47	40	35	45	39	35	33
8	60	46	37	32	58	45	37	31	44	37	31	43	36	31	42	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	36	30	25	23

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 6 MD UV 950.IES

UGR TABLE - CORRECTED


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	20.2	21.9	20.6	22.2	22.5	20.3	22.0	20.7	22.3	22.6
	3H	22.0	23.5	22.4	23.8	24.2	22.1	23.6	22.5	24.0	24.3
	4H	22.6	24.0	23.0	24.4	24.7	22.7	24.1	23.1	24.5	24.9
	6H	23.0	24.3	23.4	24.7	25.1	23.1	24.4	23.5	24.8	25.2
	8H	23.1	24.3	23.5	24.7	25.1	23.2	24.5	23.6	24.9	25.3
	12H	23.1	24.3	23.5	24.7	25.1	23.3	24.5	23.7	24.8	25.3
4H	2H	20.9	22.3	21.3	22.6	23.0	21.0	22.4	21.4	22.7	23.1
	3H	22.8	24.0	23.2	24.4	24.8	22.9	24.1	23.3	24.5	24.9
	4H	23.6	24.6	24.0	25.0	25.5	23.6	24.7	24.0	25.1	25.5
	6H	24.1	25.0	24.5	25.4	25.9	24.1	25.1	24.6	25.5	25.9
	8H	24.2	25.0	24.6	25.5	26.0	24.3	25.1	24.7	25.6	26.0
	12H	24.2	25.0	24.7	25.5	26.0	24.3	25.1	24.8	25.6	26.1
8H	4H	23.8	24.7	24.3	25.1	25.6	23.9	24.8	24.3	25.2	25.7
	6H	24.4	25.1	24.9	25.6	26.1	24.5	25.2	24.9	25.7	26.1
	8H	24.5	25.2	25.1	25.7	26.2	24.6	25.3	25.1	25.8	26.3
	12H	24.6	25.2	25.2	25.7	26.3	24.7	25.3	25.3	25.8	26.4
12H	4H	23.8	24.6	24.3	25.1	25.6	23.9	24.7	24.4	25.2	25.6
	6H	24.4	25.1	24.9	25.5	26.1	24.5	25.1	25.0	25.6	26.1
	8H	24.6	25.2	25.1	25.7	26.2	24.7	25.3	25.2	25.8	26.3

Maximum UGR = 26.4

POLAR GRAPH



Maximum Candela = 2216.722 Located At Horizontal Angle = 90, Vertical Angle = 2.5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (2.5) (Through Max. Cd.)