



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 6 HI UV FR 930.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-018(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/1/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] ECL G2 6 HI UV FR 930

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMP] 144 white LEDs on three LS3872A LED boards

[BALLAST] One ULT D15CC55UNVPW-C LED driver labeled as 1220mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	9107
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	146
Total Luminaire Watts	62.2
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	6.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.06 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	12855	12353	12301
55	11230	11223	11298
65	9058	9831	9973
75	6625	8428	8443
85	3930	7905	7406

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 6 HI UV FR 930.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	1132.23	N.A.	12.40
0-30	2407.79	N.A.	26.40
0-40	3942.51	N.A.	43.30
0-60	6910.96	N.A.	75.90
0-80	8614.92	N.A.	94.60
0-90	8944.22	N.A.	98.20
10-90	8651.85	N.A.	95.00
20-40	2810.29	N.A.	30.90
20-50	4385.03	N.A.	48.20
40-70	4017.71	N.A.	44.10
60-80	1703.95	N.A.	18.70
70-80	654.70	N.A.	7.20
80-90	329.30	N.A.	3.60
90-110	162.33	N.A.	1.80
90-120	162.66	N.A.	1.80
90-130	162.66	N.A.	1.80
90-150	162.66	N.A.	1.80
90-180	162.66	N.A.	1.80
110-180	0.33	N.A.	0.00
0-180	9106.88	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	292.37
10-20	839.86
20-30	1275.57
30-40	1534.72
40-50	1574.74
50-60	1393.71
60-70	1049.26
70-80	654.70
80-90	329.30
90-100	132.00
100-110	30.33
110-120	0.33
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 6 HI UV FR 930.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	108	103	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83	81
2	98	89	82	76	95	87	81	75	83	78	73	80	75	71	76	73	69	67
3	89	78	70	63	86	77	69	63	73	67	61	70	65	60	67	63	59	56
4	82	69	60	54	79	68	60	53	65	58	52	63	56	51	60	55	50	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	44	54	48	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	49	43	38	36
7	64	51	42	36	62	50	41	35	48	40	35	46	40	35	45	39	34	32
8	60	46	38	32	58	45	37	32	44	36	31	42	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 6 HI UV FR 930.IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	19.3	20.9	19.7	21.3	21.6	21.0	22.6	21.4	23.0	23.3
	3H	20.6	22.1	21.0	22.4	22.8	23.0	24.4	23.4	24.8	25.2
	4H	21.0	22.4	21.4	22.8	23.2	23.8	25.2	24.3	25.6	26.0
	6H	21.2	22.5	21.7	22.9	23.3	24.6	25.9	25.1	26.3	26.8
	8H	21.3	22.5	21.7	22.9	23.4	25.0	26.2	25.5	26.7	27.1
	12H	21.3	22.5	21.8	22.9	23.4	25.4	26.6	25.9	27.0	27.5
4H	2H	20.1	21.5	20.6	21.9	22.3	21.5	22.8	21.9	23.2	23.7
	3H	21.7	22.8	22.1	23.3	23.7	23.7	24.8	24.1	25.3	25.7
	4H	22.2	23.3	22.7	23.7	24.2	24.7	25.7	25.2	26.2	26.7
	6H	22.6	23.5	23.0	24.0	24.5	25.7	26.6	26.1	27.1	27.6
	8H	22.6	23.5	23.1	24.0	24.5	26.1	27.0	26.6	27.5	28.0
	12H	22.7	23.5	23.2	24.0	24.5	26.6	27.4	27.1	27.9	28.4
8H	4H	22.8	23.6	23.3	24.1	24.6	24.9	25.8	25.4	26.3	26.8
	6H	23.3	24.0	23.8	24.5	25.1	26.1	26.8	26.6	27.3	27.8
	8H	23.5	24.1	24.0	24.7	25.2	26.7	27.3	27.2	27.8	28.4
	12H	23.6	24.2	24.1	24.7	25.3	27.3	27.9	27.8	28.4	29.0
12H	4H	22.9	23.7	23.4	24.2	24.7	24.9	25.7	25.4	26.2	26.7
	6H	23.5	24.2	24.1	24.7	25.2	26.1	26.8	26.7	27.3	27.9
	8H	23.7	24.3	24.3	24.9	25.5	26.8	27.3	27.3	27.9	28.5

Maximum UGR = 29.0

POLAR GRAPH



Maximum Candela = 3094.688 Located At Horizontal Angle = 90, Vertical Angle = 3.5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (3.5) (Through Max. Cd.)