



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 8 HI UV FR 930.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-018(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/1/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] ECL G2 8 HI UV FR 930

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMP] 192 white LEDs on four LS3872A LED boards

[BALLAST] One ULT D21CC80UNVPW-D LED driver labeled as 1680mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	12508
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	147
Total Luminaire Watts	85.1
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	8.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.06 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	13277	12746	12671
55	11610	11587	11638
65	9382	10159	10273
75	6889	8723	8697
85	4159	8214	7629

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 8 HI UV FR 930.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	1555.05	N.A.	12.40
0-30	3306.98	N.A.	26.40
0-40	5414.83	N.A.	43.30
0-60	9491.84	N.A.	75.90
0-80	11832.13	N.A.	94.60
0-90	12284.41	N.A.	98.20
10-90	11882.86	N.A.	95.00
20-40	3859.78	N.A.	30.90
20-50	6022.6	N.A.	48.20
40-70	5518.11	N.A.	44.10
60-80	2340.29	N.A.	18.70
70-80	899.19	N.A.	7.20
80-90	452.28	N.A.	3.60
90-110	222.95	N.A.	1.80
90-120	223.40	N.A.	1.80
90-130	223.40	N.A.	1.80
90-150	223.40	N.A.	1.80
90-180	223.40	N.A.	1.80
110-180	0.45	N.A.	0.00
0-180	12507.81	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	401.55
10-20	1153.5
20-30	1751.92
30-40	2107.85
40-50	2162.82
50-60	1914.19
60-70	1441.1
70-80	899.19
80-90	452.28
90-100	181.30
100-110	41.65
110-120	0.45
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 8 HI UV FR 930.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	108	103	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83	81
2	98	89	82	76	95	87	81	75	83	78	73	80	75	71	76	73	69	67
3	89	78	70	63	86	77	69	63	73	67	61	70	65	60	67	63	59	56
4	82	69	60	54	79	68	60	53	65	58	52	63	56	51	60	55	50	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	44	54	48	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	49	43	38	36
7	64	51	42	36	62	50	41	35	48	40	35	46	40	35	45	39	34	32
8	60	46	38	32	58	45	37	32	44	36	31	42	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23


IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 8 HI UV FR 930.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	19.4	21.0	19.8	21.4	21.7	21.1	22.7	21.5	23.1	23.4
	3H	20.7	22.2	21.1	22.5	22.9	23.1	24.6	23.5	24.9	25.3
	4H	21.1	22.5	21.5	22.9	23.3	23.9	25.3	24.4	25.7	26.1
	6H	21.3	22.6	21.8	23.0	23.5	24.7	26.0	25.2	26.4	26.9
	8H	21.4	22.6	21.8	23.0	23.5	25.1	26.4	25.6	26.8	27.2
	12H	21.4	22.6	21.9	23.0	23.5	25.5	26.7	26.0	27.1	27.6
4H	2H	20.2	21.6	20.7	22.0	22.4	21.6	23.0	22.0	23.3	23.8
	3H	21.8	23.0	22.2	23.4	23.8	23.8	25.0	24.2	25.4	25.8
	4H	22.3	23.4	22.8	23.8	24.3	24.8	25.9	25.3	26.3	26.8
	6H	22.7	23.6	23.1	24.1	24.6	25.8	26.7	26.3	27.2	27.7
	8H	22.7	23.6	23.2	24.1	24.6	26.2	27.1	26.7	27.6	28.1
	12H	22.8	23.6	23.3	24.1	24.6	26.8	27.5	27.3	28.1	28.6
8H	4H	22.9	23.7	23.4	24.2	24.7	25.0	25.9	25.5	26.4	26.9
	6H	23.4	24.1	23.9	24.6	25.2	26.2	26.9	26.7	27.4	28.0
	8H	23.6	24.2	24.1	24.8	25.3	26.8	27.4	27.3	28.0	28.5
	12H	23.7	24.3	24.2	24.8	25.4	27.4	28.0	28.0	28.5	29.1
12H	4H	23.0	23.8	23.5	24.3	24.8	25.0	25.8	25.6	26.4	26.9
	6H	23.6	24.3	24.2	24.8	25.4	26.3	26.9	26.8	27.4	28.0
	8H	23.9	24.4	24.4	25.0	25.6	26.9	27.5	27.4	28.0	28.6

Maximum UGR = 29.1

POLAR GRAPH



Maximum Candela = 4250.389 Located At Horizontal Angle = 90, Vertical Angle = 3.5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (3.5) (Through Max. Cd.)