



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 8 LW UV FR 950.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-018(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/1/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] ECL G2 8 LW UV FR 950

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMP] 112 white LEDs on four LS3872A LED boards

[BALLAST] One ULT D10CC30UNVPW-C LED driver labeled as 640mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4369
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	153
Total Luminaire Watts	28.5
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	8.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.06 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	4638	4453	4426
55	4056	4048	4065
65	3278	3549	3589
75	2407	3047	3038
85	1453	2869	2665

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 8 LW UV FR 950.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	543.24	N.A.	12.40
0-30	1155.26	N.A.	26.40
0-40	1891.61	N.A.	43.30
0-60	3315.87	N.A.	75.90
0-80	4133.43	N.A.	94.60
0-90	4291.43	N.A.	98.20
10-90	4151.15	N.A.	95.00
20-40	1348.37	N.A.	30.90
20-50	2103.93	N.A.	48.20
40-70	1927.69	N.A.	44.10
60-80	817.56	N.A.	18.70
70-80	314.12	N.A.	7.20
80-90	158.00	N.A.	3.60
90-110	77.89	N.A.	1.80
90-120	78.04	N.A.	1.80
90-130	78.04	N.A.	1.80
90-150	78.04	N.A.	1.80
90-180	78.04	N.A.	1.80
110-180	0.16	N.A.	0.00
0-180	4369.47	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	140.28
10-20	402.96
20-30	612.02
30-40	736.36
40-50	755.56
50-60	668.70
60-70	503.43
70-80	314.12
80-90	158.00
90-100	63.33
100-110	14.55
110-120	0.16
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 8 LW UV FR 950.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	108	103	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83	81
2	98	89	82	76	95	87	81	75	83	78	73	80	75	71	76	73	69	67
3	89	78	70	63	86	77	69	63	73	67	61	70	65	60	67	63	59	56
4	82	69	60	54	79	68	60	53	65	58	52	63	56	51	60	55	50	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	44	54	48	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	49	43	38	36
7	64	51	42	36	62	50	41	35	48	40	35	46	40	35	45	39	34	32
8	60	46	38	32	58	45	37	32	44	36	31	42	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	26	36	30	25	35	29	25	23

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 8 LW UV FR 950.IES

UGR TABLE - CORRECTED


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	15.7	17.3	16.1	17.7	18.0	17.4	19.0	17.8	19.4	19.7
	3H	17.0	18.5	17.4	18.8	19.2	19.4	20.9	19.8	21.2	21.6
	4H	17.4	18.8	17.8	19.2	19.6	20.2	21.6	20.7	22.0	22.4
	6H	17.6	18.9	18.1	19.3	19.8	21.0	22.3	21.5	22.7	23.2
	8H	17.7	18.9	18.1	19.3	19.8	21.4	22.7	21.9	23.1	23.5
	12H	17.7	18.9	18.2	19.3	19.8	21.8	23.0	22.3	23.4	23.9
4H	2H	16.5	17.9	17.0	18.3	18.7	17.9	19.3	18.3	19.6	20.1
	3H	18.1	19.3	18.5	19.7	20.1	20.1	21.3	20.5	21.7	22.1
	4H	18.6	19.7	19.1	20.1	20.6	21.1	22.2	21.6	22.6	23.1
	6H	19.0	19.9	19.4	20.4	20.9	22.1	23.0	22.6	23.5	24.0
	8H	19.0	19.9	19.5	20.4	20.9	22.5	23.4	23.0	23.9	24.4
	12H	19.1	19.9	19.6	20.4	20.9	23.1	23.8	23.6	24.4	24.9
8H	4H	19.2	20.0	19.7	20.5	21.0	21.3	22.2	21.8	22.7	23.2
	6H	19.7	20.4	20.2	20.9	21.5	22.5	23.2	23.0	23.7	24.3
	8H	19.9	20.5	20.4	21.1	21.6	23.1	23.7	23.6	24.3	24.8
	12H	20.0	20.6	20.5	21.1	21.7	23.7	24.3	24.3	24.8	25.4
12H	4H	19.3	20.1	19.8	20.6	21.1	21.3	22.1	21.9	22.7	23.2
	6H	19.9	20.6	20.5	21.1	21.7	22.6	23.2	23.1	23.7	24.3
	8H	20.2	20.7	20.7	21.3	21.9	23.2	23.8	23.7	24.3	24.9

Maximum UGR = 25.4

POLAR GRAPH



Maximum Candela = 1484.828 Located At Horizontal Angle = 90, Vertical Angle = 3.5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (3.5) (Through Max. Cd.)