



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 8 VH UV FR 930.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-018(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/1/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] ECL G2 8 VH UV FR 930

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMP] 256 white LEDs on four LS3872A LED boards

[BALLAST] Two ULT D15CC55UNVPW-C LED drivers labeled as 1100mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	16404
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	146
Total Luminaire Watts	112.6
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	8.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.06 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	17412	16716	16617
55	15227	15196	15262
65	12305	13323	13473
75	9035	11440	11406
85	5455	10772	10005

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 8 VH UV FR 930.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	2039.43	N.A.	12.40
0-30	4337.05	N.A.	26.40
0-40	7101.47	N.A.	43.30
0-60	12448.41	N.A.	75.90
0-80	15517.67	N.A.	94.60
0-90	16110.82	N.A.	98.20
10-90	15584.2	N.A.	95.00
20-40	5062.04	N.A.	30.90
20-50	7898.55	N.A.	48.20
40-70	7236.92	N.A.	44.10
60-80	3069.26	N.A.	18.70
70-80	1179.28	N.A.	7.20
80-90	593.16	N.A.	3.60
90-110	292.40	N.A.	1.80
90-120	292.99	N.A.	1.80
90-130	292.99	N.A.	1.80
90-150	292.99	N.A.	1.80
90-180	292.99	N.A.	1.80
110-180	0.59	N.A.	0.00
0-180	16403.81	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	526.63
10-20	1512.8
20-30	2297.62
30-40	2764.42
40-50	2836.51
50-60	2510.43
60-70	1889.98
70-80	1179.28
80-90	593.16
90-100	237.77
100-110	54.62
110-120	0.59
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 8 VH UV FR 930.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	108	103	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83	81
2	98	89	82	76	95	87	81	75	83	78	73	80	75	71	76	73	69	67
3	89	78	70	63	86	77	69	63	73	67	61	70	65	60	67	63	59	56
4	82	69	60	54	79	68	60	53	65	58	52	63	56	51	60	55	50	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	44	54	48	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	49	43	38	36
7	64	51	42	36	62	50	41	35	48	40	35	46	40	35	45	39	34	32
8	60	46	38	32	58	45	37	32	44	36	31	42	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23


IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 8 VH UV FR 930.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	20.3	21.9	20.7	22.3	22.6	22.0	23.6	22.4	24.0	24.3
	3H	21.6	23.1	22.0	23.4	23.8	24.0	25.5	24.4	25.8	26.2
	4H	22.0	23.4	22.4	23.8	24.2	24.8	26.2	25.3	26.6	27.0
	6H	22.2	23.5	22.7	23.9	24.4	25.6	26.9	26.1	27.3	27.8
	8H	22.3	23.5	22.7	23.9	24.4	26.0	27.3	26.5	27.7	28.1
	12H	22.3	23.5	22.8	23.9	24.4	26.4	27.6	26.9	28.0	28.5
4H	2H	21.1	22.5	21.6	22.9	23.3	22.5	23.9	22.9	24.2	24.7
	3H	22.7	23.9	23.1	24.3	24.7	24.7	25.9	25.1	26.3	26.7
	4H	23.2	24.3	23.7	24.7	25.2	25.7	26.8	26.2	27.2	27.7
	6H	23.6	24.5	24.0	25.0	25.5	26.7	27.6	27.2	28.1	28.6
	8H	23.6	24.5	24.1	25.0	25.5	27.1	28.0	27.6	28.5	29.0
	12H	23.7	24.5	24.2	25.0	25.5	27.7	28.4	28.2	29.0	29.5
8H	4H	23.8	24.6	24.3	25.1	25.6	25.9	26.8	26.4	27.3	27.8
	6H	24.3	25.0	24.8	25.5	26.1	27.1	27.8	27.6	28.3	28.9
	8H	24.5	25.1	25.0	25.7	26.2	27.7	28.3	28.2	28.9	29.4
	12H	24.6	25.2	25.1	25.7	26.3	28.3	28.9	28.9	29.4	30.0
12H	4H	23.9	24.7	24.4	25.2	25.7	25.9	26.7	26.5	27.3	27.8
	6H	24.5	25.2	25.1	25.7	26.3	27.2	27.8	27.7	28.3	28.9
	8H	24.8	25.3	25.3	25.9	26.5	27.8	28.4	28.3	28.9	29.5

Maximum UGR = 30.0

POLAR GRAPH



Maximum Candela = 5574.322 Located At Horizontal Angle = 90, Vertical Angle = 3.5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (3.5) (Through Max. Cd.)