



IES INDOOR REPORT

PHOTOMETRIC FILENAME : NVL G2 2 LW UV FRA 935.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001796-005(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 7/6/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] NVL G2 2 LW UV FRA 935

[LUMINAIRE] Surface/pendant mounted, formed white plastic housing, formed

[MORE] white painted steel LED tray/reflector, translucent linear stepped plastic

[MORE] lens.

[LAMP] 48 white LEDs on one LS3872A7-3500K-R90 LED board

[BALLAST] One ULT Everline D700C20UNVPW-C LED driver at 300mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

| | |
|---------------------------------|---------------------|
| Lumens Per Lamp | N.A. (absolute) |
| Total Lamp Lumens | N.A. (absolute) |
| Luminaire Lumens | 2144 |
| Total Luminaire Efficiency | N.A. |
| Luminaire Efficacy Rating (LER) | 141 |
| Total Luminaire Watts | 15.2 |
| Ballast Factor | 1.00 |
| CIE Type | Direct |
| Spacing Criterion (0-180) | 1.24 |
| Spacing Criterion (90-270) | 1.28 |
| Spacing Criterion (Diagonal) | 1.38 |
| Basic Luminous Shape | Rectangular w/Sides |
| Luminous Length (0-180) | 2.27 ft |
| Luminous Width (90-270) | 0.54 ft |
| Luminous Height | 0.16 ft |

LUMINANCE DATA (cd/sq.m)

| Angle In Degrees | Average 0-Deg | Average 45-Deg | Average 90-Deg |
|---------------------|------------------|-------------------|-------------------|
| 45 | 4935 | 4460 | 4340 |
| 55 | 4312 | 3855 | 4351 |
| 65 | 3566 | 3524 | 4092 |
| 75 | 2784 | 2916 | 3305 |
| 85 | 1894 | 2160 | 2381 |

IES INDOOR REPORT
PHOTOMETRIC FILENAME : NVL G2 2 LW UV FRA 935.IES

ZONAL LUMEN SUMMARY

| Zone | Lumens | %Lamp | %Fixt |
|---------|---------|-------|--------|
| 0-20 | 254.86 | N.A. | 11.90 |
| 0-30 | 542.51 | N.A. | 25.30 |
| 0-40 | 885.59 | N.A. | 41.30 |
| 0-60 | 1545.92 | N.A. | 72.10 |
| 0-80 | 1973.89 | N.A. | 92.10 |
| 0-90 | 2058.77 | N.A. | 96.00 |
| 10-90 | 1993.13 | N.A. | 93.00 |
| 20-40 | 630.73 | N.A. | 29.40 |
| 20-50 | 975.54 | N.A. | 45.50 |
| 40-70 | 918.11 | N.A. | 42.80 |
| 60-80 | 427.97 | N.A. | 20.00 |
| 70-80 | 170.18 | N.A. | 7.90 |
| 80-90 | 84.88 | N.A. | 4.00 |
| 90-110 | 63.75 | N.A. | 3.00 |
| 90-120 | 77.50 | N.A. | 3.60 |
| 90-130 | 83.47 | N.A. | 3.90 |
| 90-150 | 85.32 | N.A. | 4.00 |
| 90-180 | 85.40 | N.A. | 4.00 |
| 110-180 | 21.65 | N.A. | 1.00 |
| 0-180 | 2144.17 | N.A. | 100.00 |

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

| Zone | Lumens |
|---------|--------|
| 0-10 | 65.63 |
| 10-20 | 189.23 |
| 20-30 | 287.65 |
| 30-40 | 343.08 |
| 40-50 | 344.80 |
| 50-60 | 315.53 |
| 60-70 | 257.78 |
| 70-80 | 170.18 |
| 80-90 | 84.88 |
| 90-100 | 39.82 |
| 100-110 | 23.93 |
| 110-120 | 13.75 |
| 120-130 | 5.97 |
| 130-140 | 1.44 |
| 140-150 | 0.41 |
| 150-160 | 0.08 |
| 160-170 | 0.00 |
| 170-180 | 0.00 |

IES INDOOR REPORT
PHOTOMETRIC FILENAME : NVL G2 2 LW UV FRA 935.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

| RC | 80 | | | | 70 | | | | 50 | | | 30 | | | 10 | | | 0 |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|----|----|----|
| RW | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 0 |
| 0 | 118 | 118 | 118 | 118 | 115 | 115 | 115 | 115 | 109 | 109 | 109 | 103 | 103 | 103 | 98 | 98 | 98 | 96 |
| 1 | 107 | 102 | 97 | 93 | 104 | 99 | 95 | 91 | 94 | 90 | 87 | 89 | 86 | 84 | 85 | 83 | 81 | 78 |
| 2 | 97 | 88 | 81 | 75 | 94 | 86 | 79 | 74 | 82 | 76 | 71 | 78 | 73 | 69 | 74 | 70 | 67 | 64 |
| 3 | 88 | 77 | 69 | 62 | 85 | 75 | 67 | 61 | 72 | 65 | 59 | 68 | 63 | 58 | 65 | 60 | 56 | 54 |
| 4 | 81 | 68 | 59 | 52 | 78 | 67 | 58 | 52 | 64 | 56 | 50 | 61 | 54 | 49 | 58 | 53 | 48 | 46 |
| 5 | 74 | 61 | 52 | 45 | 72 | 59 | 51 | 44 | 57 | 49 | 44 | 54 | 48 | 43 | 52 | 47 | 42 | 40 |
| 6 | 68 | 55 | 46 | 39 | 66 | 54 | 45 | 39 | 51 | 44 | 38 | 49 | 43 | 37 | 47 | 41 | 37 | 35 |
| 7 | 63 | 50 | 41 | 35 | 61 | 49 | 40 | 34 | 47 | 39 | 34 | 45 | 38 | 33 | 43 | 37 | 33 | 31 |
| 8 | 59 | 45 | 37 | 31 | 57 | 44 | 36 | 31 | 43 | 35 | 30 | 41 | 35 | 30 | 40 | 34 | 29 | 27 |
| 9 | 55 | 42 | 33 | 28 | 53 | 41 | 33 | 27 | 39 | 32 | 27 | 38 | 31 | 27 | 37 | 31 | 26 | 25 |
| 10 | 52 | 38 | 30 | 25 | 50 | 38 | 30 | 25 | 36 | 29 | 25 | 35 | 29 | 24 | 34 | 28 | 24 | 22 |


IES INDOOR REPORT
PHOTOMETRIC FILENAME : NVL G2 2 LW UV FRA 935.IES

UGR TABLE - CORRECTED

| Reflectances | | | | | | | | | | | |
|----------------|------|----------------------|------|------|------|------|--------------------|------|------|------|------|
| Ceiling Cavity | | 70 | 70 | 50 | 50 | 30 | 70 | 70 | 50 | 50 | 30 |
| Walls | | 50 | 30 | 50 | 30 | 30 | 50 | 30 | 50 | 30 | 30 |
| Floor Cavity | | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 |
| Room Size | | UGR Viewed Crosswise | | | | | UGR Viewed Endwise | | | | |
| X=2H | Y=2H | 15.5 | 17.1 | 15.9 | 17.5 | 17.9 | 17.7 | 19.3 | 18.2 | 19.7 | 20.1 |
| | 3H | 16.9 | 18.3 | 17.3 | 18.7 | 19.2 | 20.0 | 21.4 | 20.4 | 21.8 | 22.3 |
| | 4H | 17.4 | 18.7 | 17.8 | 19.1 | 19.6 | 20.9 | 22.2 | 21.4 | 22.7 | 23.1 |
| | 6H | 17.7 | 18.9 | 18.2 | 19.4 | 19.9 | 21.7 | 22.9 | 22.2 | 23.4 | 23.9 |
| | 8H | 17.8 | 19.0 | 18.3 | 19.4 | 19.9 | 22.0 | 23.2 | 22.5 | 23.7 | 24.2 |
| | 12H | 17.8 | 19.0 | 18.3 | 19.4 | 20.0 | 22.3 | 23.5 | 22.8 | 24.0 | 24.5 |
| 4H | 2H | 16.4 | 17.7 | 16.8 | 18.2 | 18.6 | 18.1 | 19.5 | 18.6 | 19.9 | 20.4 |
| | 3H | 18.0 | 19.2 | 18.5 | 19.6 | 20.1 | 20.6 | 21.8 | 21.1 | 22.2 | 22.7 |
| | 4H | 18.6 | 19.6 | 19.1 | 20.1 | 20.6 | 21.7 | 22.7 | 22.2 | 23.2 | 23.7 |
| | 6H | 19.0 | 19.9 | 19.5 | 20.5 | 21.0 | 22.7 | 23.6 | 23.2 | 24.1 | 24.6 |
| | 8H | 19.1 | 20.0 | 19.7 | 20.5 | 21.1 | 23.1 | 23.9 | 23.6 | 24.4 | 25.0 |
| | 12H | 19.2 | 20.0 | 19.8 | 20.6 | 21.1 | 23.5 | 24.2 | 24.0 | 24.8 | 25.3 |
| 8H | 4H | 19.2 | 20.0 | 19.7 | 20.6 | 21.1 | 21.9 | 22.7 | 22.4 | 23.2 | 23.8 |
| | 6H | 19.8 | 20.5 | 20.3 | 21.0 | 21.6 | 23.0 | 23.7 | 23.5 | 24.3 | 24.8 |
| | 8H | 20.0 | 20.6 | 20.5 | 21.2 | 21.8 | 23.5 | 24.2 | 24.1 | 24.7 | 25.3 |
| | 12H | 20.1 | 20.7 | 20.7 | 21.2 | 21.9 | 24.0 | 24.6 | 24.6 | 25.2 | 25.8 |
| 12H | 4H | 19.3 | 20.1 | 19.8 | 20.6 | 21.2 | 21.9 | 22.7 | 22.4 | 23.2 | 23.8 |
| | 6H | 20.0 | 20.6 | 20.5 | 21.1 | 21.8 | 23.0 | 23.7 | 23.6 | 24.2 | 24.8 |
| | 8H | 20.2 | 20.8 | 20.8 | 21.4 | 22.0 | 23.6 | 24.2 | 24.2 | 24.7 | 25.4 |

Maximum UGR = 25.8

POLAR GRAPH



Maximum Candela = 697.054 Located At Horizontal Angle = 90, Vertical Angle = 5.5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (5.5) (Through Max. Cd.)