



IES INDOOR REPORT

PHOTOMETRIC FILENAME : NVL G2 2 VL UV FRA 930.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001796-005(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 7/6/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] NVL G2 2 VL UV FRA 930

[LUMINAIRE] Surface/pendant mounted, formed white plastic housing, formed

[MORE] white painted steel LED tray/reflector, translucent linear stepped plastic

[MORE] lens.

[LAMP] 28 white LEDs on one LS3872A6-3000K-R90 LED board

[BALLAST] One ULT Everline D700C20UNVPW-C LED driver at 180mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1123
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	122
Total Luminaire Watts	9.2
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.24
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	2.27 ft
Luminous Width (90-270)	0.54 ft
Luminous Height	0.16 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	2585	2336	2273
55	2258	2019	2279
65	1868	1846	2143
75	1458	1527	1731
85	992	1132	1247

IES INDOOR REPORT
PHOTOMETRIC FILENAME : NVL G2 2 VL UV FRA 930.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	133.49	N.A.	11.90
0-30	284.16	N.A.	25.30
0-40	463.86	N.A.	41.30
0-60	809.73	N.A.	72.10
0-80	1033.89	N.A.	92.10
0-90	1078.35	N.A.	96.00
10-90	1043.97	N.A.	93.00
20-40	330.37	N.A.	29.40
20-50	510.97	N.A.	45.50
40-70	480.89	N.A.	42.80
60-80	224.16	N.A.	20.00
70-80	89.14	N.A.	7.90
80-90	44.46	N.A.	4.00
90-110	33.39	N.A.	3.00
90-120	40.60	N.A.	3.60
90-130	43.72	N.A.	3.90
90-150	44.69	N.A.	4.00
90-180	44.73	N.A.	4.00
110-180	11.34	N.A.	1.00
0-180	1123.08	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	34.38
10-20	99.11
20-30	150.67
30-40	179.70
40-50	180.60
50-60	165.27
60-70	135.02
70-80	89.14
80-90	44.46
90-100	20.86
100-110	12.53
110-120	7.20
120-130	3.13
130-140	0.75
140-150	0.22
150-160	0.04
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : NVL G2 2 VL UV FRA 930.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	118	118	118	118	115	115	115	115	109	109	109	103	103	103	98	98	98	96
1	107	102	97	93	104	99	95	91	94	90	87	89	86	84	85	83	81	78
2	97	88	81	75	94	86	79	74	82	76	71	78	73	69	74	70	67	64
3	88	77	69	62	85	75	67	61	72	65	59	68	63	58	65	60	56	54
4	81	68	59	52	78	67	58	52	64	56	50	61	54	49	58	53	48	46
5	74	61	52	45	72	59	51	44	57	49	44	54	48	43	52	47	42	40
6	68	55	46	39	66	54	45	39	51	44	38	49	43	37	47	41	37	35
7	63	50	41	35	61	49	40	34	47	39	34	45	38	33	43	37	33	31
8	59	45	37	31	57	44	36	31	43	35	30	41	35	30	40	34	29	27
9	55	42	33	28	53	41	33	27	39	32	27	38	31	27	37	31	26	25
10	52	38	30	25	50	38	30	25	36	29	25	35	29	24	34	28	24	22

IES INDOOR REPORT
PHOTOMETRIC FILENAME : NVL G2 2 VL UV FRA 930.IES

UGR TABLE - CORRECTED


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	13.2	14.8	13.6	15.2	15.6	15.4	17.0	15.9	17.4	17.8
	3H	14.6	16.0	15.0	16.4	16.9	17.7	19.1	18.1	19.5	20.0
	4H	15.1	16.4	15.5	16.8	17.3	18.6	19.9	19.1	20.4	20.8
	6H	15.4	16.6	15.9	17.1	17.6	19.4	20.6	19.9	21.1	21.6
	8H	15.5	16.7	16.0	17.1	17.6	19.7	20.9	20.2	21.4	21.9
	12H	15.5	16.7	16.0	17.1	17.7	20.0	21.2	20.5	21.7	22.2
4H	2H	14.1	15.4	14.5	15.9	16.3	15.8	17.2	16.3	17.6	18.1
	3H	15.7	16.9	16.2	17.3	17.8	18.3	19.5	18.8	19.9	20.4
	4H	16.3	17.3	16.8	17.8	18.3	19.4	20.4	19.9	20.9	21.4
	6H	16.7	17.6	17.2	18.2	18.7	20.4	21.3	20.9	21.8	22.3
	8H	16.8	17.7	17.4	18.2	18.8	20.8	21.6	21.3	22.1	22.7
	12H	16.9	17.7	17.5	18.3	18.8	21.2	21.9	21.7	22.5	23.0
8H	4H	16.9	17.7	17.4	18.3	18.8	19.6	20.4	20.1	20.9	21.5
	6H	17.5	18.2	18.0	18.7	19.3	20.7	21.4	21.2	22.0	22.5
	8H	17.7	18.3	18.2	18.9	19.5	21.2	21.9	21.8	22.4	23.0
	12H	17.8	18.4	18.4	18.9	19.6	21.7	22.3	22.3	22.9	23.5
12H	4H	17.0	17.8	17.5	18.3	18.9	19.6	20.4	20.1	20.9	21.5
	6H	17.7	18.3	18.2	18.8	19.5	20.7	21.4	21.3	21.9	22.5
	8H	17.9	18.5	18.5	19.1	19.7	21.3	21.9	21.9	22.4	23.1

Maximum UGR = 23.5

POLAR GRAPH



Maximum Candela = 365.104 Located At Horizontal Angle = 90, Vertical Angle = 5.5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (5.5) (Through Max. Cd.)