



IES INDOOR REPORT

PHOTOMETRIC FILENAME : NVL G2 4 MD UV FRA 935.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001796-008A(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 7/6/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] NVL G2 4 MD UV FRA 935

[LUMINAIRE] Surface/pendant mounted, formed white plastic housing, formed
[MORE] white painted steel LED tray/reflector, translucent linear stepped plastic
[MORE] lens.

[LAMP] 96 white LEDs on two LS3872A7-3500K-R90 LED boards with 48 LEDs
[MORE] each.

[BALLAST] One ULT Everline D15CC55UNVPW-C LED driver labeled as 870mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	5828
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	132
Total Luminaire Watts	44.2
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.20
Spacing Criterion (Diagonal)	1.32
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	4.27 ft
Luminous Width (90-270)	0.54 ft
Luminous Height	0.16 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	7504	6506	6362
55	6438	5563	5724
65	5209	4736	5312
75	3977	4135	4930
85	2525	3742	4453

IES INDOOR REPORT
PHOTOMETRIC FILENAME : NVL G2 4 MD UV FRA 935.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	714.64	N.A.	12.30
0-30	1491.13	N.A.	25.60
0-40	2412.8	N.A.	41.40
0-60	4166.36	N.A.	71.50
0-80	5259.35	N.A.	90.20
0-90	5521.17	N.A.	94.70
10-90	5333.66	N.A.	91.50
20-40	1698.15	N.A.	29.10
20-50	2630.71	N.A.	45.10
40-70	2399.54	N.A.	41.20
60-80	1092.99	N.A.	18.80
70-80	447.01	N.A.	7.70
80-90	261.82	N.A.	4.50
90-110	238.50	N.A.	4.10
90-120	284.25	N.A.	4.90
90-130	302.06	N.A.	5.20
90-150	306.42	N.A.	5.30
90-180	306.74	N.A.	5.30
110-180	68.24	N.A.	1.20
0-180	5827.91	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	187.51
10-20	527.13
20-30	776.48
30-40	921.67
40-50	932.56
50-60	821.01
60-70	645.98
70-80	447.01
80-90	261.82
90-100	149.77
100-110	88.73
110-120	45.76
120-130	17.80
130-140	3.44
140-150	0.92
150-160	0.32
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : NVL G2 4 MD UV FRA 935.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	118	118	118	118	114	114	114	114	108	108	108	102	102	102	97	97	97	95
1	106	101	96	92	103	98	94	90	93	90	86	88	85	83	84	82	79	77
2	97	88	81	75	93	85	79	73	81	76	71	77	72	68	73	69	66	64
3	88	77	69	62	85	75	67	61	71	65	59	68	62	58	65	60	56	53
4	81	68	59	52	78	67	58	52	63	56	51	60	54	49	58	52	48	46
5	74	61	52	45	72	60	51	45	57	49	44	54	48	43	52	46	42	40
6	68	55	46	39	66	54	45	39	51	44	38	49	43	38	47	41	37	35
7	63	50	41	35	61	49	40	35	47	39	34	45	38	33	43	37	33	31
8	59	46	37	31	57	45	37	31	43	36	30	41	35	30	40	34	29	27
9	55	42	34	28	54	41	33	28	39	32	27	38	32	27	37	31	27	25
10	52	39	31	25	50	38	30	25	37	30	25	35	29	25	34	28	24	22


IES INDOOR REPORT
PHOTOMETRIC FILENAME : NVL G2 4 MD UV FRA 935.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	16.6	18.1	17.0	18.6	19.0	18.3	19.9	18.8	20.3	20.7
	3H	17.9	19.3	18.3	19.7	20.2	20.7	22.1	21.2	22.5	23.0
	4H	18.3	19.6	18.8	20.1	20.6	21.8	23.2	22.3	23.6	24.1
	6H	18.6	19.8	19.1	20.3	20.8	22.9	24.2	23.4	24.6	25.1
	8H	18.6	19.8	19.1	20.3	20.8	23.4	24.6	23.9	25.1	25.6
	12H	18.6	19.8	19.2	20.3	20.8	24.0	25.1	24.5	25.6	26.2
4H	2H	17.3	18.7	17.8	19.1	19.6	18.7	20.1	19.2	20.5	21.0
	3H	18.9	20.0	19.4	20.5	21.0	21.3	22.5	21.8	23.0	23.5
	4H	19.4	20.5	19.9	21.0	21.5	22.6	23.7	23.1	24.2	24.7
	6H	19.8	20.7	20.3	21.2	21.8	23.9	24.8	24.5	25.4	25.9
	8H	19.9	20.8	20.4	21.3	21.9	24.6	25.4	25.1	25.9	26.5
	12H	20.0	20.7	20.5	21.3	21.9	25.2	26.0	25.8	26.6	27.1
8H	4H	20.0	20.9	20.6	21.4	22.0	22.8	23.7	23.4	24.2	24.8
	6H	20.6	21.3	21.1	21.9	22.5	24.3	25.0	24.8	25.6	26.2
	8H	20.8	21.4	21.3	22.0	22.6	25.0	25.7	25.6	26.3	26.9
	12H	20.9	21.5	21.5	22.1	22.7	25.9	26.5	26.5	27.0	27.7
12H	4H	20.2	21.0	20.8	21.5	22.1	22.8	23.6	23.4	24.2	24.7
	6H	20.9	21.5	21.4	22.1	22.7	24.3	25.0	24.9	25.5	26.2
	8H	21.1	21.7	21.7	22.3	22.9	25.1	25.7	25.7	26.3	27.0

Maximum UGR = 27.7

POLAR GRAPH



Maximum Candela = 1996.471 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)