



IES INDOOR REPORT

PHOTOMETRIC FILENAME : NVL G2 8 MH UV FRA 930.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001796-008A(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 7/6/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] NVL G2 8 MH UV FRA 930

[LUMINAIRE] Surface/pendant mounted, formed white plastic housing, formed

[MORE] white painted steel LED tray/reflector, translucent linear stepped plastic

[MORE] lens.

[LAMP] 192 white LEDs on four LS3872A7-3000K-R90 LED boards with 48 LEDs

[MORE] each.

[BALLAST] One ULT Everline D21CC80UNVPW-C LED driver labeled as 1730mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	11546
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	134
Total Luminaire Watts	86.1
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.20
Spacing Criterion (Diagonal)	1.32
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	8.27 ft
Luminous Width (90-270)	0.54 ft
Luminous Height	0.16 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	7810	6724	6508
55	6748	5769	5856
65	5523	4934	5434
75	4319	4339	5044
85	3012	3985	4556

IES INDOOR REPORT
PHOTOMETRIC FILENAME : NVL G2 8 MH UV FRA 930.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	1415.86	N.A.	12.30
0-30	2954.23	N.A.	25.60
0-40	4780.25	N.A.	41.40
0-60	8254.43	N.A.	71.50
0-80	10419.86	N.A.	90.20
0-90	10938.58	N.A.	94.70
10-90	10567.08	N.A.	91.50
20-40	3364.39	N.A.	29.10
20-50	5211.98	N.A.	45.10
40-70	4753.99	N.A.	41.20
60-80	2165.44	N.A.	18.80
70-80	885.63	N.A.	7.70
80-90	518.72	N.A.	4.50
90-110	472.51	N.A.	4.10
90-120	563.17	N.A.	4.90
90-130	598.43	N.A.	5.20
90-150	607.07	N.A.	5.30
90-180	607.71	N.A.	5.30
110-180	135.20	N.A.	1.20
0-180	11546.29	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	371.50
10-20	1044.36
20-30	1538.37
30-40	1826.02
40-50	1847.59
50-60	1626.59
60-70	1279.81
70-80	885.63
80-90	518.72
90-100	296.72
100-110	175.79
110-120	90.66
120-130	35.27
130-140	6.82
140-150	1.82
150-160	0.64
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : NVL G2 8 MH UV FRA 930.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	118	118	118	118	114	114	114	114	108	108	108	102	102	102	97	97	97	95
1	106	101	96	92	103	98	94	90	93	90	86	88	85	83	84	82	79	77
2	97	88	81	75	93	85	79	73	81	76	71	77	72	68	73	69	66	64
3	88	77	69	62	85	75	67	61	71	65	59	68	62	58	65	60	56	53
4	81	68	59	52	78	67	58	52	63	56	51	60	54	49	58	52	48	46
5	74	61	52	45	72	60	51	45	57	49	44	54	48	43	52	46	42	40
6	68	55	46	39	66	54	45	39	51	44	38	49	43	38	47	41	37	35
7	63	50	41	35	61	49	40	35	47	39	34	45	38	33	43	37	33	31
8	59	46	37	31	57	45	37	31	43	36	30	41	35	30	40	34	29	27
9	55	42	34	28	54	41	33	28	39	32	27	38	32	27	37	31	27	25
10	52	39	31	25	50	38	30	25	37	30	25	35	29	25	34	28	24	22


IES INDOOR REPORT
PHOTOMETRIC FILENAME : NVL G2 8 MH UV FRA 930.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	16.7	18.3	17.2	18.7	19.1	18.5	20.1	19.0	20.5	20.9
	3H	18.0	19.4	18.5	19.8	20.3	20.9	22.3	21.4	22.8	23.2
	4H	18.4	19.8	18.9	20.2	20.7	22.1	23.4	22.5	23.8	24.3
	6H	18.7	19.9	19.2	20.4	20.9	23.2	24.4	23.7	24.9	25.4
	8H	18.7	19.9	19.2	20.4	20.9	23.7	24.9	24.2	25.4	25.9
	12H	18.8	19.9	19.3	20.4	20.9	24.3	25.5	24.8	25.9	26.5
4H	2H	17.5	18.8	17.9	19.2	19.7	18.9	20.2	19.4	20.7	21.2
	3H	19.0	20.2	19.5	20.6	21.2	21.5	22.7	22.0	23.2	23.7
	4H	19.6	20.6	20.1	21.1	21.6	22.9	23.9	23.4	24.4	24.9
	6H	19.9	20.8	20.5	21.4	21.9	24.2	25.1	24.7	25.6	26.2
	8H	20.0	20.9	20.6	21.4	22.0	24.8	25.7	25.4	26.2	26.8
	12H	20.1	20.9	20.7	21.4	22.0	25.5	26.3	26.1	26.9	27.5
8H	4H	20.2	21.0	20.7	21.6	22.2	23.1	23.9	23.6	24.4	25.0
	6H	20.7	21.5	21.3	22.0	22.6	24.5	25.3	25.1	25.8	26.4
	8H	20.9	21.6	21.5	22.2	22.7	25.3	26.0	25.9	26.6	27.2
	12H	21.0	21.6	21.6	22.2	22.9	26.2	26.8	26.8	27.4	28.0
12H	4H	20.4	21.1	20.9	21.7	22.3	23.1	23.8	23.6	24.4	25.0
	6H	21.0	21.7	21.6	22.2	22.9	24.6	25.2	25.2	25.8	26.4
	8H	21.3	21.8	21.8	22.4	23.1	25.4	26.0	26.0	26.6	27.2

Maximum UGR = 28.0

POLAR GRAPH



Maximum Candela = 3955.422 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)