



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : NVL G2 8 SL UV FRA 950.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001796-008A(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUEDATE] 7/6/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] NVL G2 8 SL UV FRA 950

[LUMINAIRE] Surface/pendant mounted, formed white plastic housing, formed

[MORE] white painted steel LED tray/reflector, translucent linear stepped plastic

[MORE] lens.

[LAMP] 112 white LEDs on four LS3872A6-5000K-R90 LED boards with 28 LEDs

[MORE] each.

[BALLAST] One ULT Everline D10CC30UNVPW-C LED driver labeled as 680mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4171
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	141
Total Luminaire Watts	29.6
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.20
Spacing Criterion (Diagonal)	1.32
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	8.27 ft
Luminous Width (90-270)	0.54 ft
Luminous Height	0.16 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	2821	2429	2351
55	2438	2084	2115
65	1995	1782	1963
75	1560	1567	1822
85	1088	1440	1646

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : NVL G2 8 SL UV FRA 950.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	511.45	N.A.	12.30
0-30	1067.15	N.A.	25.60
0-40	1726.76	N.A.	41.40
0-60	2981.73	N.A.	71.50
0-80	3763.95	N.A.	90.20
0-90	3951.33	N.A.	94.70
10-90	3817.13	N.A.	91.50
20-40	1215.31	N.A.	29.10
20-50	1882.72	N.A.	45.10
40-70	1717.28	N.A.	41.20
60-80	782.22	N.A.	18.80
70-80	319.91	N.A.	7.70
80-90	187.38	N.A.	4.50
90-110	170.68	N.A.	4.10
90-120	203.43	N.A.	4.90
90-130	216.17	N.A.	5.20
90-150	219.29	N.A.	5.30
90-180	219.52	N.A.	5.30
110-180	48.84	N.A.	1.20
0-180	4170.85	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	134.20
10-20	377.25
20-30	555.70
30-40	659.61
40-50	667.40
50-60	587.57
60-70	462.31
70-80	319.91
80-90	187.38
90-100	107.18
100-110	63.50
110-120	32.75
120-130	12.74
130-140	2.46
140-150	0.66
150-160	0.23
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : NVL G2 8 SL UV FRA 950.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	118	118	118	118	114	114	114	114	108	108	108	102	102	102	97	97	97	95
1	106	101	96	92	103	98	94	90	93	90	86	88	85	83	84	82	79	77
2	97	88	81	75	93	85	79	73	81	76	71	77	72	68	73	69	66	64
3	88	77	69	62	85	75	67	61	71	65	59	68	62	58	65	60	56	53
4	81	68	59	52	78	67	58	52	63	56	51	60	54	49	58	52	48	46
5	74	61	52	45	72	60	51	45	57	49	44	54	48	43	52	46	42	40
6	68	55	46	39	66	54	45	39	51	44	38	49	43	38	47	41	37	35
7	63	50	41	35	61	49	40	35	47	39	34	45	38	33	43	37	33	31
8	59	46	37	31	57	45	37	31	43	36	30	41	35	30	40	34	29	27
9	55	42	34	28	54	41	33	28	39	32	27	38	32	27	37	31	27	25
10	52	39	31	25	50	38	30	25	37	30	25	35	29	25	34	28	24	22


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : NVL G2 8 SL UV FRA 950.IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	13.2	14.8	13.7	15.2	15.6	15.0	16.6	15.5	17.0	17.4
	3H	14.5	15.9	15.0	16.3	16.8	17.4	18.8	17.9	19.3	19.7
	4H	14.9	16.3	15.4	16.7	17.2	18.6	19.9	19.0	20.3	20.8
	6H	15.2	16.4	15.7	16.9	17.4	19.7	20.9	20.2	21.4	21.9
	8H	15.2	16.4	15.7	16.9	17.4	20.2	21.4	20.7	21.9	22.4
	12H	15.3	16.4	15.8	16.9	17.4	20.8	22.0	21.3	22.4	23.0
4H	2H	14.0	15.3	14.5	15.7	16.2	15.4	16.7	15.9	17.2	17.7
	3H	15.5	16.7	16.0	17.1	17.7	18.0	19.2	18.5	19.7	20.2
	4H	16.1	17.1	16.6	17.6	18.1	19.4	20.4	19.9	20.9	21.4
	6H	16.4	17.3	17.0	17.9	18.4	20.7	21.6	21.2	22.1	22.7
	8H	16.5	17.4	17.1	17.9	18.5	21.3	22.2	21.9	22.7	23.3
	12H	16.6	17.4	17.2	17.9	18.5	22.0	22.8	22.6	23.4	24.0
8H	4H	16.7	17.5	17.2	18.1	18.7	19.6	20.4	20.1	20.9	21.5
	6H	17.2	18.0	17.8	18.5	19.1	21.0	21.8	21.6	22.3	22.9
	8H	17.4	18.1	18.0	18.7	19.3	21.8	22.5	22.4	23.1	23.7
	12H	17.5	18.1	18.1	18.7	19.4	22.7	23.3	23.3	23.9	24.5
12H	4H	16.9	17.6	17.4	18.2	18.8	19.6	20.3	20.1	20.9	21.5
	6H	17.5	18.2	18.1	18.7	19.4	21.1	21.7	21.7	22.3	22.9
	8H	17.8	18.4	18.3	18.9	19.6	21.9	22.5	22.5	23.1	23.7

Maximum UGR = 24.5

POLAR GRAPH



Maximum Candela = 1428.812 Located At Horizontal Angle = 90, Vertical Angle = .5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)