



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 2 LW UV FR 930.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-003(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 5/20/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] ECL N G2 2 LW UV FR 930

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMP] 28 white LEDs on one LS3872A LED board

[BALLAST] One ULT D700C20UNVPW-C LED driver labeled as 160mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

| | |
|---------------------------------|---------------------|
| Lumens Per Lamp | N.A. (absolute) |
| Total Lamp Lumens | N.A. (absolute) |
| Luminaire Lumens | 1043 |
| Total Luminaire Efficiency | N.A. |
| Luminaire Efficacy Rating (LER) | 123 |
| Total Luminaire Watts | 8.5 |
| Ballast Factor | 1.00 |
| CIE Type | Direct |
| Spacing Criterion (0-180) | 1.24 |
| Spacing Criterion (90-270) | 1.30 |
| Spacing Criterion (Diagonal) | 1.38 |
| Basic Luminous Shape | Rectangular w/Sides |
| Luminous Length (0-180) | 1.99 ft |
| Luminous Width (90-270) | 0.21 ft |
| Luminous Height | 0.06 ft |

LUMINANCE DATA (cd/sq.m)

| Angle In Degrees | Average 0-Deg | Average 45-Deg | Average 90-Deg |
|---------------------|------------------|-------------------|-------------------|
| 45 | 7530 | 6881 | 6792 |
| 55 | 6449 | 6027 | 6017 |
| 65 | 5112 | 5034 | 5103 |
| 75 | 3670 | 4037 | 4080 |
| 85 | 2028 | 3274 | 3215 |

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL N G2 2 LW UV FR 930.IES

ZONAL LUMEN SUMMARY

| Zone | Lumens | %Lamp | %Fixt |
|---------|---------|-------|--------|
| 0-20 | 127.55 | N.A. | 12.20 |
| 0-30 | 271.36 | N.A. | 26.00 |
| 0-40 | 444.12 | N.A. | 42.60 |
| 0-60 | 776.23 | N.A. | 74.40 |
| 0-80 | 967.78 | N.A. | 92.80 |
| 0-90 | 1006.41 | N.A. | 96.50 |
| 10-90 | 973.49 | N.A. | 93.30 |
| 20-40 | 316.57 | N.A. | 30.30 |
| 20-50 | 493.11 | N.A. | 47.30 |
| 40-70 | 449.41 | N.A. | 43.10 |
| 60-80 | 191.55 | N.A. | 18.40 |
| 70-80 | 74.24 | N.A. | 7.10 |
| 80-90 | 38.64 | N.A. | 3.70 |
| 90-110 | 26.72 | N.A. | 2.60 |
| 90-120 | 31.34 | N.A. | 3.00 |
| 90-130 | 33.87 | N.A. | 3.20 |
| 90-150 | 36.14 | N.A. | 3.50 |
| 90-180 | 36.78 | N.A. | 3.50 |
| 110-180 | 10.06 | N.A. | 1.00 |
| 0-180 | 1043.19 | N.A. | 100.00 |

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

| Zone | Lumens |
|---------|--------|
| 0-10 | 32.93 |
| 10-20 | 94.62 |
| 20-30 | 143.82 |
| 30-40 | 172.76 |
| 40-50 | 176.54 |
| 50-60 | 155.57 |
| 60-70 | 117.31 |
| 70-80 | 74.24 |
| 80-90 | 38.64 |
| 90-100 | 17.95 |
| 100-110 | 8.77 |
| 110-120 | 4.62 |
| 120-130 | 2.54 |
| 130-140 | 1.45 |
| 140-150 | 0.82 |
| 150-160 | 0.46 |
| 160-170 | 0.16 |
| 170-180 | 0.02 |

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL N G2 2 LW UV FR 930.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

| RC | 80 | | | | 70 | | | | 50 | | | 30 | | | 10 | | | 0 |
|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|----|----|----|
| RW | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 0 |
| 0 | 118 | 118 | 118 | 118 | 115 | 115 | 115 | 115 | 109 | 109 | 109 | 104 | 104 | 104 | 99 | 99 | 99 | 96 |
| 1 | 107 | 102 | 98 | 93 | 104 | 100 | 95 | 92 | 95 | 91 | 88 | 90 | 87 | 85 | 86 | 84 | 82 | 79 |
| 2 | 97 | 89 | 82 | 76 | 94 | 87 | 80 | 75 | 82 | 77 | 72 | 79 | 74 | 70 | 75 | 71 | 68 | 66 |
| 3 | 89 | 78 | 70 | 63 | 86 | 76 | 68 | 62 | 73 | 66 | 61 | 69 | 64 | 59 | 66 | 62 | 58 | 55 |
| 4 | 81 | 69 | 60 | 53 | 79 | 67 | 59 | 53 | 65 | 57 | 52 | 62 | 56 | 51 | 59 | 54 | 50 | 47 |
| 5 | 75 | 62 | 53 | 46 | 72 | 60 | 52 | 45 | 58 | 50 | 45 | 55 | 49 | 44 | 53 | 48 | 43 | 41 |
| 6 | 69 | 56 | 47 | 40 | 67 | 54 | 46 | 40 | 52 | 45 | 39 | 50 | 44 | 38 | 48 | 42 | 38 | 36 |
| 7 | 64 | 50 | 42 | 35 | 62 | 49 | 41 | 35 | 47 | 40 | 35 | 46 | 39 | 34 | 44 | 38 | 34 | 32 |
| 8 | 60 | 46 | 37 | 32 | 58 | 45 | 37 | 31 | 43 | 36 | 31 | 42 | 35 | 31 | 41 | 35 | 30 | 28 |
| 9 | 56 | 42 | 34 | 28 | 54 | 41 | 34 | 28 | 40 | 33 | 28 | 39 | 32 | 28 | 37 | 32 | 27 | 25 |
| 10 | 52 | 39 | 31 | 26 | 51 | 38 | 31 | 26 | 37 | 30 | 25 | 36 | 29 | 25 | 35 | 29 | 25 | 23 |


IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL N G2 2 LW UV FR 930.IES

UGR TABLE - CORRECTED

| Reflectances | | | | | | | | | | | |
|----------------|------|----------------------|------|------|------|------|--------------------|------|------|------|------|
| Ceiling Cavity | 70 | 70 | 50 | 50 | 30 | 70 | 70 | 50 | 50 | 30 | |
| Walls | 50 | 30 | 50 | 30 | 30 | 50 | 30 | 50 | 30 | 30 | |
| Floor Cavity | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | |
| Room Size | | UGR Viewed Crosswise | | | | | UGR Viewed Endwise | | | | |
| X=2H | Y=2H | 16.8 | 18.3 | 17.2 | 18.7 | 19.2 | 18.9 | 20.5 | 19.3 | 20.9 | 21.3 |
| | 3H | 18.0 | 19.4 | 18.4 | 19.8 | 20.3 | 20.9 | 22.3 | 21.3 | 22.7 | 23.2 |
| | 4H | 18.3 | 19.7 | 18.8 | 20.1 | 20.6 | 21.8 | 23.1 | 22.2 | 23.5 | 24.0 |
| | 6H | 18.5 | 19.8 | 19.0 | 20.2 | 20.7 | 22.6 | 23.8 | 23.1 | 24.3 | 24.7 |
| | 8H | 18.6 | 19.8 | 19.1 | 20.2 | 20.7 | 23.0 | 24.1 | 23.5 | 24.6 | 25.1 |
| | 12H | 18.6 | 19.7 | 19.1 | 20.2 | 20.7 | 23.4 | 24.5 | 23.9 | 25.0 | 25.5 |
| 4H | 2H | 17.6 | 19.0 | 18.1 | 19.4 | 19.9 | 19.3 | 20.6 | 19.8 | 21.1 | 21.6 |
| | 3H | 19.1 | 20.2 | 19.6 | 20.7 | 21.2 | 21.5 | 22.7 | 22.0 | 23.1 | 23.6 |
| | 4H | 19.6 | 20.6 | 20.1 | 21.1 | 21.6 | 22.6 | 23.6 | 23.0 | 24.1 | 24.6 |
| | 6H | 19.9 | 20.8 | 20.4 | 21.3 | 21.8 | 23.5 | 24.4 | 24.1 | 24.9 | 25.5 |
| | 8H | 19.9 | 20.8 | 20.5 | 21.3 | 21.8 | 24.0 | 24.8 | 24.5 | 25.4 | 25.9 |
| | 12H | 20.0 | 20.7 | 20.5 | 21.3 | 21.8 | 24.5 | 25.3 | 25.0 | 25.8 | 26.4 |
| 8H | 4H | 20.1 | 21.0 | 20.6 | 21.5 | 22.0 | 22.7 | 23.6 | 23.3 | 24.1 | 24.6 |
| | 6H | 20.6 | 21.3 | 21.1 | 21.8 | 22.4 | 23.9 | 24.6 | 24.4 | 25.1 | 25.7 |
| | 8H | 20.7 | 21.4 | 21.3 | 21.9 | 22.5 | 24.4 | 25.1 | 25.0 | 25.7 | 26.2 |
| | 12H | 20.8 | 21.4 | 21.4 | 21.9 | 22.6 | 25.1 | 25.7 | 25.7 | 26.2 | 26.9 |
| 12H | 4H | 20.2 | 21.0 | 20.8 | 21.5 | 22.1 | 22.7 | 23.5 | 23.3 | 24.0 | 24.6 |
| | 6H | 20.8 | 21.4 | 21.4 | 22.0 | 22.6 | 23.9 | 24.5 | 24.5 | 25.1 | 25.7 |
| | 8H | 21.0 | 21.6 | 21.6 | 22.1 | 22.8 | 24.5 | 25.1 | 25.1 | 25.7 | 26.3 |

Maximum UGR = 26.9

POLAR GRAPH



Maximum Candela = 348.971 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)