



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 2 ML UV FR 930.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-003(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 5/20/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] ECL N G2 2 ML UV FR 930

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMP] 28 white LEDs on one LS3872A LED board

[BALLAST] One ULT D700C20UNVPW-C LED driver labeled as 240mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1550
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	128
Total Luminaire Watts	12.1
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.24
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	1.99 ft
Luminous Width (90-270)	0.21 ft
Luminous Height	0.06 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	11191	10226	10094
55	9584	8957	8942
65	7597	7482	7584
75	5454	5999	6063
85	3013	4865	4778

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL N G2 2 ML UV FR 930.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	189.56	N.A.	12.20
0-30	403.29	N.A.	26.00
0-40	660.03	N.A.	42.60
0-60	1153.6	N.A.	74.40
0-80	1438.28	N.A.	92.80
0-90	1495.7	N.A.	96.50
10-90	1446.76	N.A.	93.30
20-40	470.48	N.A.	30.30
20-50	732.85	N.A.	47.30
40-70	667.90	N.A.	43.10
60-80	284.67	N.A.	18.40
70-80	110.34	N.A.	7.10
80-90	57.42	N.A.	3.70
90-110	39.71	N.A.	2.60
90-120	46.57	N.A.	3.00
90-130	50.34	N.A.	3.20
90-150	53.72	N.A.	3.50
90-180	54.66	N.A.	3.50
110-180	14.95	N.A.	1.00
0-180	1550.36	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	48.93
10-20	140.62
20-30	213.74
30-40	256.74
40-50	262.37
50-60	231.20
60-70	174.33
70-80	110.34
80-90	57.42
90-100	26.68
100-110	13.03
110-120	6.86
120-130	3.77
130-140	2.15
140-150	1.22
150-160	0.68
160-170	0.24
170-180	0.03

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL N G2 2 ML UV FR 930.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	118	118	118	118	115	115	115	115	109	109	109	104	104	104	99	99	99	96
1	107	102	98	93	104	100	95	92	95	91	88	90	87	85	86	84	82	79
2	97	89	82	76	94	87	80	75	82	77	72	79	74	70	75	71	68	66
3	89	78	70	63	86	76	68	62	73	66	61	69	64	59	66	62	58	55
4	81	69	60	53	79	67	59	53	65	57	52	62	56	51	59	54	50	47
5	75	62	53	46	72	60	52	45	58	50	45	55	49	44	53	48	43	41
6	69	56	47	40	67	54	46	40	52	45	39	50	44	38	48	42	38	36
7	64	50	42	35	62	49	41	35	47	40	35	46	39	34	44	38	34	32
8	60	46	37	32	58	45	37	31	43	36	31	42	35	31	41	35	30	28
9	56	42	34	28	54	41	34	28	40	33	28	39	32	28	37	32	27	25
10	52	39	31	26	51	38	31	26	37	30	25	36	29	25	35	29	25	23


IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL N G2 2 ML UV FR 930.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	18.1	19.6	18.5	20.0	20.5	20.2	21.8	20.6	22.2	22.6
	3H	19.3	20.7	19.7	21.1	21.6	22.2	23.6	22.7	24.0	24.5
	4H	19.6	21.0	20.1	21.4	21.9	23.1	24.4	23.5	24.8	25.3
	6H	19.8	21.1	20.3	21.5	22.0	23.9	25.1	24.4	25.6	26.1
	8H	19.9	21.1	20.4	21.5	22.0	24.3	25.5	24.8	25.9	26.4
	12H	19.9	21.0	20.4	21.5	22.0	24.7	25.8	25.2	26.3	26.8
4H	2H	18.9	20.3	19.4	20.7	21.2	20.6	22.0	21.1	22.4	22.9
	3H	20.4	21.5	20.9	22.0	22.5	22.8	24.0	23.3	24.4	24.9
	4H	20.9	21.9	21.4	22.4	22.9	23.9	24.9	24.4	25.4	25.9
	6H	21.2	22.1	21.7	22.6	23.1	24.8	25.7	25.4	26.2	26.8
	8H	21.2	22.1	21.8	22.6	23.1	25.3	26.1	25.8	26.7	27.2
	12H	21.3	22.0	21.8	22.6	23.1	25.8	26.6	26.3	27.1	27.7
8H	4H	21.4	22.3	21.9	22.8	23.3	24.0	24.9	24.6	25.4	26.0
	6H	21.9	22.6	22.4	23.2	23.7	25.2	25.9	25.7	26.4	27.0
	8H	22.0	22.7	22.6	23.2	23.8	25.8	26.4	26.3	27.0	27.5
	12H	22.1	22.7	22.7	23.2	23.9	26.4	27.0	27.0	27.5	28.2
12H	4H	21.5	22.3	22.1	22.9	23.4	24.0	24.8	24.6	25.3	25.9
	6H	22.1	22.7	22.7	23.3	23.9	25.2	25.8	25.8	26.4	27.0
	8H	22.3	22.9	22.9	23.4	24.1	25.9	26.4	26.4	27.0	27.6

Maximum UGR = 28.2

POLAR GRAPH



Maximum Candela = 518.629 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)