



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 4 LW UV FR 935.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-006(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 5/20/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] ECL N G2 4 LW UV FR 935

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMP] 56 white LEDs on two LS3872A LED boards

[BALLAST] One ULT D700C20UNVPW-C LED driver labeled as 320mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	2101
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	136
Total Luminaire Watts	15.4
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.24
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	3.84 ft
Luminous Width (90-270)	0.21 ft
Luminous Height	0.06 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	8144	7270	7082
55	7070	6415	6272
65	5664	5377	5263
75	4110	4289	4124
85	2365	3460	3126

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL N G2 4 LW UV FR 935.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	257.56	N.A.	12.30
0-30	547.66	N.A.	26.10
0-40	896.65	N.A.	42.70
0-60	1571.52	N.A.	74.80
0-80	1957.95	N.A.	93.20
0-90	2033.27	N.A.	96.80
10-90	1966.74	N.A.	93.60
20-40	639.10	N.A.	30.40
20-50	997.27	N.A.	47.50
40-70	912.89	N.A.	43.50
60-80	386.43	N.A.	18.40
70-80	148.41	N.A.	7.10
80-90	75.32	N.A.	3.60
90-110	50.60	N.A.	2.40
90-120	59.06	N.A.	2.80
90-130	63.54	N.A.	3.00
90-150	66.90	N.A.	3.20
90-180	67.49	N.A.	3.20
110-180	16.89	N.A.	0.80
0-180	2100.76	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	66.53
10-20	191.03
20-30	290.10
30-40	348.99
40-50	358.17
50-60	316.70
60-70	238.02
70-80	148.41
80-90	75.32
90-100	34.15
100-110	16.45
110-120	8.47
120-130	4.48
130-140	2.29
140-150	1.07
150-160	0.46
160-170	0.13
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL N G2 4 LW UV FR 935.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	118	118	118	118	115	115	115	115	109	109	109	104	104	104	99	99	99	97
1	107	102	98	94	104	100	96	92	95	91	88	90	88	85	86	84	82	80
2	97	89	82	76	94	87	80	75	83	77	73	79	74	70	75	72	68	66
3	89	78	70	63	86	76	69	62	73	66	61	70	64	59	67	62	58	56
4	81	69	60	53	79	68	59	53	65	57	52	62	56	51	59	54	50	47
5	75	62	53	46	72	60	52	46	58	50	45	56	49	44	53	48	43	41
6	69	56	47	40	67	54	46	40	52	45	39	50	44	39	48	43	38	36
7	64	50	42	35	62	49	41	35	48	40	35	46	39	34	44	38	34	32
8	60	46	37	32	58	45	37	31	44	36	31	42	35	31	41	35	30	28
9	56	42	34	28	54	41	34	28	40	33	28	39	32	28	38	32	27	25
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL N G2 4 LW UV FR 935.IES**

**UGR TABLE - CORRECTED**


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	17.1	18.7	17.5	19.1	19.5	19.1	20.7	19.5	21.1	21.5
	3H	18.3	19.8	18.8	20.1	20.6	21.1	22.5	21.5	22.9	23.4
	4H	18.7	20.0	19.1	20.4	20.9	22.0	23.3	22.4	23.7	24.2
	6H	18.9	20.1	19.3	20.6	21.0	22.7	24.0	23.2	24.4	24.9
	8H	18.9	20.1	19.4	20.6	21.0	23.1	24.3	23.6	24.8	25.2
	12H	18.9	20.1	19.4	20.5	21.0	23.5	24.6	24.0	25.1	25.6
4H	2H	18.0	19.3	18.4	19.7	20.2	19.6	20.9	20.0	21.3	21.8
	3H	19.4	20.5	19.8	21.0	21.5	21.7	22.9	22.2	23.3	23.8
	4H	19.9	20.9	20.3	21.4	21.9	22.7	23.8	23.2	24.2	24.7
	6H	20.2	21.1	20.7	21.6	22.1	23.7	24.6	24.2	25.1	25.6
	8H	20.2	21.1	20.7	21.6	22.1	24.1	25.0	24.6	25.5	26.0
	12H	20.3	21.0	20.8	21.6	22.1	24.6	25.4	25.1	25.9	26.5
8H	4H	20.4	21.3	20.9	21.8	22.3	22.9	23.8	23.4	24.3	24.8
	6H	20.9	21.6	21.4	22.1	22.7	24.0	24.7	24.5	25.3	25.8
	8H	21.0	21.7	21.5	22.2	22.8	24.6	25.2	25.1	25.8	26.3
	12H	21.1	21.7	21.6	22.2	22.8	25.2	25.8	25.7	26.3	26.9
12H	4H	20.5	21.3	21.0	21.8	22.4	22.9	23.7	23.4	24.2	24.8
	6H	21.1	21.7	21.6	22.2	22.8	24.0	24.7	24.6	25.2	25.8
	8H	21.3	21.9	21.8	22.4	23.0	24.7	25.2	25.2	25.8	26.4

Maximum UGR = 26.9

POLAR GRAPH



Maximum Candela = 706.536 Located At Horizontal Angle = 90, Vertical Angle = .5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)