



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 4 ML UV FR 950.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-006(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 5/20/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] ECL N G2 4 ML UV FR 950

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,
[MORE] translucent curved plastic enclosure.

[LAMP] 56 white LEDs on two LS3872A LED boards

[BALLAST] One ULT D700C20UNVPW-C LED driver labeled as 480mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	3197
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	143
Total Luminaire Watts	22.3
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.24
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	3.84 ft
Luminous Width (90-270)	0.21 ft
Luminous Height	0.06 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	12392	11063	10776
55	10758	9761	9544
65	8618	8181	8008
75	6253	6526	6275
85	3599	5265	4757

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL N G2 4 ML UV FR 950.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	391.90	N.A.	12.30
0-30	833.32	N.A.	26.10
0-40	1364.35	N.A.	42.70
0-60	2391.24	N.A.	74.80
0-80	2979.24	N.A.	93.20
0-90	3093.84	N.A.	96.80
10-90	2992.61	N.A.	93.60
20-40	972.45	N.A.	30.40
20-50	1517.45	N.A.	47.50
40-70	1389.07	N.A.	43.50
60-80	587.99	N.A.	18.40
70-80	225.82	N.A.	7.10
80-90	114.61	N.A.	3.60
90-110	76.99	N.A.	2.40
90-120	89.87	N.A.	2.80
90-130	96.69	N.A.	3.00
90-150	101.80	N.A.	3.20
90-180	102.69	N.A.	3.20
110-180	25.70	N.A.	0.80
0-180	3196.54	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	101.23
10-20	290.67
20-30	441.42
30-40	531.03
40-50	545.00
50-60	481.89
60-70	362.18
70-80	225.82
80-90	114.61
90-100	51.96
100-110	25.03
110-120	12.88
120-130	6.81
130-140	3.49
140-150	1.62
150-160	0.70
160-170	0.20
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 4 ML UV FR 950.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	118	118	118	118	115	115	115	115	109	109	109	104	104	104	99	99	99	97
1	107	102	98	94	104	100	96	92	95	91	88	90	88	85	86	84	82	80
2	97	89	82	76	94	87	80	75	83	77	73	79	74	70	75	72	68	66
3	89	78	70	63	86	76	69	62	73	66	61	70	64	59	67	62	58	56
4	81	69	60	53	79	68	59	53	65	57	52	62	56	51	59	54	50	47
5	75	62	53	46	72	60	52	46	58	50	45	56	49	44	53	48	43	41
6	69	56	47	40	67	54	46	40	52	45	39	50	44	39	48	43	38	36
7	64	50	42	35	62	49	41	35	48	40	35	46	39	34	44	38	34	32
8	60	46	37	32	58	45	37	31	44	36	31	42	35	31	41	35	30	28
9	56	42	34	28	54	41	34	28	40	33	28	39	32	28	38	32	27	25
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23


IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL N G2 4 ML UV FR 950.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	18.5	20.1	18.9	20.5	20.9	20.5	22.1	20.9	22.5	22.9
	3H	19.7	21.2	20.2	21.5	22.0	22.5	23.9	22.9	24.3	24.8
	4H	20.1	21.4	20.5	21.8	22.3	23.4	24.7	23.8	25.1	25.6
	6H	20.3	21.5	20.7	22.0	22.4	24.1	25.4	24.6	25.8	26.3
	8H	20.3	21.5	20.8	22.0	22.4	24.5	25.7	25.0	26.2	26.6
	12H	20.3	21.5	20.8	21.9	22.4	24.9	26.0	25.4	26.5	27.0
4H	2H	19.4	20.7	19.8	21.1	21.6	21.0	22.3	21.4	22.7	23.2
	3H	20.8	21.9	21.2	22.4	22.9	23.1	24.3	23.6	24.7	25.2
	4H	21.3	22.3	21.7	22.8	23.3	24.1	25.2	24.6	25.6	26.1
	6H	21.6	22.5	22.1	23.0	23.5	25.1	26.0	25.6	26.5	27.0
	8H	21.6	22.5	22.1	23.0	23.5	25.5	26.4	26.0	26.9	27.4
	12H	21.7	22.4	22.2	23.0	23.5	26.0	26.8	26.5	27.3	27.9
8H	4H	21.8	22.7	22.3	23.2	23.7	24.3	25.2	24.8	25.7	26.2
	6H	22.3	23.0	22.8	23.5	24.1	25.4	26.1	25.9	26.7	27.2
	8H	22.4	23.1	22.9	23.6	24.2	26.0	26.6	26.5	27.2	27.7
	12H	22.5	23.1	23.0	23.6	24.2	26.6	27.2	27.1	27.7	28.3
12H	4H	21.9	22.7	22.4	23.2	23.8	24.3	25.1	24.8	25.6	26.2
	6H	22.5	23.1	23.0	23.6	24.2	25.4	26.1	26.0	26.6	27.2
	8H	22.7	23.3	23.2	23.8	24.4	26.1	26.6	26.6	27.2	27.8

Maximum UGR = 28.3

POLAR GRAPH



Maximum Candela = 1075.072 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)