



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : PBL V2 4W VH UV 850.IES

### DESCRIPTION INFORMATION (From Photometric File)

[IESNA:LM-63-2002

[TEST] LLIA001687-021

[TESTLAB] LightLab International Allentown, LLC

[ISSUEDATE] 4/20/2022

[MANUFAC] Lumen Focus, LLC

[LUMCAT] PBL V2 4W VH UV 850

[LUMINAIRE] High Bay mounted, formed white painted aluminum housing/reflector,

[MORE] no enclosure.

[LAMP] 672 white LEDs, eight ULT M900C85084N2Q LED boards

[BALLAST] Four ULT D21CC80UNVPW-D LED drivers labeled at 1880mA

[OTHER] 120.1Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	53074
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	158
Total Luminaire Watts	334.9
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.30
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.40
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.80 ft
Luminous Width (90-270)	1.26 ft
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	40779	40022	40239
55	40009	39141	39663
65	37819	37155	38191
75	31542	34118	13239
85	16199	10312	11172

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : PBL V2 4W VH UV 850.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	6630.71	N.A.	12.50
0-30	14167.49	N.A.	26.70
0-40	23400.4	N.A.	44.10
0-60	42134.99	N.A.	79.40
0-80	52471.07	N.A.	98.90
0-90	53067.81	N.A.	100.00
10-90	51356.62	N.A.	96.80
20-40	16769.69	N.A.	31.60
20-50	26524.03	N.A.	50.00
40-70	25692.55	N.A.	48.40
60-80	10336.08	N.A.	19.50
70-80	3378.12	N.A.	6.40
80-90	596.74	N.A.	1.10
90-110	5.92	N.A.	0.00
90-120	5.92	N.A.	0.00
90-130	5.92	N.A.	0.00
90-150	5.92	N.A.	0.00
90-180	5.92	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	53073.73	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	1711.18
10-20	4919.53
20-30	7536.78
30-40	9232.91
40-50	9754.34
50-60	8980.25
60-70	6957.96
70-80	3378.12
80-90	596.74
90-100	5.79
100-110	0.13
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : PBL V2 4W VH UV 850.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	95	98	95	92	94	91	89	90	88	86	84
2	99	91	84	78	96	89	83	77	85	80	76	82	78	74	79	75	72	70
3	90	80	71	65	88	78	70	64	75	68	63	72	67	62	70	65	61	59
4	82	70	62	55	80	69	61	54	66	59	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	53	47	59	52	46	57	51	46	56	50	45	43
6	70	56	47	41	68	55	47	41	54	46	40	52	45	40	50	44	40	38
7	65	51	42	36	63	50	42	36	49	41	36	47	40	35	46	40	35	33
8	60	46	38	32	59	46	38	32	44	37	32	43	36	32	42	36	31	29
9	56	43	34	29	55	42	34	29	41	34	29	40	33	28	39	33	28	26
10	53	39	31	26	51	39	31	26	38	31	26	37	30	26	36	30	26	24


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : PBL V2 4W VH UV 850.IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	25.0	26.7	25.4	27.0	27.3	25.2	26.8	25.5	27.1	27.5
	3H	26.9	28.4	27.3	28.7	29.1	27.1	28.6	27.5	29.0	29.3
	4H	27.5	28.9	27.9	29.3	29.7	27.2	28.7	27.6	29.0	29.4
	6H	28.0	29.3	28.4	29.6	30.0	27.3	28.6	27.7	29.0	29.4
	8H	28.1	29.3	28.5	29.7	30.1	27.3	28.6	27.7	28.9	29.3
	12H	28.1	29.3	28.5	29.7	30.1	27.3	28.5	27.8	28.9	29.3
4H	2H	25.7	27.1	26.1	27.4	27.8	25.8	27.2	26.2	27.6	27.9
	3H	27.8	28.9	28.2	29.3	29.7	28.0	29.2	28.4	29.6	30.0
	4H	28.5	29.6	29.0	30.0	30.4	28.1	29.2	28.6	29.6	30.0
	6H	29.1	30.0	29.5	30.4	30.9	28.2	29.2	28.7	29.6	30.1
	8H	29.2	30.1	29.7	30.5	31.0	28.3	29.1	28.7	29.6	30.0
	12H	29.3	30.1	29.8	30.5	31.0	28.3	29.1	28.8	29.5	30.0
8H	4H	28.8	29.7	29.3	30.1	30.6	28.4	29.3	28.9	29.7	30.2
	6H	29.4	30.1	29.9	30.6	31.1	28.6	29.3	29.0	29.7	30.2
	8H	29.6	30.3	30.1	30.8	31.2	28.6	29.2	29.1	29.7	30.2
	12H	29.7	30.3	30.2	30.7	31.3	28.6	29.2	29.1	29.7	30.2
12H	4H	28.8	29.6	29.3	30.0	30.5	28.4	29.2	28.9	29.7	30.2
	6H	29.4	30.0	29.9	30.5	31.0	28.6	29.2	29.1	29.7	30.2
	8H	29.6	30.2	30.1	30.7	31.2	28.6	29.2	29.1	29.7	30.2

Maximum UGR = 31.3

POLAR GRAPH



Maximum Candela = 18202.004 Located At Horizontal Angle = 90, Vertical Angle = .5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)