



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : DLS V2 6 SEL UV SW 9SEL [LW,940].IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002  
[TEST] JG202002005Y  
[TESTLAB] EVERFINE  
[TESTDATE] 2021-09-28  
[ISSUEDATE] 2021-10-08 14:54:41  
[NEARFIELD]  
[LAMPPOSITION] 0,0  
[OTHER] EVERFINE GO-2000B\_V1 SYSTEM  
[MANUFAC] LumenFocus, LLC.  
[LUMINAIRE] LED 6" Can - 10W/40K/Dim/100-277V  
[LUMCAT] DLS v2 6 SEL UV SW 9SEL [LW,940]

### CHARACTERISTICS

Lumens Per Lamp	833.44 (1 lamp)
Total Lamp Lumens	833.44
Luminaire Lumens	833
Total Luminaire Efficiency	100 %
Luminaire Efficacy Rating (LER)	87
Total Luminaire Watts	9.6
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.20
Spacing Criterion (Diagonal)	1.28
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.15 m (Diameter)
Luminous Width (90-270)	0.15 m (Diameter)
Luminous Height	0.00 m

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	16661	16962	16930
55	11006	11644	11913
65	6132	6814	7423
75	2675	3284	4045
85	980	1452	2193

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : DLS V2 6 SEL UV SW 9SEL [LW,940].IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	144.31	17.30	17.30
0-30	301.47	36.20	36.20
0-40	480.04	57.60	57.60
0-60	751.40	90.20	90.20
0-80	823.09	98.80	98.80
0-90	826.10	99.10	99.10
10-90	788.55	94.60	94.60
20-40	335.73	40.30	40.30
20-50	498.50	59.80	59.80
40-70	325.16	39.00	39.00
60-80	71.69	8.60	8.60
70-80	17.90	2.10	2.10
80-90	3.01	0.40	0.40
90-110	0.74	0.10	0.10
90-120	1.58	0.20	0.20
90-130	2.71	0.30	0.30
90-150	5.24	0.60	0.60
90-180	7.34	0.90	0.90
110-180	6.60	0.80	0.80
0-180	833.44	100.00	100.00

Total Luminaire Efficiency = 100.00%

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	37.55
10-20	106.75
20-30	157.16
30-40	178.57
40-50	162.77
50-60	108.59
60-70	53.80
70-80	17.90
80-90	3.01
90-100	0.23
100-110	0.51
110-120	0.85
120-130	1.13
130-140	1.27
140-150	1.25
150-160	1.08
160-170	0.75
170-180	0.27

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : DLS V2 6 SEL UV SW 9SEL [LW,940].IES

## COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
1	111	107	103	100	108	105	101	99	100	98	95	96	94	92	93	91	89	87
2	102	95	90	85	100	94	88	84	90	86	82	87	83	80	84	81	78	76
3	95	85	79	73	92	84	77	72	81	75	71	78	74	70	76	72	68	66
4	87	77	69	63	85	76	68	63	73	67	62	71	65	61	69	64	60	58
5	81	70	62	56	79	68	61	55	66	60	55	64	59	54	62	57	53	51
6	75	63	55	49	73	62	55	49	60	54	49	59	53	48	57	52	48	46
7	70	58	50	44	68	57	49	44	55	49	44	54	48	43	53	47	43	41
8	65	53	45	40	64	52	45	40	51	44	39	50	44	39	48	43	39	37
9	61	49	41	36	60	48	41	36	47	40	36	46	40	36	45	39	35	34
10	58	45	38	33	56	45	38	33	44	37	33	43	37	33	42	36	32	31


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : DLS V2 6 SEL UV SW 9SEL [LW,940].IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	18.2	19.7	18.6	20.0	20.3	18.5	20.0	18.9	20.3	20.6
	3H	18.8	20.1	19.2	20.4	20.8	19.3	20.6	19.7	20.9	21.3
	4H	18.9	20.1	19.3	20.4	20.8	19.5	20.7	19.9	21.1	21.5
	6H	18.9	20.0	19.3	20.4	20.8	19.6	20.6	20.0	21.0	21.5
	8H	18.9	19.9	19.3	20.3	20.7	19.6	20.6	20.0	21.0	21.4
	12H	18.8	19.8	19.3	20.2	20.7	19.6	20.5	20.0	20.9	21.4
4H	2H	18.6	19.8	19.0	20.1	20.5	18.8	20.0	19.2	20.3	20.7
	3H	19.3	20.2	19.7	20.7	21.1	19.7	20.7	20.1	21.1	21.5
	4H	19.4	20.2	19.8	20.7	21.1	19.9	20.8	20.4	21.2	21.7
	6H	19.4	20.2	19.9	20.6	21.1	20.0	20.8	20.5	21.3	21.7
	8H	19.4	20.1	19.9	20.6	21.0	20.1	20.8	20.5	21.2	21.7
	12H	19.4	20.0	19.9	20.5	21.0	20.1	20.7	20.6	21.2	21.7
8H	4H	19.4	20.1	19.9	20.6	21.1	19.9	20.6	20.4	21.1	21.6
	6H	19.5	20.0	20.0	20.5	21.0	20.1	20.6	20.6	21.2	21.7
	8H	19.5	20.0	20.0	20.5	21.0	20.1	20.6	20.6	21.1	21.7
	12H	19.4	19.9	19.9	20.4	21.0	20.1	20.6	20.6	21.1	21.7
12H	4H	19.4	20.0	19.9	20.5	21.0	19.9	20.5	20.4	21.0	21.5
	6H	19.4	19.9	20.0	20.4	21.0	20.0	20.6	20.6	21.0	21.6
	8H	19.4	19.9	20.0	20.4	21.0	20.1	20.5	20.6	21.0	21.6

Maximum UGR = 21.7

POLAR GRAPH



Maximum Candela = 397.64 Located At Horizontal Angle = 255, Vertical Angle = 1  
# 1 - Vertical Plane Through Horizontal Angles (255 - 75) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (1) (Through Max. Cd.)