



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : DLS V2 6 SEL UV SW 9SEL [MD,930].IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002  
[TEST] JG202002002W  
[TESTLAB] EVERFINE  
[TESTDATE] 2021-09-28  
[ISSUEDATE] 2021-10-08 14:57:01  
[NEARFIELD]  
[LAMPPOSITION] 0,0  
[OTHER] EVERFINE GO-2000B\_V1 SYSTEM  
[MANUFAC] LumenFocus, LLC.  
[LUMINAIRE] LED 6" Can - 15W/30K/Dim/100-277V  
[LUMCAT] DLS v2 6 SEL UV SW 9SEL [MD,930]

### CHARACTERISTICS

Lumens Per Lamp	1227.9 (1 lamp)
Total Lamp Lumens	1227.9
Luminaire Lumens	1228
Total Luminaire Efficiency	100 %
Luminaire Efficacy Rating (LER)	86
Total Luminaire Watts	14.3
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.20
Spacing Criterion (Diagonal)	1.28
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.15 m (Diameter)
Luminous Width (90-270)	0.15 m (Diameter)
Luminous Height	0.00 m

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	24541	24986	24935
55	16133	17167	17571
65	9031	10060	10965
75	3948	4861	5986
85	1456	2181	3267

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : DLS V2 6 SEL UV SW 9SEL [MD,930].IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	212.57	17.30	17.30
0-30	444.07	36.20	36.20
0-40	706.96	57.60	57.60
0-60	1106.53	90.10	90.10
0-80	1212.33	98.70	98.70
0-90	1216.81	99.10	99.10
10-90	1161.49	94.60	94.60
20-40	494.39	40.30	40.30
20-50	734.07	59.80	59.80
40-70	478.93	39.00	39.00
60-80	105.79	8.60	8.60
70-80	26.44	2.20	2.20
80-90	4.48	0.40	0.40
90-110	1.18	0.10	0.10
90-120	2.47	0.20	0.20
90-130	4.17	0.30	0.30
90-150	7.95	0.60	0.60
90-180	11.09	0.90	0.90
110-180	9.91	0.80	0.80
0-180	1227.89	100.00	100.00

Total Luminaire Efficiency = 100.00%

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	55.32
10-20	157.25
20-30	231.50
30-40	262.89
40-50	239.68
50-60	159.90
60-70	79.36
70-80	26.44
80-90	4.48
90-100	0.38
100-110	0.80
110-120	1.29
120-130	1.70
130-140	1.91
140-150	1.87
150-160	1.61
160-170	1.12
170-180	0.41

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : DLS V2 6 SEL UV SW 9SEL [MD,930].IES

## COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
1	111	107	103	100	108	105	101	99	100	98	95	96	94	92	93	91	89	87
2	102	95	90	85	100	94	88	84	90	86	82	87	83	80	84	81	78	76
3	95	85	79	73	92	84	77	72	81	75	71	78	74	70	76	72	68	66
4	87	77	69	63	85	76	68	63	73	67	62	71	65	61	69	64	60	58
5	81	70	62	56	79	68	61	55	66	60	55	64	59	54	62	57	53	51
6	75	63	55	49	73	62	55	49	60	54	49	59	53	48	57	52	48	46
7	70	58	50	44	68	57	49	44	55	49	44	54	48	43	53	47	43	41
8	65	53	45	40	64	52	45	40	51	44	39	50	44	39	48	43	39	37
9	61	49	41	36	60	48	41	36	47	40	36	46	40	36	45	39	35	34
10	58	45	38	33	56	45	38	33	44	37	33	43	37	32	42	36	32	31

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : DLS V2 6 SEL UV SW 9SEL [MD,930].IES

## UGR TABLE - CORRECTED


### Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	19.5	21.0	19.9	21.3	21.6	19.9	21.3	20.2	21.6	22.0
	3H	20.1	21.4	20.5	21.7	22.1	20.6	21.9	21.0	22.3	22.6
	4H	20.2	21.4	20.6	21.7	22.1	20.8	22.0	21.2	22.4	22.8
	6H	20.2	21.3	20.6	21.7	22.1	20.9	22.0	21.3	22.4	22.8
	8H	20.2	21.2	20.6	21.6	22.0	20.9	21.9	21.3	22.3	22.7
	12H	20.1	21.1	20.6	21.5	22.0	20.9	21.9	21.3	22.3	22.7
4H	2H	19.9	21.1	20.3	21.4	21.8	20.1	21.3	20.5	21.7	22.1
	3H	20.6	21.5	21.0	21.9	22.4	21.0	22.0	21.5	22.4	22.8
	4H	20.7	21.5	21.1	22.0	22.4	21.3	22.1	21.7	22.6	23.0
	6H	20.7	21.5	21.2	21.9	22.4	21.4	22.1	21.8	22.6	23.1
	8H	20.7	21.4	21.2	21.9	22.3	21.4	22.1	21.9	22.5	23.0
	12H	20.7	21.3	21.2	21.8	22.3	21.4	22.0	21.9	22.5	23.0
8H	4H	20.7	21.4	21.2	21.9	22.4	21.3	21.9	21.7	22.4	22.9
	6H	20.8	21.3	21.3	21.8	22.3	21.4	22.0	21.9	22.5	23.0
	8H	20.7	21.3	21.3	21.8	22.3	21.4	21.9	21.9	22.5	23.0
	12H	20.7	21.2	21.3	21.7	22.3	21.4	21.9	22.0	22.4	23.0
12H	4H	20.7	21.3	21.2	21.8	22.3	21.2	21.8	21.7	22.3	22.8
	6H	20.7	21.2	21.3	21.7	22.3	21.3	21.9	21.9	22.4	22.9
	8H	20.7	21.2	21.3	21.7	22.3	21.4	21.9	21.9	22.4	23.0

Maximum UGR = 23.1

POLAR GRAPH



Maximum Candela = 585.66 Located At Horizontal Angle = 255, Vertical Angle = 1  
# 1 - Vertical Plane Through Horizontal Angles (255 - 75) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (1) (Through Max. Cd.)