



IES INDOOR REPORT

PHOTOMETRIC FILENAME : DLS V2 8 SEL UV SW 9SEL [LW,950].IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
[TEST] 20211007e
[TESTLAB] EVERFINE
[TESTDATE] 2021-10-07
[ISSUEDATE] 2021-10-08 11:07:06
[NEARFIELD]
[LAMPPOSITION] 0,0
[OTHER] EVERFINE GO-2000B_V1 SYSTEM
[MANUFAC] LumenFocus, LLC.
[LUMINAIRE] LED 8" Can - 12W/50K/Dim/100-277V
[LUMCAT] DLS v2 8 SEL UV SW 9SEL [LW/950]

CHARACTERISTICS

Lumens Per Lamp	1189.6 (1 lamp)
Total Lamp Lumens	1189.6
Luminaire Lumens	1190
Total Luminaire Efficiency	100 %
Luminaire Efficacy Rating (LER)	102
Total Luminaire Watts	11.7
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.18
Spacing Criterion (90-270)	1.18
Spacing Criterion (Diagonal)	1.28
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.19 m (Diameter)
Luminous Width (90-270)	0.19 m (Diameter)
Luminous Height	0.00 m

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	15584	15767	15794
55	11991	12302	12407
65	7637	7998	8259
75	3318	3743	4031
85	1646	2338	2739

IES INDOOR REPORT
PHOTOMETRIC FILENAME : DLS V2 8 SEL UV SW 9SEL [LW,950].IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	197.56	16.60	16.60
0-30	410.97	34.50	34.50
0-40	654.58	55.00	55.00
0-60	1054.64	88.70	88.70
0-80	1173.44	98.60	98.60
0-90	1178.98	99.10	99.10
10-90	1127.27	94.80	94.80
20-40	457.02	38.40	38.40
20-50	687.44	57.80	57.80
40-70	490.41	41.20	41.20
60-80	118.80	10.00	10.00
70-80	28.45	2.40	2.40
80-90	5.54	0.50	0.50
90-110	1.23	0.10	0.10
90-120	2.50	0.20	0.20
90-130	4.11	0.30	0.30
90-150	7.66	0.60	0.60
90-180	10.59	0.90	0.90
110-180	9.35	0.80	0.80
0-180	1189.57	100.00	100.00

Total Luminaire Efficiency = 100.00%

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	51.71
10-20	145.85
20-30	213.41
30-40	243.61
40-50	230.42
50-60	169.64
60-70	90.35
70-80	28.45
80-90	5.54
90-100	0.42
100-110	0.82
110-120	1.26
120-130	1.61
130-140	1.79
140-150	1.76
150-160	1.51
160-170	1.04
170-180	0.38

IES INDOOR REPORT
PHOTOMETRIC FILENAME : DLS V2 8 SEL UV SW 9SEL [LW,950].IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
1	110	107	103	100	108	104	101	98	100	97	95	96	94	92	92	91	89	87
2	102	95	89	84	99	93	88	83	89	85	81	86	82	79	83	80	77	75
3	94	85	77	72	91	83	76	71	80	74	70	77	72	68	75	71	67	65
4	87	76	68	62	84	75	67	62	72	66	61	70	64	60	67	63	59	57
5	80	68	60	54	78	67	60	54	65	58	53	63	57	53	61	56	52	50
6	74	62	54	48	72	61	53	48	59	52	47	58	51	47	56	51	46	44
7	69	57	48	43	67	56	48	43	54	47	42	53	47	42	51	46	42	40
8	65	52	44	38	63	51	44	38	50	43	38	49	42	38	47	42	38	36
9	60	48	40	35	59	47	40	35	46	39	35	45	39	34	44	38	34	32
10	57	44	37	32	55	44	37	32	43	36	32	42	36	31	41	35	31	30


IES INDOOR REPORT
PHOTOMETRIC FILENAME : DLS V2 8 SEL UV SW 9SEL [LW,950].IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	19.1	20.5	19.5	20.9	21.2	19.2	20.7	19.6	21.0	21.4
	3H	19.8	21.1	20.2	21.5	21.8	20.1	21.4	20.5	21.7	22.1
	4H	19.9	21.1	20.3	21.5	21.9	20.2	21.4	20.6	21.8	22.2
	6H	19.9	21.0	20.3	21.4	21.8	20.2	21.4	20.7	21.8	22.2
	8H	19.9	21.0	20.4	21.4	21.8	20.3	21.3	20.7	21.7	22.2
	12H	19.9	20.9	20.3	21.3	21.8	20.3	21.3	20.7	21.7	22.1
4H	2H	19.4	20.6	19.8	21.0	21.4	19.6	20.8	20.0	21.2	21.6
	3H	20.2	21.2	20.6	21.6	22.1	20.5	21.5	20.9	21.9	22.4
	4H	20.4	21.3	20.8	21.7	22.2	20.7	21.6	21.2	22.0	22.5
	6H	20.4	21.2	20.9	21.7	22.1	20.8	21.6	21.3	22.0	22.5
	8H	20.4	21.1	20.9	21.6	22.1	20.8	21.5	21.3	22.0	22.5
	12H	20.4	21.0	20.9	21.5	22.0	20.8	21.5	21.3	22.0	22.5
8H	4H	20.4	21.1	20.8	21.5	22.0	20.7	21.4	21.2	21.9	22.4
	6H	20.4	21.0	21.0	21.5	22.0	20.8	21.4	21.4	21.9	22.4
	8H	20.5	21.0	21.0	21.5	22.0	20.9	21.4	21.4	21.9	22.4
	12H	20.5	20.9	21.0	21.4	22.0	20.9	21.4	21.4	21.9	22.5
12H	4H	20.3	21.0	20.8	21.5	22.0	20.7	21.3	21.2	21.8	22.3
	6H	20.4	21.0	21.0	21.4	22.0	20.8	21.3	21.4	21.8	22.4
	8H	20.5	20.9	21.0	21.4	22.0	20.9	21.3	21.4	21.8	22.4

Maximum UGR = 22.5

POLAR GRAPH



Maximum Candela = 548.68 Located At Horizontal Angle = 105, Vertical Angle = 1
1 - Vertical Plane Through Horizontal Angles (105 - 285) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (1) (Through Max. Cd.)