



IES INDOOR REPORT

PHOTOMETRIC FILENAME : DLS V2 4 SEL UV SW 9SEL [HI,950].IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
[TEST] 027
[TESTLAB] EVERFINE
[TESTDATE] 2020-06-15
[ISSUEDATE] 2020-08-01 08:51:37
[LAMPPOSITION] 0,0
[OTHER] EVERFINE GO-2000B_V1 SYSTEM
[MANUFAC] LumenFocus, LLC.
[LUMINAIRE] DLS v2 4 SEL UV SW 9SEL [HI,950]
[LUMCAT] LED 4" Can - 13W/50K/Dim/100-277V

CHARACTERISTICS

Lumens Per Lamp	1159.8 (1 lamp)
Total Lamp Lumens	1159.8
Luminaire Lumens	1160
Total Luminaire Efficiency	100 %
Luminaire Efficacy Rating (LER)	90
Total Luminaire Watts	12.9
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.18
Spacing Criterion (90-270)	1.18
Spacing Criterion (Diagonal)	1.24
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.18 m (Diameter)
Luminous Width (90-270)	0.18 m (Diameter)
Luminous Height	0.00 m

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	16353	16353	16353
55	12159	12159	12159
65	8468	8468	8468
75	5228	5228	5228
85	2227	2227	2227

IES INDOOR REPORT
PHOTOMETRIC FILENAME : DLS V2 4 SEL UV SW 9SEL [HI,950].IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	197.21	17.00	17.00
0-30	411.40	35.50	35.50
0-40	652.07	56.20	56.20
0-60	1018.15	87.80	87.80
0-80	1141.03	98.40	98.40
0-90	1147.81	99.00	99.00
10-90	1096.23	94.50	94.50
20-40	454.86	39.20	39.20
20-50	669.24	57.70	57.70
40-70	452.96	39.10	39.10
60-80	122.88	10.60	10.60
70-80	36.01	3.10	3.10
80-90	6.78	0.60	0.60
90-110	1.67	0.10	0.10
90-120	3.16	0.30	0.30
90-130	4.99	0.40	0.40
90-150	8.88	0.80	0.80
90-180	11.97	1.00	1.00
110-180	10.30	0.90	0.90
0-180	1159.78	100.00	100.00

Total Luminaire Efficiency = 100.00%

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	51.58
10-20	145.63
20-30	214.19
30-40	240.67
40-50	214.39
50-60	151.70
60-70	86.87
70-80	36.01
80-90	6.78
90-100	0.62
100-110	1.05
110-120	1.49
120-130	1.83
130-140	1.98
140-150	1.91
150-160	1.60
160-170	1.09
170-180	0.39

IES INDOOR REPORT
PHOTOMETRIC FILENAME : DLS V2 4 SEL UV SW 9SEL [HI,950].IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
1	110	106	103	100	108	104	101	98	100	97	95	96	94	92	92	90	89	87
2	102	95	89	84	99	93	87	83	89	85	81	86	82	79	83	80	77	75
3	94	85	77	72	91	83	76	71	80	74	70	77	72	68	75	71	67	65
4	87	76	68	62	84	75	67	62	72	66	61	70	64	60	68	63	59	57
5	80	69	60	54	78	67	60	54	65	59	54	63	57	53	61	56	52	50
6	74	62	54	48	73	61	54	48	60	53	48	58	52	47	56	51	47	45
7	69	57	49	43	68	56	48	43	55	48	43	53	47	42	52	46	42	40
8	65	52	44	39	63	52	44	39	50	43	38	49	43	38	48	42	38	36
9	61	48	40	35	59	48	40	35	46	40	35	45	39	35	44	39	35	33
10	57	45	37	32	56	44	37	32	43	36	32	42	36	32	41	36	32	30


IES INDOOR REPORT
PHOTOMETRIC FILENAME : DLS V2 4 SEL UV SW 9SEL [HI,950].IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	18.9	20.4	19.3	20.7	21.0	18.9	20.4	19.3	20.7	21.0
	3H	19.9	21.2	20.3	21.6	21.9	19.9	21.2	20.3	21.6	21.9
	4H	20.2	21.4	20.6	21.8	22.2	20.2	21.4	20.6	21.8	22.2
	6H	20.3	21.4	20.8	21.8	22.2	20.3	21.4	20.8	21.8	22.2
	8H	20.3	21.4	20.8	21.8	22.2	20.3	21.4	20.8	21.8	22.2
	12H	20.3	21.3	20.8	21.7	22.2	20.3	21.3	20.8	21.7	22.2
4H	2H	19.3	20.5	19.7	20.8	21.2	19.3	20.5	19.7	20.8	21.2
	3H	20.4	21.4	20.9	21.9	22.3	20.4	21.4	20.9	21.9	22.3
	4H	20.8	21.7	21.3	22.1	22.6	20.8	21.7	21.3	22.1	22.6
	6H	21.0	21.8	21.5	22.2	22.7	21.0	21.8	21.5	22.2	22.7
	8H	21.0	21.7	21.5	22.2	22.7	21.0	21.7	21.5	22.2	22.7
	12H	21.0	21.7	21.5	22.2	22.7	21.0	21.7	21.5	22.2	22.7
8H	4H	20.9	21.6	21.4	22.1	22.6	20.9	21.6	21.4	22.1	22.6
	6H	21.1	21.7	21.6	22.2	22.7	21.1	21.7	21.6	22.2	22.7
	8H	21.2	21.7	21.7	22.2	22.8	21.2	21.7	21.7	22.2	22.8
	12H	21.2	21.7	21.7	22.2	22.8	21.2	21.7	21.7	22.2	22.8
12H	4H	20.9	21.5	21.4	22.0	22.5	20.9	21.5	21.4	22.0	22.5
	6H	21.1	21.7	21.7	22.1	22.7	21.1	21.7	21.7	22.1	22.7
	8H	21.2	21.7	21.7	22.2	22.8	21.2	21.7	21.7	22.2	22.8

Maximum UGR = 22.8

POLAR GRAPH



Maximum Candela = 548.1 Located At Horizontal Angle = 0, Vertical Angle = 0
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (0) (Through Max. Cd.)