



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : DLS V2 4 SEL UV SW 9SEL [MD,927].IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002  
[TEST] 027  
[TESTLAB] EVERFINE  
[TESTDATE] 2020-06-17  
[ISSUEDATE] 2020-08-01 08:49:49  
[LAMPPOSITION] 0,0  
[OTHER] EVERFINE GO-2000B\_V1 SYSTEM  
[MANUFAC] LumenFocus, LLC.  
[LUMINAIRE] DLS v2 4 SEL UV SW 9SEL [MD,927]  
[LUMCAT] LED 4" Can - 10W/27K/Dim/100-277V

### CHARACTERISTICS

Lumens Per Lamp	876.69 (1 lamp)
Total Lamp Lumens	876.69
Luminaire Lumens	877
Total Luminaire Efficiency	100 %
Luminaire Efficacy Rating (LER)	92
Total Luminaire Watts	9.5
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.18
Spacing Criterion (90-270)	1.18
Spacing Criterion (Diagonal)	1.24
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.18 m (Diameter)
Luminous Width (90-270)	0.18 m (Diameter)
Luminous Height	0.00 m

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	12376	12376	12376
55	9222	9222	9222
65	6423	6423	6423
75	3975	3975	3975
85	1712	1712	1712

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : DLS V2 4 SEL UV SW 9SEL [MD,927].IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	148.85	17.00	17.00
0-30	310.43	35.40	35.40
0-40	492.08	56.10	56.10
0-60	769.29	87.70	87.80
0-80	862.53	98.40	98.40
0-90	867.71	99.00	99.00
10-90	828.77	94.50	94.50
20-40	343.23	39.20	39.20
20-50	505.43	57.70	57.70
40-70	343.09	39.10	39.10
60-80	93.24	10.60	10.60
70-80	27.36	3.10	3.10
80-90	5.18	0.60	0.60
90-110	1.23	0.10	0.10
90-120	2.34	0.30	0.30
90-130	3.72	0.40	0.40
90-150	6.63	0.80	0.80
90-180	8.96	1.00	1.00
110-180	7.73	0.90	0.90
0-180	876.66	100.00	100.00

Total Luminaire Efficiency = 100.00%

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	38.94
10-20	109.91
20-30	161.59
30-40	181.64
40-50	162.20
50-60	115.01
60-70	65.88
70-80	27.36
80-90	5.18
90-100	0.46
100-110	0.77
110-120	1.12
120-130	1.37
130-140	1.49
140-150	1.43
150-160	1.21
160-170	0.82
170-180	0.30

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : DLS V2 4 SEL UV SW 9SEL [MD,927].IES

## COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
1	110	106	103	100	108	104	101	98	100	97	95	96	93	92	92	90	89	87
2	102	95	89	84	99	93	87	83	89	85	81	86	82	79	83	80	77	75
3	94	85	77	72	91	83	76	71	80	74	70	77	72	68	75	71	67	65
4	87	76	68	62	84	75	67	62	72	66	61	70	64	60	67	63	59	57
5	80	69	60	54	78	67	60	54	65	59	53	63	57	53	61	56	52	50
6	74	62	54	48	73	61	54	48	59	53	48	58	52	47	56	51	47	45
7	69	57	49	43	68	56	48	43	54	48	43	53	47	42	52	46	42	40
8	65	52	44	39	63	51	44	39	50	43	38	49	43	38	48	42	38	36
9	61	48	40	35	59	48	40	35	46	40	35	45	39	35	44	39	35	33
10	57	45	37	32	56	44	37	32	43	36	32	42	36	32	41	36	32	30


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : DLS V2 4 SEL UV SW 9SEL [MD,927].IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	17.9	19.4	18.3	19.7	20.0	17.9	19.4	18.3	19.7	20.0
	3H	18.9	20.2	19.3	20.6	21.0	18.9	20.2	19.3	20.6	21.0
	4H	19.2	20.4	19.6	20.8	21.2	19.2	20.4	19.6	20.8	21.2
	6H	19.3	20.5	19.8	20.8	21.3	19.3	20.5	19.8	20.8	21.3
	8H	19.4	20.4	19.8	20.8	21.3	19.4	20.4	19.8	20.8	21.3
	12H	19.3	20.4	19.8	20.8	21.2	19.3	20.4	19.8	20.8	21.2
4H	2H	18.3	19.5	18.7	19.9	20.3	18.3	19.5	18.7	19.9	20.3
	3H	19.5	20.5	19.9	20.9	21.3	19.5	20.5	19.9	20.9	21.3
	4H	19.8	20.7	20.3	21.1	21.6	19.8	20.7	20.3	21.1	21.6
	6H	20.0	20.8	20.5	21.3	21.7	20.0	20.8	20.5	21.3	21.7
	8H	20.0	20.8	20.5	21.2	21.7	20.0	20.8	20.5	21.2	21.7
	12H	20.1	20.7	20.6	21.2	21.7	20.1	20.7	20.6	21.2	21.7
8H	4H	19.9	20.6	20.4	21.1	21.6	19.9	20.6	20.4	21.1	21.6
	6H	20.2	20.7	20.7	21.3	21.8	20.2	20.7	20.7	21.3	21.8
	8H	20.2	20.7	20.8	21.3	21.8	20.2	20.7	20.8	21.3	21.8
	12H	20.2	20.7	20.8	21.2	21.8	20.2	20.7	20.8	21.2	21.8
12H	4H	19.9	20.5	20.4	21.0	21.5	19.9	20.5	20.4	21.0	21.5
	6H	20.2	20.7	20.7	21.2	21.7	20.2	20.7	20.7	21.2	21.7
	8H	20.2	20.7	20.8	21.2	21.8	20.2	20.7	20.8	21.2	21.8

Maximum UGR = 21.8

POLAR GRAPH



Maximum Candela = 413.916 Located At Horizontal Angle = 0, Vertical Angle = 0  
# 1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (0) (Through Max. Cd.)