



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 2 SEL15 UV 935 @230MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-011A(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/5/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL G2 2 SEL15 UV 935

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] no enclosure.

[LAMPCAT] One LS3872A 28 LED board, 3500K

[BALLAST] One KTLD-15-UV-PS300-54-VDIM-LP1 LED driver set to 230mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1591
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	150
Total Luminaire Watts	10.6
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.30
Spacing Criterion (90-270)	1.32
Spacing Criterion (Diagonal)	1.42
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	1.99 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.02 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	7558	7316	7294
55	7405	7077	6933
65	6955	6425	6253
75	5873	5028	4916
85	3235	2233	2094

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 2 SEL15 UV 935 @230MA.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	194.70	N.A.	12.20
0-30	416.88	N.A.	26.20
0-40	690.02	N.A.	43.40
0-60	1247.68	N.A.	78.40
0-80	1565.23	N.A.	98.40
0-90	1591.19	N.A.	100.00
10-90	1541.06	N.A.	96.80
20-40	495.32	N.A.	31.10
20-50	785.44	N.A.	49.40
40-70	762.36	N.A.	47.90
60-80	317.54	N.A.	20.00
70-80	112.84	N.A.	7.10
80-90	25.97	N.A.	1.60
90-110	0.15	N.A.	0.00
90-120	0.15	N.A.	0.00
90-130	0.15	N.A.	0.00
90-150	0.15	N.A.	0.00
90-180	0.15	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	1591.34	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	50.13
10-20	144.58
20-30	222.17
30-40	273.14
40-50	290.12
50-60	267.54
60-70	204.70
70-80	112.84
80-90	25.97
90-100	0.15
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT  
 PHOTOMETRIC FILENAME : ECL G2 2 SEL15 UV 935 @230MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	93	91	88	90	88	86	84
2	99	90	83	78	96	88	82	77	85	79	75	82	77	73	78	75	71	69
3	90	79	71	64	87	77	70	64	74	68	62	72	66	61	69	64	60	58
4	82	70	61	54	80	68	60	54	66	59	53	64	57	52	61	56	51	49
5	75	62	53	46	73	61	53	46	59	51	46	57	50	45	55	49	45	42
6	69	56	47	40	68	55	46	40	53	45	40	51	45	39	50	44	39	37
7	64	51	42	36	63	50	41	35	48	41	35	47	40	35	45	39	35	33
8	60	46	37	32	58	45	37	31	44	37	31	43	36	31	42	35	31	29
9	56	42	34	28	54	42	34	28	41	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	36	30	25	23


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 2 SEL15 UV 935 @230MA.IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	19.0	20.7	19.4	21.0	21.3	19.1	20.8	19.5	21.1	21.4
	3H	20.8	22.3	21.2	22.6	23.0	20.9	22.4	21.3	22.7	23.1
	4H	21.4	22.8	21.8	23.2	23.5	21.5	22.9	21.9	23.3	23.7
	6H	21.8	23.1	22.2	23.5	23.9	21.9	23.2	22.3	23.6	24.0
	8H	21.9	23.1	22.3	23.5	23.9	22.0	23.3	22.5	23.7	24.1
	12H	21.9	23.1	22.3	23.5	23.9	22.1	23.3	22.5	23.7	24.1
4H	2H	19.7	21.1	20.1	21.4	21.8	19.8	21.2	20.2	21.5	21.9
	3H	21.6	22.8	22.0	23.2	23.6	21.7	22.9	22.1	23.3	23.7
	4H	22.4	23.4	22.8	23.8	24.3	22.4	23.5	22.9	23.9	24.4
	6H	22.8	23.8	23.3	24.2	24.7	22.9	23.9	23.4	24.3	24.8
	8H	23.0	23.8	23.4	24.3	24.8	23.1	24.0	23.5	24.4	24.9
	12H	23.0	23.8	23.5	24.3	24.8	23.2	23.9	23.6	24.4	24.9
8H	4H	22.6	23.5	23.1	23.9	24.4	22.7	23.6	23.2	24.0	24.5
	6H	23.2	23.9	23.7	24.4	24.9	23.3	24.0	23.8	24.5	25.0
	8H	23.3	24.0	23.9	24.5	25.0	23.5	24.1	24.0	24.6	25.1
	12H	23.5	24.0	24.0	24.5	25.1	23.6	24.2	24.1	24.7	25.2
12H	4H	22.6	23.4	23.1	23.9	24.4	22.7	23.5	23.2	24.0	24.4
	6H	23.2	23.9	23.7	24.3	24.9	23.3	24.0	23.8	24.4	25.0
	8H	23.4	24.0	23.9	24.5	25.0	23.5	24.1	24.0	24.6	25.2

Maximum UGR = 25.2

POLAR GRAPH



Maximum Candela = 529.675 Located At Horizontal Angle = 90, Vertical Angle = 2  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (2) (Through Max. Cd.)