



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 2 SEL25 UV 930 @400MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-011A(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/5/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL G2 2 SEL25 UV 930

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] no enclosure.

[LAMPCAT] One LS3872A 48 LED board, 3000K

[BALLAST] One KTLD-25-UV-PS450-54-VDIM-LP2 LED driver set to 400mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	3125
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	152
Total Luminaire Watts	20.6
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.30
Spacing Criterion (90-270)	1.32
Spacing Criterion (Diagonal)	1.42
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	1.99 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.02 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	14843	14370	14325
55	14543	13899	13616
65	13660	12618	12281
75	11534	9875	9655
85	6354	4386	4113

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 2 SEL25 UV 930 @400MA.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	382.41	N.A.	12.20
0-30	818.77	N.A.	26.20
0-40	1355.24	N.A.	43.40
0-60	2450.5	N.A.	78.40
0-80	3074.17	N.A.	98.40
0-90	3125.17	N.A.	100.00
10-90	3026.72	N.A.	96.80
20-40	972.83	N.A.	31.10
20-50	1542.63	N.A.	49.40
40-70	1497.31	N.A.	47.90
60-80	623.67	N.A.	20.00
70-80	221.63	N.A.	7.10
80-90	51.00	N.A.	1.60
90-110	0.29	N.A.	0.00
90-120	0.29	N.A.	0.00
90-130	0.29	N.A.	0.00
90-150	0.29	N.A.	0.00
90-180	0.29	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	3125.46	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	98.45
10-20	283.96
20-30	436.36
30-40	536.47
40-50	569.80
50-60	525.46
60-70	402.04
70-80	221.63
80-90	51.00
90-100	0.29
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 2 SEL25 UV 930 @400MA.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	93	91	88	90	88	86	84
2	99	90	83	78	96	88	82	77	85	79	75	82	77	73	78	75	71	69
3	90	79	71	64	87	77	70	64	74	68	62	72	66	61	69	64	60	58
4	82	70	61	54	80	68	60	54	66	59	53	64	57	52	61	56	51	49
5	75	62	53	46	73	61	53	46	59	51	46	57	50	45	55	49	45	42
6	69	56	47	40	68	55	46	40	53	45	40	51	45	39	50	44	39	37
7	64	51	42	35	63	50	41	35	48	41	35	47	40	35	45	39	35	33
8	60	46	37	32	58	45	37	31	44	37	31	43	36	31	42	35	31	29
9	56	42	34	28	54	42	34	28	41	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	36	30	25	23


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 2 SEL25 UV 930 @400MA.IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	21.4	23.1	21.8	23.4	23.7	21.5	23.2	21.9	23.5	23.8
	3H	23.2	24.7	23.6	25.0	25.4	23.3	24.8	23.7	25.1	25.5
	4H	23.8	25.2	24.2	25.6	25.9	23.9	25.3	24.3	25.7	26.1
	6H	24.2	25.5	24.6	25.9	26.3	24.3	25.6	24.7	26.0	26.4
	8H	24.3	25.5	24.7	25.9	26.3	24.4	25.7	24.9	26.1	26.5
	12H	24.3	25.5	24.7	25.9	26.3	24.5	25.7	24.9	26.1	26.5
4H	2H	22.1	23.5	22.5	23.8	24.2	22.2	23.6	22.6	23.9	24.3
	3H	24.0	25.2	24.4	25.6	26.0	24.1	25.3	24.5	25.7	26.1
	4H	24.8	25.8	25.2	26.2	26.7	24.8	25.9	25.3	26.3	26.8
	6H	25.2	26.2	25.7	26.6	27.1	25.3	26.3	25.8	26.7	27.2
	8H	25.4	26.2	25.8	26.7	27.1	25.5	26.4	25.9	26.8	27.3
	12H	25.4	26.2	25.9	26.7	27.2	25.6	26.3	26.0	26.8	27.3
8H	4H	25.0	25.9	25.5	26.3	26.8	25.1	26.0	25.6	26.4	26.9
	6H	25.6	26.3	26.1	26.8	27.3	25.7	26.4	26.2	26.9	27.4
	8H	25.7	26.4	26.3	26.9	27.4	25.9	26.5	26.4	27.0	27.5
	12H	25.9	26.4	26.4	26.9	27.5	26.0	26.6	26.5	27.1	27.6
12H	4H	25.0	25.8	25.5	26.3	26.8	25.1	25.9	25.6	26.4	26.8
	6H	25.6	26.3	26.1	26.7	27.3	25.7	26.4	26.2	26.8	27.4
	8H	25.8	26.4	26.3	26.9	27.4	25.9	26.5	26.4	27.0	27.6

Maximum UGR = 27.6

POLAR GRAPH



Maximum Candela = 1040.304 Located At Horizontal Angle = 90, Vertical Angle = 2  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (2) (Through Max. Cd.)