



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 2 SEL25 UV FR 940 @400MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-013(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/5/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL G2 2 SEL25 UV FR 940

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] One LS3872A 48 LED board, 4000K

[BALLAST] One KTLD-25-UV-PS450-54-VDIM-LP2 LED driver set to 400mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	3039
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	148
Total Luminaire Watts	20.6
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.24
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	1.99 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.06 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	12608	12282	12396
55	10820	11080	11386
65	8535	9617	10072
75	6060	8133	8569
85	3182	7404	7583

**IES INDOOR REPORT****PHOTOMETRIC FILENAME : ECL G2 2 SEL25 UV FR 940 @400MA.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	378.82	N.A.	12.50
0-30	805.36	N.A.	26.50
0-40	1318.05	N.A.	43.40
0-60	2307.11	N.A.	75.90
0-80	2873.17	N.A.	94.50
0-90	2983.3	N.A.	98.20
10-90	2885.43	N.A.	94.90
20-40	939.23	N.A.	30.90
20-50	1464.54	N.A.	48.20
40-70	1337.41	N.A.	44.00
60-80	566.05	N.A.	18.60
70-80	217.71	N.A.	7.20
80-90	110.13	N.A.	3.60
90-110	55.61	N.A.	1.80
90-120	55.78	N.A.	1.80
90-130	55.78	N.A.	1.80
90-150	55.78	N.A.	1.80
90-180	55.78	N.A.	1.80
110-180	0.16	N.A.	0.00
0-180	3039.08	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	97.87
10-20	280.96
20-30	426.53
30-40	512.69
40-50	525.31
50-60	463.75
60-70	348.34
70-80	217.71
80-90	110.13
90-100	44.85
100-110	10.76
110-120	0.16
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 2 SEL25 UV FR 940 @400MA.IES

## COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	108	103	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83	81
2	98	89	82	76	95	87	81	75	83	78	73	80	75	71	76	73	69	67
3	89	78	70	63	86	77	69	63	73	67	61	70	65	60	67	63	59	56
4	82	69	60	54	79	68	60	53	65	58	52	63	56	51	60	55	50	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	44	54	48	44	42
6	69	56	47	40	67	55	46	40	53	45	40	51	44	39	49	43	39	36
7	64	51	42	36	62	50	41	35	48	40	35	46	40	35	45	39	34	32
8	60	46	38	32	58	45	37	32	44	37	31	43	36	31	41	35	31	29
9	56	42	34	29	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	26	36	30	25	35	29	25	23

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 2 SEL25 UV FR 940 @400MA.IES

## UGR TABLE - CORRECTED


### Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	19.2	20.8	19.6	21.2	21.6	20.9	22.5	21.3	22.9	23.3
	3H	20.5	22.0	20.9	22.3	22.7	22.9	24.4	23.3	24.7	25.1
	4H	20.9	22.3	21.3	22.7	23.1	23.7	25.1	24.2	25.5	25.9
	6H	21.1	22.4	21.6	22.8	23.2	24.5	25.8	25.0	26.2	26.6
	8H	21.2	22.4	21.6	22.8	23.3	24.9	26.1	25.3	26.5	27.0
	12H	21.2	22.4	21.7	22.8	23.3	25.2	26.4	25.7	26.8	27.3
4H	2H	20.1	21.5	20.5	21.8	22.3	21.4	22.8	21.8	23.2	23.6
	3H	21.6	22.8	22.0	23.2	23.6	23.6	24.8	24.0	25.2	25.7
	4H	22.1	23.2	22.6	23.6	24.1	24.6	25.7	25.1	26.1	26.6
	6H	22.4	23.4	22.9	23.9	24.4	25.5	26.5	26.0	27.0	27.5
	8H	22.5	23.4	23.0	23.9	24.4	26.0	26.9	26.5	27.3	27.9
	12H	22.6	23.4	23.1	23.9	24.4	26.4	27.2	27.0	27.8	28.3
8H	4H	22.7	23.5	23.1	24.0	24.5	24.8	25.7	25.3	26.2	26.7
	6H	23.2	23.9	23.7	24.4	24.9	25.9	26.7	26.5	27.2	27.7
	8H	23.3	24.0	23.9	24.5	25.1	26.5	27.2	27.1	27.7	28.2
	12H	23.4	24.0	24.0	24.6	25.2	27.1	27.7	27.7	28.2	28.8
12H	4H	22.8	23.6	23.3	24.1	24.6	24.8	25.6	25.3	26.1	26.6
	6H	23.4	24.1	23.9	24.5	25.1	26.0	26.7	26.6	27.2	27.7
	8H	23.6	24.2	24.2	24.7	25.3	26.6	27.2	27.2	27.7	28.3

Maximum UGR = 28.8

POLAR GRAPH



Maximum Candela = 1034.793 Located At Horizontal Angle = 90, Vertical Angle = 1.5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (1.5) (Through Max. Cd.)