



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 2 SEL35 UV FR 940 @600MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-013(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/5/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL G2 2 SEL35 UV FR 940

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] One LS3872A 64 LED board, 4000K

[BALLAST] One KTLD-35-UV-PS650-54-VDIM-LM1 LED driver set to 600mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4514
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	150
Total Luminaire Watts	30.1
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.24
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	1.99 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.06 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	18725	18240	18410
55	16070	16455	16911
65	12675	14284	14959
75	9001	12079	12727
85	4725	10997	11263

IES INDOOR REPORT**PHOTOMETRIC FILENAME : ECL G2 2 SEL35 UV FR 940 @600MA.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	562.62	N.A.	12.50
0-30	1196.1	N.A.	26.50
0-40	1957.55	N.A.	43.40
0-60	3426.49	N.A.	75.90
0-80	4267.18	N.A.	94.50
0-90	4430.75	N.A.	98.20
10-90	4285.4	N.A.	94.90
20-40	1394.93	N.A.	30.90
20-50	2175.11	N.A.	48.20
40-70	1986.29	N.A.	44.00
60-80	840.69	N.A.	18.60
70-80	323.34	N.A.	7.20
80-90	163.56	N.A.	3.60
90-110	82.60	N.A.	1.80
90-120	82.84	N.A.	1.80
90-130	82.84	N.A.	1.80
90-150	82.84	N.A.	1.80
90-180	82.84	N.A.	1.80
110-180	0.24	N.A.	0.00
0-180	4513.59	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	145.35
10-20	417.27
20-30	633.48
30-40	761.44
40-50	780.18
50-60	688.76
60-70	517.35
70-80	323.34
80-90	163.56
90-100	66.61
100-110	15.98
110-120	0.24
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 2 SEL35 UV FR 940 @600MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	108	103	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83	81
2	98	89	82	76	95	87	81	75	83	78	73	80	75	71	76	73	69	67
3	89	78	70	63	86	77	69	63	73	67	61	70	65	60	67	63	59	56
4	82	69	60	54	79	68	60	53	65	58	52	63	56	51	60	55	50	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	44	54	48	44	42
6	69	56	47	40	67	55	46	40	53	45	40	51	44	39	49	43	39	36
7	64	51	42	36	62	50	41	35	48	40	35	46	40	35	45	39	34	32
8	60	46	38	32	58	45	37	32	44	37	31	42	36	31	41	35	31	29
9	56	42	34	29	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	26	36	30	25	35	29	25	23

IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 2 SEL35 UV FR 940 @600MA.IES

UGR TABLE - CORRECTED


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	20.5	22.1	20.9	22.5	22.9	22.2	23.8	22.6	24.2	24.6
	3H	21.8	23.3	22.2	23.6	24.0	24.2	25.7	24.6	26.0	26.4
	4H	22.2	23.6	22.6	24.0	24.4	25.0	26.4	25.5	26.8	27.2
	6H	22.4	23.7	22.9	24.1	24.5	25.8	27.1	26.3	27.5	27.9
	8H	22.5	23.7	22.9	24.1	24.6	26.2	27.4	26.6	27.8	28.3
	12H	22.5	23.7	23.0	24.1	24.6	26.5	27.7	27.0	28.1	28.6
4H	2H	21.4	22.7	21.8	23.1	23.6	22.7	24.1	23.1	24.5	24.9
	3H	22.9	24.1	23.3	24.5	24.9	24.9	26.1	25.3	26.5	27.0
	4H	23.4	24.5	23.9	24.9	25.4	25.9	27.0	26.4	27.4	27.9
	6H	23.7	24.7	24.2	25.2	25.7	26.8	27.8	27.3	28.3	28.8
	8H	23.8	24.7	24.3	25.2	25.7	27.3	28.2	27.8	28.6	29.1
	12H	23.9	24.7	24.4	25.2	25.7	27.7	28.5	28.3	29.1	29.6
8H	4H	24.0	24.8	24.4	25.3	25.8	26.1	27.0	26.6	27.5	28.0
	6H	24.5	25.2	25.0	25.7	26.2	27.2	28.0	27.8	28.5	29.0
	8H	24.6	25.3	25.2	25.8	26.4	27.8	28.5	28.4	29.0	29.5
	12H	24.7	25.3	25.3	25.9	26.5	28.4	29.0	29.0	29.5	30.1
12H	4H	24.1	24.9	24.6	25.4	25.9	26.1	26.9	26.6	27.4	27.9
	6H	24.7	25.4	25.2	25.8	26.4	27.3	28.0	27.9	28.5	29.0
	8H	24.9	25.5	25.5	26.0	26.6	27.9	28.5	28.5	29.0	29.6

Maximum UGR = 30.1

POLAR GRAPH



Maximum Candela = 1536.859 Located At Horizontal Angle = 90, Vertical Angle = 1.5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (1.5) (Through Max. Cd.)