



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 4 SEL75 UV FR 935 @1200MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-018(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/5/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL G2 4 SEL75 UV FR 935

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] Two LS3872A 64 LED boards, 3500K

[BALLAST] One KTLD-75-UV-PS1400-54-VDIM-LM2 LED driver set to 1200mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	8914
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	148
Total Luminaire Watts	60.2
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	4.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.06 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	18777	18077	18059
55	16366	16404	16587
65	13154	14344	14642
75	9547	12259	12396
85	5476	11407	10873

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 4 SEL75 UV FR 935 @1200MA.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	1108.21	N.A.	12.40
0-30	2356.72	N.A.	26.40
0-40	3858.89	N.A.	43.30
0-60	6764.38	N.A.	75.90
0-80	8432.19	N.A.	94.60
0-90	8754.51	N.A.	98.20
10-90	8468.35	N.A.	95.00
20-40	2750.68	N.A.	30.90
20-50	4292.02	N.A.	48.20
40-70	3932.49	N.A.	44.10
60-80	1667.81	N.A.	18.70
70-80	640.81	N.A.	7.20
80-90	322.32	N.A.	3.60
90-110	158.89	N.A.	1.80
90-120	159.21	N.A.	1.80
90-130	159.21	N.A.	1.80
90-150	159.21	N.A.	1.80
90-180	159.21	N.A.	1.80
110-180	0.32	N.A.	0.00
0-180	8913.72	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	286.16
10-20	822.05
20-30	1248.51
30-40	1502.17
40-50	1541.34
50-60	1364.15
60-70	1027.00
70-80	640.81
80-90	322.32
90-100	129.20
100-110	29.68
110-120	0.32
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 4 SEL75 UV FR 935 @1200MA.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	108	103	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83	81
2	98	89	82	76	95	87	81	75	83	78	73	80	75	71	76	73	69	67
3	89	78	70	63	86	77	69	63	73	67	61	70	65	60	67	63	59	56
4	82	69	60	54	79	68	60	53	65	58	52	63	56	51	60	55	50	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	44	54	48	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	49	43	38	36
7	64	51	42	36	62	50	41	35	48	40	35	46	40	35	45	39	34	32
8	60	46	38	32	58	45	37	32	44	36	31	42	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 4 SEL75 UV FR 935 @1200MA.IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	20.6	22.2	21.0	22.6	22.9	22.3	23.9	22.7	24.2	24.6
	3H	21.9	23.4	22.3	23.7	24.1	24.3	25.7	24.7	26.1	26.5
	4H	22.3	23.7	22.7	24.1	24.5	25.1	26.5	25.5	26.9	27.3
	6H	22.5	23.8	23.0	24.2	24.6	25.9	27.2	26.3	27.6	28.0
	8H	22.6	23.8	23.0	24.2	24.7	26.3	27.5	26.7	27.9	28.4
	12H	22.6	23.8	23.1	24.2	24.7	26.7	27.8	27.1	28.2	28.7
4H	2H	21.4	22.8	21.9	23.2	23.6	22.7	24.1	23.2	24.5	24.9
	3H	23.0	24.1	23.4	24.6	25.0	25.0	26.1	25.4	26.6	27.0
	4H	23.5	24.6	24.0	25.0	25.5	26.0	27.0	26.4	27.5	28.0
	6H	23.8	24.8	24.3	25.3	25.8	26.9	27.9	27.4	28.3	28.8
	8H	23.9	24.8	24.4	25.3	25.8	27.4	28.3	27.9	28.7	29.2
	12H	24.0	24.8	24.5	25.3	25.8	27.9	28.7	28.4	29.2	29.7
8H	4H	24.1	24.9	24.5	25.4	25.9	26.2	27.1	26.7	27.5	28.1
	6H	24.6	25.3	25.1	25.8	26.4	27.3	28.1	27.8	28.6	29.1
	8H	24.8	25.4	25.3	25.9	26.5	27.9	28.6	28.4	29.1	29.6
	12H	24.9	25.4	25.4	26.0	26.6	28.5	29.1	29.1	29.7	30.3
12H	4H	24.2	25.0	24.7	25.5	26.0	26.2	27.0	26.7	27.5	28.0
	6H	24.8	25.5	25.4	26.0	26.5	27.4	28.0	27.9	28.5	29.1
	8H	25.0	25.6	25.6	26.2	26.8	28.0	28.6	28.5	29.1	29.7

Maximum UGR = 30.3

POLAR GRAPH



Maximum Candela = 3029.049 Located At Horizontal Angle = 90, Vertical Angle = 3.5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (3.5) (Through Max. Cd.)